



Minimum Performance at Standard Test Conditions

Voltage at Nominal Power [V]*: 30.74 Current at Nominal Power [A]*: 8.46

Open Circuit Voltage [V]: 37.70 Short Circuit Current [A]: 9.07

* typical values, actual values may differ

Note 2 - Must meet the requirements of an apporved serves box as per OESC. In addition the switch shall have a visible break isolation and should be pad-lockable from outdoors

Note 3 - Must be labeled "Distributed Generation System Disconnect - Warning - Two Power

Sources and Maximum Fuse size of 60 amps Note 4 - Utility meter, generation meter and distributed generation disconnect switch must be mounted together on exterior wall of the house 1.7m to 2.1. above Grade as per EHM standing

Note 5- Configuration and voltage rating of the proposed meter must match the existing metering equipment

Note 6- Permanent SLD must be attached to the blank cell of the meter base and must follow Enersource Lamacoid/engraved SLD template

Note 7- Permanent Single Line Diangram must be attached to the blank cell of the meter base & must follow "Enersource Lamacoid/Engraved SLC Template"

Note 8- The existing equipment drawn on the schematic must be distinguishable from the proposed installation. The common coupling (PCC) must be clearly identified on the SLD