

## Water Quality 2022

### 7.1 Water Quality Objectives for EPCOR

2022

Parameter	Approval Requirement	EPCOR Internal Limit	EPCOR Target
Turbidity (NTU)			
Individual Filters	<0.3	<0.1 (2)	<0.08
Distribution System	N/A	< 1 (1)	< 1
Distribution System (Maintenance)	N/A	< 3 (1)	< 1
Colour (TCU)	<15 (3)	<10 (1)	<3
pH (25°C)	6.5 - 8.5	7.3 - 8.3 (1)	7.4 - 8.0
Taste and Odour	Inoffensive (3)	Inoffensive (1)	Inoffensive
E.coli (PA/100 mL)	absent	absent (1)	absent
Total Coliforms (PA/100 mL)	absent	absent (1)	absent
Total Chlorine Residual (mg/L)			
Water Treatment Plant Effluent	>1.0	1.3 - 2.4 (2)	1.9 - 2.2
Reservoirs	>0.5	1.0 - 2.4 (1)	1.2 - 2.2
Distribution	>0.5 (4)	1.0 - 2.4 (1)	1.0 - 2.2
Fluoride: (mg/L)			
Reservoir Effluent	0.5 - 0.9	0.6 - 0.8 (1)	0.6 - 0.8
Trihalomethanes (mg/L)			
Reservoir Effluent	<0.100	<0.050 (1)	<0.040
Distribution System	<0.100	<0.050 (1)	<0.040
UV254 % Transmittance			
E.L. Smith		>89% (2)	>90%
Rossdale		>87% (2)	>88%
HAA (mg/L)			
Reservoir Effluent	< 0.080	< 0.040 (1)	<0.035
Distribution System	< 0.080	< 0.040 (1)	<0.035
NDMA (mg/L):			
Reservoir Effluent	< 0.000040	< 0.000010 (1)	<0.000005
Distribution System	< 0.000040	< 0.000010 (1)	
Microorganism Log Removal at Water			
<i>Giardia</i>	≥5.5	≥6.0 (2)	>6.5
<i>Cryptosporidium</i>	≥5.5	≥5.3 (2)	>6.0
Virus	≥4.0	≥4.5 (2)	>5.0

(1) Limit based on City of Edmonton Performance Based Rate (PBR) agreement

(2) Limit based on EPCOR Action Level

(3) Aesthetic Objective

(4) in 75% of samples collected in a day

All values are expressed in units of mg/L unless otherwise stated.

Based on March 2022 Summary of Epcor Edmonton Water Quality Standards.

**7.2 SUMMARY OF MAJOR CHEMICALS, MICROBIOLOGICAL, AND PHYSICAL  
PARAMETERS OF EDMONTON DRINKING WATER PRODUCED  
AT WATER TREATMENT PLANTS**

**2022**

<b>Parameter</b>	<b>Unit</b>	<b>MAC*</b>	<b>Average</b>	<b>Median</b>	<b>Min</b>	<b>Max</b>	<b>Count</b>
Alkalinity Total	mg CaCO <sub>3</sub> /L		121	121	90	143	730
Aluminum	mg/L	2.9	0.082	0.082	0.018	0.176	25
Arsenic	mg/L	0.01	0.0002	<0.0002	<0.0002	0.0003	25
Bromate Dissolved	mg/L	0.01	<0.005	<0.005	<0.005	<0.005	107
Bromodichloromethane	µg/L		<0.5	<0.5	<0.5	<0.5	726
Cadmium	mg/L	0.007	<0.0002	<0.0002	<0.0002	<0.0002	25
Calcium Hardness	mg/L CaCO <sub>3</sub>		112	111	93	198	730
Chlorate Dissolved	mg/L	1	0.128	0.129	<0.100	0.264	107
Chloride Dissolved	mg/L	(250)	6.04	5.63	4.34	12.20	107
Chlorite Dissolved	mg/L	1	<0.01	<0.20	<0.20	<0.20	107
Chromium	mg/L	0.05	<0.0002	<0.0002	<0.0002	<0.0002	25
Colour	TCU	(15)	0.8	0.7	<0.5	2.1	730
Conductivity	µS/cm	(<1)	382	372	320	527	105
Copper	mg/L	2 (1)	<0.0050	<0.0050	<0.0050	<0.0050	25
Fluoride	mg/L	1.5	0.68	0.68	0.59	0.77	730
Haloacetic Acids, total (HAA5)	ug/L	80	21.1	17.4	12.2	37.8	23
Iron	mg/L	(0.3)	<0.0050	<0.0050	<0.0050	<0.0050	25
Lead	mg/L	0.005	<0.0002	<0.0002	<0.0002	<0.0002	25
Manganese	mg/L	0.12 (0.02)	0.0023	<0.0020	<0.0020	0.0070	25
Mercury	mg/L	0.001	<0.0002	<0.0002	<0.0002	<0.0002	25
Nitrate (as N) Dissolved	mg/L	10	0.053	0.050	<0.010	0.263	107
Nitrite (as N) Dissolved	mg/L	1	<0.01	<0.01	<0.01	<0.01	107
pH	N/A	(7.0 - 10.5)	7.8	7.8	7.4	8.2	730
Potassium	mg/L		0.92	0.80	0.40	2.20	25
Sodium	mg/L	(200)	11.68	7.60	6.10	36.20	25
Sulphate Dissolved	mg/L	(500)	67.6	59.4	51.5	142.0	107
Total Chlorine	mg/L	>1.0	2.06	2.07	1.18	2.32	730
Total Dissolved Solids	mg/L	(500)	223	220	186	279	25
Total Hardness	mg/L CaCO <sub>3</sub>		170	169	142	246	710
Total Organic Carbon	mg/L C		1.6	1.2	<0.6	9.9	105
Trihalomethanes	µg/L	100	14.4	11.0	3.1	42.1	726
Turbidity	NTU		0.05	0.05	<0.04	0.16	730
Uranium	mg/L	0.02	0.0005	<0.0005	<0.0005	0.0006	25
Zinc	mg/L	(5.0)	<0.0050	<0.0050	<0.0050	<0.0050	25

**Bacteriological Data**

Coliforms, total	PA/100mL		Absent	Absent	Absent	Absent	729
E. coli	PA/100mL		Absent	Absent	Absent	Absent	729

\* Numbers with no brackets are Health Canada Guidelines for Canadian Drinking Water Quality (GCDWQ) Maximum Acceptable Concentrations (MAC) and/or a limit set out in the Alberta Environment and Parks (AEP) Operating Approval 638-04-00. Limits in brackets indicate Aesthetic Objectives or Operational Guidelines (OG) and are not Approval limits.

### 7.3 SUMMARY OF LABORATORY ANALYSIS - 2022

#### DISTRIBUTION OF TESTING

##### Drinking Water Testing

		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Water Treatment Plant	# Tests	7,438	6,875	7,964	7,416	7,506	7,363	7,062	7,631	7,248	7,404	7,189	7,460	88,556
	# Samples	268	248	334	288	269	265	268	270	269	269	266	272	3,286
Field Reservoirs	# Tests	784	684	814	801	916	688	866	758	868	716	890	692	9,477
	# Samples	55	48	60	56	64	48	52	66	53	56	59	50	667
Routine Distribution System	# Tests	761	718	712	763	660	632	657	664	736	788	788	752	8,631
	# Samples	156	146	146	156	142	134	134	144	132	145	131	136	1,702
System Depressurization/Repair	# Tests	268	196	232	212	332	276	304	352	344	272	232	220	3,240
	# Samples	67	49	58	53	83	69	76	88	86	68	58	55	810
Customer Complaints	# Tests	296	706	888	586	814	665	888	370	592	666	370	370	7,211
	# Samples	4	10	12	9	11	9	12	5	8	9	5	5	99
<b>Total</b>	# Tests	9,547	9,179	10,610	9,778	10,228	9,624	9,777	9,775	9,788	9,846	9,469	9,494	117,115
	# Samples	550	501	610	562	569	525	542	573	548	547	519	518	6,564

##### Additional Testing

		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
New Watermain Testing	# Tests	95	0	20	10	155	175	205	115	122	355	655	195	2,102
	# Samples	19	0	4	2	31	35	41	23	25	71	131	39	421
Water Treatment Plant Waste Discharge	# Tests	155	63	79	80	87	104	127	77	56	73	51	178	1,130
	# Samples	44	40	49	41	46	49	42	37	41	32	41	44	506
Quality Control	# Tests	4,183	3,670	4,412	3,770	4,311	3,595	2,648	4,367	4,206	3,584	3,572	3,767	46,085
	# Samples	707	714	917	725	816	851	805	938	819	763	793	909	9,757
Externally Contracted Analyses	# Tests	104	113	174	114	130	128	136	172	110	118	156	108	1,563
	# Samples	52	58	69	57	65	64	68	74	55	59	66	54	741
<b>Total</b>	# Tests	4,537	3,846	4,685	3,974	4,683	4,002	3,116	4,731	4,494	4,130	4,434	4,248	50,880
	# Samples	822	812	1,039	825	958	999	956	1,072	940	925	1,031	1,046	11,425

		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
<b>Total</b>	# Tests	14,084	13,025	15,295	13,752	14,911	13,626	12,893	14,506	14,282	13,976	13,903	13,742	167,995
	# Samples	1,368	1,307	1,639	1,382	1,523	1,519	1,493	1,640	1,484	1,468	1,545	1,560	17,928

**7.4 Bacteriological Data: Water Treatment Plants  
2022**

	Coliforms, total					E. coli					cATP (pg/mL)				
	Count	# +ve	% +ve	Mean	Min	Max	# +ve	% +ve	Mean	Min	Max	Count	Mean	Min	Max
<b>January</b>															
Rossdale Raw (MPN/100mL)	32			81	1	387			9	1	51	1	10.7	10.7	10.7
E.L. Smith Raw (MPN/100mL)	5			44	31	68			1	1	2	1	15.0	15.0	15.0
<b>Raw River Water Entering the Treatment Plants</b>	<b>37</b>			<b>76</b>	<b>1</b>	<b>387</b>			<b>8</b>	<b>1</b>	<b>51</b>	<b>2</b>	<b>12.9</b>	<b>10.7</b>	<b>15.0</b>
Rossdale Treated (PA/100mL)	31	0	0.0				0	0.0				31	0.61	0.03	1.00
E.L. Smith Treated (PA/100mL)	31	0	0.0				0	0.0				31	0.43	0.03	1.00
<b>Water Entering the Plant Reservoir</b>	<b>62</b>	<b>0</b>	<b>0.0</b>				<b>0</b>	<b>0.0</b>				<b>62</b>	<b>0.52</b>	<b>0.03</b>	<b>1.00</b>
Rossdale Reservoir (PA/100mL)	31	0	0.0				0	0.0				31	0.66	0.03	1.00
E.L. Smith Reservoir (PA/100mL)	31	0	0.0				0	0.0				31	0.49	0.03	1.00
<b>Treated Water Entering the Distribution System</b>	<b>62</b>	<b>0</b>	<b>0.0</b>				<b>0</b>	<b>0.0</b>				<b>62</b>	<b>0.58</b>	<b>0.03</b>	<b>1.00</b>
<b>February</b>															
Rossdale Raw (MPN/100mL)	29			188	1	1,990			12	1	58	1	24.8	24.8	24.8
E.L. Smith Raw (MPN/100mL)	5			57	19	196			1	1	3	1	29.6	29.6	29.6
<b>Raw River Water Entering the Treatment Plants</b>	<b>34</b>			<b>169</b>	<b>1</b>	<b>1,990</b>			<b>10</b>	<b>1</b>	<b>58</b>	<b>2</b>	<b>27.2</b>	<b>24.8</b>	<b>29.6</b>
Rossdale Treated (PA/100mL)	28	0	0.0				0	0.0				28	0.48	0.03	1.00
E.L. Smith Treated (PA/100mL)	28	0	0.0				0	0.0				28	0.40	0.03	1.00
<b>Water Entering the Plant Reservoir</b>	<b>56</b>	<b>0</b>	<b>0.0</b>				<b>0</b>	<b>0.0</b>				<b>56</b>	<b>0.44</b>	<b>0.03</b>	<b>1.00</b>
Rossdale Reservoir (PA/100mL)	28	0	0.0				0	0.0				28	0.61	0.04	1.00
E.L. Smith Reservoir (PA/100mL)	29	0	0.0				0	0.0				29	0.22	0.03	1.00
<b>Treated Water Entering the Distribution System</b>	<b>57</b>	<b>0</b>	<b>0.0</b>				<b>0</b>	<b>0.0</b>				<b>57</b>	<b>0.41</b>	<b>0.03</b>	<b>1.00</b>

## 7.4 Bacteriological Data: Water Treatment Plants

2022

	Coliforms, total					E. coli					cATP (pg/mL)				
	Count	# +ve	% +ve	Mean	Min	Max	# +ve	% +ve	Mean	Min	Max	Count	Mean	Min	Max
<b>March</b>															
Rossdale Raw (MPN/100mL)	32			1,105	1	7,310			40	1	161	1	11.5	11.5	11.5
E.L. Smith Raw (MPN/100mL)	5			240	8	722			5	1	20	1	15.2	15.2	15.2
<b>Raw River Water Entering the Treatment Plants</b>	<b>37</b>			<b>988</b>	<b>1</b>	<b>7,310</b>			<b>35</b>	<b>1</b>	<b>161</b>	<b>2</b>	<b>13.3</b>	<b>11.5</b>	<b>15.2</b>
Rossdale Treated (PA/100mL)	31	0	0.0				0	0.0				31	0.70	0.03	1.00
E.L. Smith Treated (PA/100mL)	31	0	0.0				0	0.0				31	0.62	0.03	1.00
<b>Water Entering the Plant Reservoir</b>	<b>62</b>	<b>0</b>	<b>0.0</b>				<b>0</b>	<b>0.0</b>				<b>62</b>	<b>0.66</b>	<b>0.03</b>	<b>1.00</b>
Rossdale Reservoir (PA/100mL)	31	0	0.0				0	0.0				31	0.76	0.03	1.00
E.L. Smith Reservoir (PA/100mL)	31	0	0.0				0	0.0				31	0.53	0.03	1.00
<b>Treated Water Entering the Distribution System</b>	<b>62</b>	<b>0</b>	<b>0.0</b>				<b>0</b>	<b>0.0</b>				<b>62</b>	<b>0.64</b>	<b>0.03</b>	<b>1.00</b>
<b>April</b>															
Rossdale Raw (MPN/100mL)	31			356	1	2,420			26	1	276	1	78.4	78.4	78.4
E.L. Smith Raw (MPN/100mL)	5			148	43	291			1	1	2	1	91.7	91.7	91.7
<b>Raw River Water Entering the Treatment Plants</b>	<b>36</b>			<b>327</b>	<b>1</b>	<b>2,420</b>			<b>23</b>	<b>1</b>	<b>276</b>	<b>2</b>	<b>85.0</b>	<b>78.4</b>	<b>91.7</b>
Rossdale Treated (PA/100mL)	30	0	0.0				0	0.0				30	0.75	0.03	1.00
E.L. Smith Treated (PA/100mL)	30	0	0.0				0	0.0				30	0.67	0.03	1.00
<b>Water Entering the Plant Reservoir</b>	<b>60</b>	<b>0</b>	<b>0.0</b>				<b>0</b>	<b>0.0</b>				<b>60</b>	<b>0.71</b>	<b>0.03</b>	<b>1.00</b>
Rossdale Reservoir (PA/100mL)	30	0	0.0				0	0.0				30	0.72	0.03	1.00
E.L. Smith Reservoir (PA/100mL)	30	0	0.0				0	0.0				30	0.75	0.03	1.00
<b>Treated Water Entering the Distribution System</b>	<b>60</b>	<b>0</b>	<b>0.0</b>				<b>0</b>	<b>0.0</b>				<b>60</b>	<b>0.73</b>	<b>0.03</b>	<b>1.00</b>

## 7.4 Bacteriological Data: Water Treatment Plants

2022

	Coliforms, total					E. coli					cATP (pg/mL)				
	Count	# +ve	% +ve	Mean	Min	Max	# +ve	% +ve	Mean	Min	Max	Count	Mean	Min	Max
<b>May</b>															
Rossdale Raw (MPN/100mL)	31			344	55	2,670			26	2	158	1	269	269	269
E.L. Smith Raw (MPN/100mL)	4			91	71	121			2	1	2	1	78.2	78.2	78.2
<b>Raw River Water Entering the Treatment Plants</b>	35			315	55	2,670			23	1	158	2	174	78.2	269
Rossdale Treated (PA/100mL)	31	0	0.0				0	0.0				31	0.76	0.03	1.00
E.L. Smith Treated (PA/100mL)	31	0	0.0				0	0.0				31	0.61	0.02	1.00
<b>Water Entering the Plant Reservoir</b>	62	0	0.0				0	0.0				62	0.69	0.02	1.00
Rossdale Reservoir (PA/100mL)	31	0	0.0				0	0.0				31	0.79	0.02	1.00
E.L. Smith Reservoir (PA/100mL)	31	0	0.0				0	0.0				31	0.80	0.03	1.00
<b>Treated Water Entering the Distribution System</b>	62	0	0.0				0	0.0				62	0.79	0.02	1.00
<b>June</b>															
Rossdale Raw (MPN/100mL)	30			2,510	35	15,400			128	3	654	1	178	178	178
E.L. Smith Raw (MPN/100mL)	5			882	88	1,730			44	2	84	1	182	182	182
<b>Raw River Water Entering the Treatment Plants</b>	35			2,278	35	15,400			116	2	654	2	180	178	182
Rossdale Treated (PA/100mL)	30	0	0.0				0	0.0				30	0.82	0.07	1.00
E.L. Smith Treated (PA/100mL)	30	0	0.0				0	0.0				30	0.64	0.03	1.00
<b>Water Entering the Plant Reservoir</b>	60	0	0.0				0	0.0				60	0.73	0.03	1.00
Rossdale Reservoir (PA/100mL)	30	0	0.0				0	0.0				30	0.77	0.07	1.00
E.L. Smith Reservoir (PA/100mL)	30	0	0.0				0	0.0				30	0.82	0.03	1.00
<b>Treated Water Entering the Distribution System</b>	60	0	0.0				0	0.0				60	0.79	0.03	1.00

## 7.4 Bacteriological Data: Water Treatment Plants

2022

	Coliforms, total					E. coli					cATP (pg/mL)				
	Count	# +ve	% +ve	Mean	Min	Max	# +ve	% +ve	Mean	Min	Max	Count	Mean	Min	Max
<b>July</b>															
Rossdale Raw (MPN/100mL)	31			4,014	186	48,400			232	4	3,720	1	268	268	268
E.L. Smith Raw (MPN/100mL)	4			1,617	727	4,200			57	7	150	0			
<b>Raw River Water Entering the Treatment Plants</b>	35			3,740	186	48,400			212	4	3,720	1	268	268	268
Rossdale Treated (PA/100mL)	31	0	0.0				0	0.0				31	0.92	0.06	1.00
E.L. Smith Treated (PA/100mL)	31	0	0.0				0	0.0				31	0.80	0.03	1.00
<b>Water Entering the Plant Reservoir</b>	62	0	0.0				0	0.0				62	0.86	0.03	1.00
Rossdale Reservoir (PA/100mL)	31	0	0.0				0	0.0				31	0.88	0.03	1.00
E.L. Smith Reservoir (PA/100mL)	31	0	0.0				0	0.0				31	0.88	0.05	1.00
<b>Treated Water Entering the Distribution System</b>	62	0	0.0				0	0.0				62	0.88	0.03	1.00
<b>August</b>															
Rossdale Raw (MPN/100mL)	31			466	75	4,370			24	3	170	1	49.2	49.2	49.2
E.L. Smith Raw (MPN/100mL)	5			324	172	613			10	5	14	1	55.4	55.4	55.4
<b>Raw River Water Entering the Treatment Plants</b>	36			446	75	4,370			22	3	170	2	52.3	49.2	55.4
Rossdale Treated (PA/100mL)	31	0	0.0				0	0.0				31	0.70	0.03	1.00
E.L. Smith Treated (PA/100mL)	31	0	0.0				0	0.0				31	0.86	0.08	1.00
<b>Water Entering the Plant Reservoir</b>	62	0	0.0				0	0.0				62	0.78	0.03	1.00
Rossdale Reservoir (PA/100mL)	31	0	0.0				0	0.0				31	0.82	0.03	1.00
E.L. Smith Reservoir (PA/100mL)	31	0	0.0				0	0.0				31	0.89	0.06	1.00
<b>Treated Water Entering the Distribution System</b>	62	0	0.0				0	0.0				62	0.85	0.03	1.00

**7.4 Bacteriological Data: Water Treatment Plants  
2022**

	Coliforms, total					E. coli					cATP (pg/mL)				
	Count	# +ve	% +ve	Mean	Min	Max	# +ve	% +ve	Mean	Min	Max	Count	Mean	Min	Max
<b>September</b>															
Rossdale Raw (MPN/100mL)	30			180	34	921			23	1	194	1	58.4	58.4	58.4
E.L. Smith Raw (MPN/100mL)	4			231	79	579			70	6	248	1	81.8	81.8	81.8
<b>Raw River Water Entering the Treatment Plants</b>	34			186	34	921			29	1	248	2	70.1	58.4	81.8
Rossdale Treated (PA/100mL)	30	0	0.0				0	0.0				30	0.68	0.15	1.00
E.L. Smith Treated (PA/100mL)	30	0	0.0				0	0.0				30	0.60	0.12	1.04
<b>Water Entering the Plant Reservoir</b>	60	0	0.0				0	0.0				60	0.64	0.12	1.04
Rossdale Reservoir (PA/100mL)	30	0	0.0				0	0.0				30	0.66	0.11	1.33
E.L. Smith Reservoir (PA/100mL)	30	0	0.0				0	0.0				30	0.76	0.15	1.17
<b>Treated Water Entering the Distribution System</b>	60	0	0.0				0	0.0				60	0.71	0.11	1.33
<b>October</b>															
Rossdale Raw (MPN/100mL)	31			193	62	1,990			57	1	1,550	1	45.3	45.3	45.3
E.L. Smith Raw (MPN/100mL)	4			206	172	248			10	2	21	1	57.5	57.5	57.5
<b>Raw River Water Entering the Treatment Plants</b>	35			194	62	1,990			52	1	1,550	2	51.4	45.3	57.5
Rossdale Treated (PA/100mL)	31	0	0.0				0	0.0				31	0.90	0.16	1.00
E.L. Smith Treated (PA/100mL)	30	0	0.0				0	0.0				30	0.50	0.10	1.00
<b>Water Entering the Plant Reservoir</b>	61	0	0.0				0	0.0				61	0.70	0.10	1.00
Rossdale Reservoir (PA/100mL)	31	0	0.0				0	0.0				31	0.92	0.15	1.00
E.L. Smith Reservoir (PA/100mL)	31	0	0.0				0	0.0				31	0.61	0.11	1.00
<b>Treated Water Entering the Distribution System</b>	62	0	0.0				0	0.0				62	0.76	0.11	1.00



**7.4 Bacteriological Data: Water Treatment Plants  
2022**

	Coliforms, total					E. coli					cATP (pg/mL)				
	Count	# +ve	% +ve	Mean	Min	Max	# +ve	% +ve	Mean	Min	Max	Count	Mean	Min	Max
<b>November</b>															
Rossdale Raw (MPN/100mL)	29			272	75	921			23	1	126	1	23.1	23.1	23.1
E.L. Smith Raw (MPN/100mL)	4			209	166	261			9	5	15	0			
<b>Raw River Water Entering the Treatment Plants</b>	<b>33</b>			<b>264</b>	<b>75</b>	<b>921</b>			<b>21</b>	<b>1</b>	<b>126</b>	<b>1</b>	<b>23.1</b>	<b>23.1</b>	<b>23.1</b>
Rossdale Treated (PA/100mL)	29	0	0.0				0	0.0				29	0.73	0.11	1.48
E.L. Smith Treated (PA/100mL)	29	0	0.0				0	0.0				29	0.58	0.10	1.33
<b>Water Entering the Plant Reservoir</b>	<b>58</b>	<b>0</b>	<b>0.0</b>				<b>0</b>	<b>0.0</b>				<b>58</b>	<b>0.66</b>	<b>0.10</b>	<b>1.48</b>
Rossdale Reservoir (PA/100mL)	29	0	0.0				0	0.0				29	0.82	0.10	1.62
E.L. Smith Reservoir (PA/100mL)	29	0	0.0				0	0.0				29	0.55	0.10	1.63
<b>Treated Water Entering the Distribution System</b>	<b>58</b>	<b>0</b>	<b>0.0</b>				<b>0</b>	<b>0.0</b>				<b>58</b>	<b>0.68</b>	<b>0.10</b>	<b>1.63</b>
<b>December</b>															
Rossdale Raw (MPN/100mL)	31			176	75	548			6	1	18	2	24.2	21.0	27.3
E.L. Smith Raw (MPN/100mL)	5			201	108	261			6	1	17	1	36.4	36.4	36.4
<b>Raw River Water Entering the Treatment Plants</b>	<b>36</b>			<b>180</b>	<b>75</b>	<b>548</b>			<b>6</b>	<b>1</b>	<b>18</b>	<b>3</b>	<b>28.2</b>	<b>21.0</b>	<b>36.4</b>
Rossdale Treated (PA/100mL)	31	0	0.0				0	0.0				31	0.81	0.10	1.00
E.L. Smith Treated (PA/100mL)	31	0	0.0				0	0.0				31	0.64	0.10	1.00
<b>Water Entering the Plant Reservoir</b>	<b>62</b>	<b>0</b>	<b>0.0</b>				<b>0</b>	<b>0.0</b>				<b>62</b>	<b>0.72</b>	<b>0.10</b>	<b>1.00</b>
Rossdale Reservoir (PA/100mL)	31	0	0.0				0	0.0				31	0.67	0.10	1.00
E.L. Smith Reservoir (PA/100mL)	31	0	0.0				0	0.0				31	0.41	0.10	1.00
<b>Treated Water Entering the Distribution System</b>	<b>62</b>	<b>0</b>	<b>0.0</b>				<b>0</b>	<b>0.0</b>				<b>62</b>	<b>0.54</b>	<b>0.10</b>	<b>1.00</b>

PA = present or absent, MPN = most probable number, cATP = cellular adenosine triphosphate

**7.5 Bacteriological Data: Distribution System  
2022**

	Coliforms, total (PA/100 mL)			E. coli (PA/100 mL)		cATP (pg/mL)			
	Count	# +ve	% +ve	# +ve	% +ve	Count	Mean	Min	Max
<b>January</b>									
FIELD DISTRIBUTION	91	0	0.0	0	0.0	60	0.09	0.03	0.37
FIELD DISTRIBUTION - PLPH	60	0	0.0	0	0.0				
FIELD RESERVOIR	50	0	0.0	0	0.0	50	0.07	0.02	0.20
FIELD RESERVOIR - PLPH (duplicate-not counted)	48	0	0.0	0	0.0				
Monthly	201	0	0.0	0	0.0	110	0.09	0.02	0.37
<b>February</b>									
FIELD DISTRIBUTION	89	0	0.0	0	0.0	57	0.09	0.03	0.28
FIELD DISTRIBUTION - PLPH	60	0	0.0	0	0.0	3	0.13	0.13	0.13
FIELD RESERVOIR	48	0	0.0	0	0.0	48	0.11	0.03	0.30
FIELD RESERVOIR - PLPH (duplicate-not counted)	48	0	0.0	0	0.0				
Monthly	197	0	0.0	0	0.0	108	0.10	0.03	0.30
<b>March</b>									
FIELD DISTRIBUTION	85	0	0.0	0	0.0	61	0.09	0.03	0.37
FIELD DISTRIBUTION - PLPH	60	0	0.0	0	0.0				
FIELD RESERVOIR	60	0	0.0	0	0.0	60	0.09	0.03	0.58
FIELD RESERVOIR - PLPH (duplicate-not counted)	59	0	0.0	0	0.0				
Monthly	205	0	0.0	0	0.0	121	0.09	0.03	0.58
<b>April</b>									
FIELD DISTRIBUTION	94	0	0.0	0	0.0	61	0.18	0.03	1.26
FIELD DISTRIBUTION - PLPH	60	0	0.0	0	0.0				
FIELD RESERVOIR	55	0	0.0	0	0.0	55	0.09	0.03	0.37
FIELD RESERVOIR - PLPH (duplicate-not counted)	52	0	0.0	0	0.0				
Monthly	209	0	0.0	0	0.0	116	0.14	0.03	1.26

**7.5 Bacteriological Data: Distribution System  
2022**

	Coliforms, total (PA/100 mL)			E. coli (PA/100 mL)		cATP (pg/mL)			
	Count	# +ve	% +ve	# +ve	% +ve	Count	Mean	Min	Max
<b>May</b>									
FIELD DISTRIBUTION	98	0	0.0	0	0.0	58	0.09	0.03	0.24
FIELD DISTRIBUTION - PLPH	58	0	0.0	0	0.0				
FIELD RESERVOIR	64	0	0.0	0	0.0	64	0.11	0.02	0.73
FIELD RESERVOIR - PLPH (duplicate-not counted)	61	0	0.0	0	0.0				
Monthly	220	0	0.0	0	0.0	122	0.10	0.02	0.73
<b>June</b>									
FIELD DISTRIBUTION	88	0	0.0	0	0.0	56	0.12	0.03	0.87
FIELD DISTRIBUTION - PLPH	60	0	0.0	0	0.0				
FIELD RESERVOIR	48	0	0.0	0	0.0	48	0.21	0.04	1.04
FIELD RESERVOIR - PLPH (duplicate-not counted)	59	0	0.0	0	0.0				
Monthly	196	0	0.0	0	0.0	104	0.16	0.03	1.04
<b>July</b>									
FIELD DISTRIBUTION	87	0	0.0	0	0.0	56	0.39	0.03	1.66
FIELD DISTRIBUTION - PLPH	56	0	0.0	0	0.0				
FIELD RESERVOIR	52	0	0.0	0	0.0	52	1.21	0.03	4.49
FIELD RESERVOIR - PLPH (duplicate-not counted)	63	0	0.0	0	0.0				
Monthly	195	0	0.0	0	0.0	108	0.85	0.03	4.49
<b>August</b>									
FIELD DISTRIBUTION	96	1	1.0	0	0.0	58	0.29	0.03	1.08
FIELD DISTRIBUTION - PLPH	57	1	1.8	0	0.0				
FIELD RESERVOIR	66	0	0.0	0	0.0	66	0.64	0.03	5.14
FIELD RESERVOIR - PLPH (duplicate-not counted)	65	1	1.5	0	0.0				
Monthly	219	3	1.4	0	0.0	124	0.47	0.03	5.14

**7.5 Bacteriological Data: Distribution System  
2022**

	Coliforms, total (PA/100 mL)			E. coli (PA/100 mL)		cATP (pg/mL)			
	Count	# +ve	% +ve	# +ve	% +ve	Count	Mean	Min	Max
<b>September</b>									
FIELD DISTRIBUTION	145	0	0.0	0	0.0	56	0.66	0.14	3.92
FIELD DISTRIBUTION - PLPH	56	0	0.0	0	0.0				
FIELD RESERVOIR	53	0	0.0	0	0.0	53	0.50	0.11	1.64
FIELD RESERVOIR - PLPH (duplicate-not counted)	51	0	0.0	0	0.0				
Monthly	254	0	0.0	0	0.0	109	0.58	0.11	3.92
<b>October</b>									
FIELD DISTRIBUTION	154	0	0.0	0	0.0	56	0.22	0.11	0.63
FIELD DISTRIBUTION - PLPH	56	0	0.0	0	0.0				
FIELD RESERVOIR	56	0	0.0	0	0.0	56	0.22	0.10	0.58
FIELD RESERVOIR - PLPH (duplicate-not counted)	55	0	0.0	0	0.0				
Monthly	266	0	0.0	0	0.0	112	0.22	0.10	0.63
<b>November</b>									
FIELD DISTRIBUTION	139	0	0.0	0	0.0	56	0.42	0.10	1.49
FIELD DISTRIBUTION - PLPH	56	0	0.0	0	0.0				
FIELD RESERVOIR	58	0	0.0	0	0.0	58	0.44	0.10	2.42
FIELD RESERVOIR - PLPH (duplicate-not counted)	57	0	0.0	0	0.0				
Monthly	253	0	0.0	0	0.0	114	0.43	0.10	2.42
<b>December</b>									
FIELD DISTRIBUTION	137	0	0.0	0	0.0	56	0.49	0.11	3.26
FIELD DISTRIBUTION - PLPH	56	0	0.0	0	0.0				
FIELD RESERVOIR	50	0	0.0	0	0.0	50	0.16	0.10	0.42
FIELD RESERVOIR - PLPH (duplicate-not counted)	50	0	0.0	0	0.0				
Monthly	243	0	0.0	0	0.0	106	0.34	0.10	3.26
Year to Date	2,658	3	0.1	0	0.0	1,354	0.34	0.02	5.14

## 7.5 Bacteriological Data: Distribution System 2022

### BACTERIOLOGICAL SAMPLING AND TESTING REQUIREMENTS:

Testing for bacteria (Total Coliform and *E.coli*) in the distribution system is an AEP Approval requirement. The approval states that grab samples in the quantity specified in the Guidelines for Canadian Drinking Water Quality be collected at regular intervals throughout the month. For a city the size of Edmonton (population 972,000 in 2019) the guidelines recommend a minimum of 190 bacteriological samples. At least 95 of the 190 samples must be tested at the Provincial Laboratory for Public Health (PLPH) each month according to the Operations Program. The remainder are tested at the EPCOR Water Laboratory (Accredited to ISO/IEC 17025: standard for water quality parameters). Samples collected weekly from the twelve field reservoirs and tested in the EPCOR Water Laboratory are included in the count. Duplicate samples from the twelve field reservoirs are collected on the same day and tested at the Provincial Laboratory for Public Health are not included in the count.

### TABLE DEFINITIONS:

- PLPH - indicates that these tests were conducted by Provincial Laboratory for Public Health (ProvLAB). All other samples were tested at the EPCOR Water Laboratory (accredited to ISO/IEC17025)
- FIELD DISTRIBUTION - includes samples collected from recreation centres, other public facilities, convenience stores, dead end locations and EPCOR employee homes and tested at the EPCOR Water Laboratory.
- FIELD DISTRIBUTION - PLPH - includes samples collected from 30 Edmonton Fire Stations twice monthly and tested at PLPH
- FIELD RESERVOIR - includes weekly samples collected from the thirteen field reservoirs in the distribution system and tested at the EPCOR Water Laboratory
- FIELD RESERVOIR - includes duplicate weekly samples collected from the twelve field reservoirs in the distribution system and tested at PLPH

**7.5 Bacteriological Data: Distribution System  
2022**

	Coliforms, total (PA/100 mL)			E. coli (PA/100 mL)		cATP (pg/mL)			
	Count	# +ve	% +ve	# +ve	% +ve	Count	Mean	Min	Max
<b>Samples from Complaints</b>									
January	4	0	0.0	0	0.0	4	0.21	0.03	0.68
February	10	0	0.0	0	0.0	10	0.19	0.03	0.50
March	12	0	0.0	0	0.0	12	0.17	0.07	0.30
April	7	0	0.0	0	0.0	7	0.12	0.04	0.21
May	11	0	0.0	0	0.0	11	0.12	0.04	0.33
June	9	0	0.0	0	0.0	9	0.14	0.04	0.29
July	12	0	0.0	0	0.0	12	0.28	0.04	0.84
August	5	0	0.0	0	0.0	5	0.30	0.18	0.53
September	8	0	0.0	0	0.0	8	0.41	0.13	0.74
October	9	0	0.0	0	0.0	9	0.20	0.10	0.33
November	5	0	0.0	0	0.0	5	0.13	0.12	0.14
December	5	0	0.0	0	0.0	5			
Year to Date	97	0	0.0	0	0.0	97	0.21	0.03	0.84
<b>Samples from Depressurizations</b>									
January	67	0	0.0	0	0.0				
February	49	0	0.0	0	0.0				
March	58	0	0.0	0	0.0				
April	53	0	0.0	0	0.0				
May	83	0	0.0	0	0.0				
June	69	0	0.0	0	0.0				
July	78	1	1.3	0	0.0				
August	88	0	0.0	0	0.0				
September	86	0	0.0	0	0.0				
October	68	0	0.0	0	0.0				
November	58	0	0.0	0	0.0				
December	55	0	0.0	0	0.0				
Year to Date	812	1	0.1	0	0.0				

## 7.6 Giardia and Cryptosporidium

2022

### Treated Water entering the distribution system

	Cryptosporidium		Giardia	
	oocysts/100L		cysts/100L	
	E.L. Smith	Rossdale	E.L. Smith	Rossdale
10 - Jan	<0.1		<0.1	
11 - Jan		<0.1		<0.1
8 - Feb		<0.1		<0.1
14 - Feb	<0.1		<0.1	
7 - Mar	<0.1		<0.1	
8 - Mar		<0.1		<0.1
4 - Apr	<0.1		<0.1	
7 - Apr		<0.1		<0.1
9 - May		<0.1		<0.1
10 - May	<0.1		<0.1	
13 - Jun		<0.1		<0.1
14 - Jun	<0.1		<0.1	
4 - Jul		<0.1		<0.1
5 - Jul	9.6		9.6	
22 - Aug		<0.1		<0.1
24 - Aug	<0.1		<0.1	
6 - Sep	<0.1		<0.1	
7 - Sep		<0.1		<0.1
12 - Sep		<0.1		<0.1
13 - Sep	<0.1		<0.1	
3 - Oct	<0.1		<0.1	
4 - Oct		<0.1		<0.1
17 - Oct	<0.1		<0.1	
1 - Nov	<0.1		<0.1	
2 - Nov		<0.1		<0.1
17 - Nov		0.1		<0.1
	<0.1		<0.1	
21 - Nov		<0.1		<0.1
27 - Nov		<0.1		<0.1
	<0.1		<0.1	
19 - Dec	<0.1		<0.1	
20 - Dec		<0.1		<0.1

### Water entering plant reservoir

	Cryptosporidium	Giardia
	oocysts/100L	cysts/100L
	Rossdale	Rossdale
8 - Feb	<0.1	<0.1
9 - May	<0.1	<0.1
22 - Aug	<0.1	<0.1

## 7.6 Giardia and Cryptosporidium

2022

### Raw Water

	Cryptosporidium		Giardia	
	oocysts/100L		cysts/100L	
	E.L. Smith	Rossdale	E.L. Smith	Rossdale
10 - Jan	<1.0		1.0	
11 - Jan		<1.0		3.0
8 - Feb		<4.5		<4.5
14 - Feb	<1.6		1.6	
7 - Mar	<1.2		2.4	
8 - Mar		<3.3		6.6
4 - Apr	<9.4		9.4	
7 - Apr		<15.0		110.0
9 - May	16.0		27.0	
10 - May		<6.7		27.0
13 - Jun		<2.2		<2.2
14 - Jun	<14.0		<14.0	
4 - Jul		<0.1		<0.1
5 - Jul	<37.0		37.0	
22 - Aug		<1.0		1.0
24 - Aug	<9.8		39.0	
6 - Sep	<2.3		<2.3	
7 - Sep		1.0		1.0
12 - Sep		0.9		23.0
13 - Sep	3.0		12.0	
26 - Sep		2.9		64.0
3 - Oct	<2.0		39.0	
4 - Oct		4.0		77.0
17 - Oct	<2.0		120.0	
1 - Nov	<1.6		88.0	
2 - Nov		<1.2		75.0
17 - Nov		<2.2		11.0
	<4.2		38.0	
21 - Nov		1.5		19.0
27 - Nov		<1.6		11.0
	<4.3		26.0	
19 - Dec	<5.8		23.0	
20 - Dec		<1.3		6.7



**7.7 ROSSDALE AND E.L. SMITH TREATED WATER ENTERING PLANT RESERVOIR**

**2022**

	ROSSDALE				E.L. SMITH				Limits	
	Mean	Min	Max	Count	Mean	Min	Max	Count	*Approval or GCDWQ MAC, (AO or OG)	EPCOR
<b>Microbiologicals</b>										
Microcystin	<0.1	<0.1	<0.1	12	<0.11	<0.10	0.16	12	1.5	
<b>Physical</b>										
Colour (TCU)	0.8	<0.5	2.1	364	0.8	<0.5	1.7	366	(15)	10
Conductivity (uS/cm)	378	320	454	52	385	326	527	53	(<1)	<1
FPA-Intensity (N/A)	0.86	0.44	3.00	67	0.73	0.31	1.69	66		
pH (N/A)	7.9	7.5	8.2	364	7.8	7.4	8.1	366	(7.0 - 10.5)	7.3-8.3
Total Dissolved Solids (mg/L)	221	186	255	12	224	186	279	13	(500)	
Turbidity (NTU)	0.05	<0.04	0.10	364	0.05	<0.04	0.16	366		0.3
<b>Primary Inorganics (mg/L)</b>										
Antimony	<0.0002	<0.0002	0.0002	12	<0.0003	<0.0002	0.0009	13	0.006	
Arsenic	<0.0002	<0.0002	0.0003	12	<0.0002	<0.0002	0.0003	13	0.01	
Barium	0.061	0.052	0.075	12	0.060	0.051	0.074	13	2	
Boron	0.010	0.007	0.014	12	0.009	0.007	0.013	13	2	
Bromate Dissolved	<0.005	<0.003	<0.005	53	<0.005	<0.003	<0.005	54	0.01	
Cadmium	<0.0002	<0.0002	<0.0002	12	<0.0002	<0.0002	<0.0002	13	0.007	
Chlorate Dissolved	0.16	0.10	0.26	53	0.11	<0.05	0.20	54	1	
Chlorite Dissolved	<0.009	<0.005	<0.200	53	<0.009	<0.005	<0.200	54	1	
Chromium	<0.0002	<0.0002	<0.0002	12	<0.0002	<0.0002	<0.0002	13	0.05	
Copper	<0.005	<0.005	<0.005	12	<0.005	<0.005	<0.005	13	2 (1)	
Cyanide Dissolved	<0.002	<0.002	<0.002	12	<0.002	<0.002	<0.002	13	0.2	
Fluoride	0.69	0.61	0.77	364	0.68	0.59	0.76	366	1.5	0.6-0.8
Lead	<0.0002	<0.0002	<0.0002	12	<0.0002	<0.0002	<0.0002	13	0.005	
Manganese	<0.002	<0.002	<0.002	12	<0.003	<0.002	0.007	13	0.12 (0.02)	
Mercury	<0.0002	<0.00001	<0.0002	16	<0.0002	<0.00001	<0.0002	17	0.001	
Nitrate (as N) Dissolved	0.05	<0.01	0.25	53	0.05	<0.01	0.26	54	10	
Nitrite (as N) Dissolved	<0.010	<0.005	0.010	53	<0.010	<0.005	<0.010	54	1	
Selenium	<0.0002	<0.0002	0.0003	12	0.0002	<0.0002	0.0003	13	0.05	
Total Chlorine	2.10	1.91	2.32	364	2.04	1.18	2.30	366	>1.0	>1.0 and <2.4
Uranium	<0.0005	<0.0005	0.0006	12	<0.0005	<0.0005	0.0006	13	0.02	

7.7 ROSSDALE AND E.L. SMITH TREATED WATER ENTERING PLANT RESERVOIR

2022

	ROSSDALE				E.L. SMITH				Limits	
	Mean	Min	Max	Count	Mean	Min	Max	Count	*Approval or GCDWQ MAC, (AO or OG)	EPCOR
<b>Primary Organics (ug/L)</b>										
2,4-D	<2.54	<0.05	<10.00	4	<2.65	<0.05	<10.00	4	100	
Atrazine	<0.1	<0.1	<0.1	4	<0.1	<0.1	<0.1	4	5	
Benzene	<0.5	<0.5	<1.0	374	<0.5	<0.5	<1.0	376	5	
Benzo(a)pyrene	<0.005	<0.005	<0.005	4	<0.005	<0.005	<0.005	4	0.04	
Bromoxynil	<0.16	<0.05	<0.50	4	<0.28	<0.05	<0.50	4	5	
Carbon Tetrachloride	<1.0	<0.5	<1.0	373	<1.0	<0.5	<1.0	375	2	
Chlorobenzene	<0.513	<0.001	<1.000	377	<0.513	<0.001	<1.000	379	80 (30)	
Chlorpyrifos	<0.1	<0.1	<0.1	4	<0.1	<0.1	<0.1	4	90	
Cyanazine	<0.1	<0.1	<0.1	4	<0.1	<0.1	<0.1	4		
Diazinon	<0.1	<0.1	<0.1	4	<0.1	<0.1	<0.1	4		
Dicamba	<3.1	<0.1	<12.0	4	<3.3	<0.1	<12.0	4	110	
Dichlorobenzene (1,2)	<0.5	<0.5	<0.5	362	<0.5	<0.5	<0.5	364		
Dichlorobenzene (1,4)	<0.5	<0.5	<0.5	362	<0.5	<0.5	<0.5	364	5 (1)	
Dichloroethylene (1,1)	<3	<3	<3	362	<3	<3	<3	364	14	
Dichlorophenol (2,4)	<0.3	<0.3	<0.3	4	<0.3	<0.3	<0.3	4		
Diclofop-methyl	<0.1	<0.1	<0.1	4	<0.1	<0.1	<0.1	4		
Dimethoate	<0.1	<0.1	<0.1	4	<0.1	<0.1	<0.1	4	20	
Diuron	<1	<1	<1	4	<1	<1	<1	4		
Ethylbenzene	<0.5	<0.5	<1.0	374	<0.5	<0.5	<1.0	376	140 (1.6)	
Glyphosate	<0.15	<0.01	<0.20	4	<0.15	<0.01	<0.20	4	280	
Haloacetic Acids, (HAA5)	21.5	11.5	37.6	13	19.5	11.2	37.8	12	80	40
Haloacetic Acids, total (HAA6)	21.7	<12.0	37.6	13	19.8	<12.0	37.9	12		
Malathion	<0.1	<0.1	<0.1	4	<0.1	<0.1	<0.1	4	190	
MCPA	<0.16	<0.05	<0.50	4	<0.28	<0.05	<0.50	4	100	
Methylene Chloride	<0.6	<0.5	<5.0	373	<0.6	<0.5	<5.0	375	50	
Metolachlor	<0.1	<0.1	<0.1	4	<0.1	<0.1	<0.1	4		
Metribuzin	<0.3	<0.1	<1.0	4	<0.3	<0.1	<1.0	4	80	
NDMA	<0.0010	<0.0009	<0.0018	13	<0.0010	<0.0009	<0.0018	13	0.040	10
NTA (mg/L)	<0.2	<0.2	<0.2	4	<0.2	<0.2	<0.2	4	0.4	
Pentachlorophenol	<1.9	<0.5	<6.0	4	<1.9	<0.5	<6.0	4	60 (30)	
Perfluorooctane sulfonic acid (PFOS)	<0.01	<0.01	<0.01	4	<0.01	<0.01	<0.01	4	0.6	
Perfluorooctanoic acid (PFOA)	<0.01	<0.01	<0.01	4	<0.01	<0.01	<0.01	4	0.0002	
Phorate	<0.1	<0.1	<0.1	4	<0.1	<0.1	<0.1	4		
Picloram	<4.8	<0.1	<19.0	4	<5.1	<0.1	<19.0	4		
Simazine	<0.1	<0.1	<0.1	4	<0.1	<0.1	<0.1	4		
Terbufos	<0.1	<0.1	<0.1	4	<0.1	<0.1	<0.1	4		
Tetrachloroethylene	<0.5	<0.5	<0.5	363	<0.5	<0.5	<0.5	365	10	
Toluene	<0.5	<0.5	<1.0	374	<0.5	<0.5	<1.0	376	60 (24)	
Total Xylenes	<2.5	<2.5	<2.5	362	<2.5	<2.5	<2.5	364	90	
Trichloroethylene	<0.5	<0.5	<0.5	363	<0.5	<0.5	<0.5	365	5	
Trifluralin	<0.1	<0.1	<0.1	4	<0.1	<0.1	<0.1	4		
Trihalomethanes	15.5	4.2	42.1	362	13.7	3.1	40.1	364	100	50
Vinyl chloride	<0.833	<0.001	<1.000	15	<0.833	<0.001	<1.000	15	2	
<b>Radionuclides (Bq/L)</b>										
Cesium-137	<0.09	<0.08	<0.10	2	<0.14	<0.07	0.20	2	10	
Gross Alpha	<0.14	<0.12	<0.15	2	<0.14	<0.11	<0.16	2	(0.5)	
Gross Beta	<0.08	<0.06	0.10	2	0.12	0.07	0.17	2	(1.0)	
Iodine-131	<0.2	<0.2	<0.2	2	<0.4	<0.2	<0.5	2	6	
Lead-210	<0.02	<0.02	<0.02	2	<0.02	<0.02	<0.02	2	0.2	
Radium-226	<0.005	<0.005	<0.005	2	<0.006	<0.005	0.006	2	0.5	
Strontium-90	<0.05	<0.05	<0.05	2	<0.05	<0.05	<0.05	2	5	
Tritium	<40	<40	<40	2	<40	<40	<40	2	7000	

**7.7 ROSSDALE AND E.L. SMITH TREATED WATER ENTERING PLANT RESERVOIR**

**2022**

	ROSSDALE				E.L. SMITH				Limits	
	Mean	Min	Max	Count	Mean	Min	Max	Count	*Approval or GCDWQ MAC, (AO or OG)	EPCOR
<b>Secondary Inorganics (mg/L)</b>										
Alkalinity Total (mg CaCO3/L)	120	90	143	364	121	97	140	366		
Aluminum	0.088	0.018	0.172	12	0.079	0.020	0.176	13	2.9	0.1/0.2
Ammonia as NH3	0.11	0.07	0.18	67	0.10	<0.05	0.18	68		
Beryllium	<0.0002	<0.0002	<0.0002	12	<0.0002	<0.0002	<0.0002	13		
Bromide Dissolved	<0.01	<0.01	<0.05	53	<0.01	<0.01	<0.05	54		
Calcium	46.8	40.2	53.8	12	47.3	40.8	55.0	13		
Chloride Dissolved	6.09	4.51	12.20	53	6.00	4.34	10.00	54	(250)	
Cobalt	<0.0002	<0.0002	<0.0002	12	<0.0002	<0.0002	0.0004	13		
Free Chlorine	<0.03	<0.03	<0.03	12	<0.03	<0.03	<0.03	13		
Hardness, Ca (mg CaCO3/L)	113	93	198	364	111	94	186	366		
Iron	<0.005	<0.005	<0.005	12	<0.005	<0.005	<0.005	13	(0.3)	0.3
Lanthanum	<0.001	<0.001	<0.001	12	<0.001	<0.001	<0.001	13		
Lithium	0.0033	0.0026	0.0045	12	0.0031	0.0024	0.0041	13		
Magnesium	13.9	11.6	16.2	12	14.0	11.7	16.1	13		
Molybdenum	0.0007	0.0005	0.0009	12	0.0007	0.0005	0.0008	13		
Nickel	<0.0005	<0.0005	0.0009	12	<0.0006	<0.0005	0.0008	13		
Phosphate,Ortho (as P)	<0.02	<0.02	<0.02	12	<0.02	<0.02	<0.02	12		
Phosphorus	<0.02	<0.02	<0.02	12	<0.02	<0.02	<0.02	13		
Potassium	1.0	0.6	2.2	12	0.9	0.4	2.0	13		
Silicon	1.97	1.46	3.16	12	1.95	1.44	3.04	13		
Silver	<0.0002	<0.0002	0.0006	12	<0.0002	<0.0002	<0.0002	13		
Sodium	10.3	6.1	23.2	12	12.6	6.4	36.2	13	(200)	
Strontium	0.415	0.296	0.485	12	0.417	0.298	0.480	13	7.0	
Sulphate Dissolved	65.5	51.5	118.0	53	69.0	52.3	142.0	54	(500)	
Sulphide	<0.002	<0.002	0.002	12	<0.002	<0.002	0.004	13	(0.05)	
Thallium	<0.0005	<0.0005	<0.0005	12	<0.0005	<0.0005	<0.0005	13		
Tin	<0.0005	<0.0005	<0.0005	12	<0.0005	<0.0005	<0.0005	13		
Titanium	<0.0005	<0.0005	<0.0005	12	<0.0005	<0.0005	<0.0005	13		
Total Hardness (mg/L CaCO3)	171	142	246	364	170	145	241	366		
Vanadium	<0.0005	<0.0005	<0.0005	12	<0.0005	<0.0005	<0.0005	13		
Zinc	<0.005	<0.005	<0.005	12	<0.005	<0.005	<0.005	13	(5.0)	
Zirconium	<0.001	<0.001	<0.001	12	<0.001	<0.001	<0.001	13		

7.7 ROSSDALE AND E.L. SMITH TREATED WATER ENTERING PLANT RESERVOIR

2022

	ROSSDALE				E.L. SMITH				Limits	
	Mean	Min	Max	Count	Mean	Min	Max	Count	*Approval or GCDWQ MAC, (AO or OG)	EPCOR
<b>Secondary Organics (ug/L)</b>										
Aldicarb	<1.0	<0.9	<1.0	4	<1.0	<0.9	<1.0	4		
Aldrin	<0.008	<0.008	<0.008	4	<0.008	<0.008	<0.008	4		
Azinphos-methyl	<0.1	<0.1	<0.1	4	<0.1	<0.1	<0.1	4		
Bromobenzene	<1	<1	<1	11	<1	<1	<1	11		
Bromochloroacetic acid	<1	<1	<2	13	<1	<1	<2	12		
Bromodichloromethane	<0.5	<0.5	2.0	374	<0.5	<0.5	1.0	376		16
Bromoform	<1.0	<0.5	<1.0	374	<1.0	<0.5	<1.0	376		
Bromomethane	<9.2	<0.5	<10.0	12	<9.2	<0.5	<10.0	12		
Carbaryl	<0.3	<0.2	<0.5	4	<0.3	<0.2	<0.5	4		
Carbofuran	<0.3	<0.2	<0.5	4	<0.3	<0.2	<0.5	4		
Chloroethane	<9.2	<0.5	<10.0	12	<9.2	<0.5	<10.0	12		
Chloroform	16.4	<0.01	69.2	377	14.5	<0.01	53.8	379		
Chloromethane	<10	<5	<10	12	<10	<5	<10	12		
Dibromoacetic acid	<1	<1	<2	13	<1	<1	<2	12		
Dibromochloromethane	<0.51	<0.01	<1.00	377	<0.51	<0.01	<1.00	379		
Dibromomethane	<1	<1	<1	11	<1	<1	<1	11		
Dichloroacetic acid	8.8	4.8	14.7	13	8.3	4.4	15.7	12		
Dichlorobenzene (1,3)	<0.5	<0.5	<0.5	362	<0.5	<0.5	<0.5	364		
Dichloroethylene, cis (1,2)	<0.5	<0.5	<0.5	362	<0.5	<0.5	<0.5	364		
Dichloroethylene, trans (1,2)	<0.5	<0.5	<0.5	362	<0.5	<0.5	<0.5	364		
Dichloropropane (1,2)	<0.5	<0.5	<0.5	362	<0.5	<0.5	<0.5	364		
Dieldrin	<0.008	<0.008	<0.008	4	<0.008	<0.008	<0.008	4		
Hexachlorobutadiene	<1	<1	<1	11	<1	<1	<1	11		
Hexachloroethane	<1	<1	<1	11	<1	<1	<1	11		
Methyl t-Butyl Ether (MTBE)	<0.5	<0.5	<0.5	362	<0.5	<0.5	<0.5	364	(15)	
MIBK	<1	<1	<1	362	<1	<1	<1	364		
Monobromoacetic acid	<1	<1	<2	13	<1	<1	<2	12		
Monochloroacetic acid	<4.8	<2.0	5.6	13	<4.9	<2.0	6.2	12		
n-Butylbenzene	<1	<1	<1	11	<1	<1	<1	11		
n-Propylbenzene	<1	<1	<1	11	<1	<1	<1	11		
Parathion	<0.1	<0.1	<0.1	4	<0.1	<0.1	<0.1	4		
Perfluorobutanoic acid (PFBA)	<0.6	<0.1	<0.8	4	<0.6	<0.1	<0.8	4		
Perfluoroheptanoic acid (PFHpA)	<0.02	<0.01	<0.02	4	<0.02	<0.01	<0.02	4		
Perfluorohexane sulfonic acid (PFHxS)	<0.02	<0.01	<0.02	4	<0.02	<0.01	<0.02	4		
Perfluorohexanoic acid (PFHxA)	<0.02	<0.01	<0.02	4	<0.02	<0.01	<0.02	4		
Perfluorononanoic acid (PFNA)	<0.02	<0.01	<0.02	4	<0.02	<0.01	<0.02	4		
Perfluoropentanoic acid (PFPeA)	<0.02	<0.01	<0.02	4	<0.02	<0.01	<0.02	4		
p-Isopropyltoluene	<5	<5	<5	11	<5	<5	<5	11		
sec-Butylbenzene	<1	<1	<1	11	<1	<1	<1	11		
Styrene	<0.5	<0.5	<1.0	374	<0.5	<0.5	<1.0	376		
tert-Butylbenzene	<1	<1	<1	11	<1	<1	<1	11		
Tetrachloroethane (1,1,2,2)	<1	<1	<1	362	<1	<1	<1	364		
Total Organic Carbon	1.7	0.9	9.9	52	1.5	<0.6	3.3	53		
Total Volatile Organics (NonTHM)	<1	<1	<1	362	<1	<1	<1	364		
Total Volatile Organics (Unknown)	<1.0	<1.0	4.8	362	<1.0	<1.0	5.4	364		
Triallate	<0.1	<0.1	<0.1	4	<0.1	<0.1	<0.1	4		
Trichloroacetic acid	10.1	5.8	17.3	13	8.7	5.2	15.8	12		
Trichlorobenzene (1,2,4)	<0.5	<0.5	<0.5	362	<0.5	<0.5	<0.5	364		
Trichloroethane (1,1,1)	<0.5	<0.5	<0.5	362	<0.5	<0.5	<0.5	364		
Trichlorofluoromethane	<1	<1	<1	11	<1	<1	<1	11		
Xylene (1,2)	<0.5	<0.5	<0.5	362	<0.5	<0.5	<0.5	364		
Xylene (1,4)	<0.5	<0.5	<0.5	362	<0.5	<0.5	<0.5	364		

TABLE EXPLANATIONS:

- \* Numbers with no brackets are Health Canada Guidelines for Canadian Drinking Water Quality (GCDWQ) Maximum Acceptable Concentrations (MAC) and/or a limit set out in the Alberta Environment and Parks (AEP) Operating Approval 638-04-00. Limits in brackets indicate Aesthetic Objectives or Operational Guidelines (OG) and are not Approval limits. The EPCOR limits are internal limits set by EPCOR in the Operations Program.
- \*\* Primary parameters are those that have health-based limits (MACs) according the AEP Operating Approval 638-04-00.
- \*\*\* Secondary parameters do not have health-based limits but may have aesthetic or operational objectives

## 7.8 Treated Water Entering the Distribution System: Physical, Inorganic, and Organic

2022

	ROSSDALE				E.L. SMITH				Limits	
									*Approval or GCDWQ MAC, (AO or OG)	EPCOR
	Mean	Min	Max	Count	Mean	Min	Max	Count		
<b>Physical</b>										
FPA-Intensity (N/A)	1.25	1.06	1.44	2				0		
Turbidity (NTU)	0.05	<0.04	0.10	364	0.05	<0.04	0.19	364		0.3
UV 254 %T ****	<94.7	<87.0	<97.4	364	<94.9	<89.8	<98.1	366		
<b>Primary Inorganics (mg/L)</b>										
Bromate Dissolved	<0.005	<0.003	<0.005	53	<0.005	<0.003	0.006	53	0.01	
Chlorate Dissolved	0.16	0.10	0.25	53	0.11	<0.05	0.21	53	1	
Chlorite Dissolved	<0.009	<0.005	<0.200	53	<0.009	<0.005	<0.200	53	1	
Nitrate (as N) Dissolved	0.05	<0.01	0.29	53	0.05	<0.01	0.29	53	10	
Nitrite (as N) Dissolved	<0.010	<0.005	0.010	53	<0.010	<0.005	<0.010	53	1	
<b>Primary Organics (ug/L)</b>										
Benzene	<0.5	<0.5	<1.0	373	<0.5	<0.5	<1.0	373	5	
Carbon Tetrachloride	<1.0	<0.5	<1.0	373	<1.0	<0.5	<1.0	373	2	
Chlorobenzene	<0.5	<0.5	<1.0	373	<0.5	<0.5	<1.0	373	80 (30)	
Dichlorobenzene (1,2)	<0.5	<0.5	<0.5	362	<0.5	<0.5	<0.5	362		
Dichlorobenzene (1,4)	<0.5	<0.5	<0.5	362	<0.5	<0.5	<0.5	362	5 (1)	
Dichloroethylene (1,1)	<3	<3	<3	362	<3	<3	<3	362	14	
Ethylbenzene	<0.5	<0.5	<1.0	373	<0.5	<0.5	<1.0	373	140 (1.6)	
Methylene Chloride	<0.6	<0.5	<5.0	373	<0.6	<0.5	<5.0	373	50	
Tetrachloroethylene	<0.5	<0.5	<0.5	362	<0.5	<0.5	<0.5	362	10	
Toluene	<0.5	<0.5	<1.0	373	<0.5	<0.5	<1.0	373	60 (24)	
Total Xylenes	<2.5	<2.5	<2.5	362	<2.5	<2.5	<2.5	362	90	
Trichloroethylene	<0.5	<0.5	<0.5	362	<0.5	<0.5	<0.5	362	5	
Trihalomethanes	12.7	3.4	34.7	362	10.6	2.6	29.6	362	100	50
Vinyl Chloride	<1	<1	<1	11	<1	<1	<1	11	2	
<b>Secondary Inorganics (mg/L)</b>										
Ammonia as NH3	0.11	0.06	0.20	67	0.10	<0.05	0.18	67		
Bromide Dissolved	<0.01	<0.01	<0.05	53	<0.01	<0.01	<0.05	53		
Chloride Dissolved	6.21	4.56	13.30	53	5.96	4.31	10.30	53	(250)	
Sulphate Dissolved	65.3	51.1	115.0	53	68.7	52.3	129.0	53	(500)	

## 7.8 Treated Water Entering the Distribution System: Physical, Inorganic, and Organic

2022

	ROSSDALE				E.L. SMITH				Limits	
									*Approval or GCDWQ MAC, (AO or OG)	EPCOR
	Mean	Min	Max	Count	Mean	Min	Max	Count		
Secondary Organics (ug/L)										
Bromobenzene	<1	<1	<1	11	<1	<1	<1	11		
Bromodichloromethane	<0.5	<0.5	2.0	373	<0.5	<0.5	1.0	373		16
Bromoform	<1	<1	<1	373	<1	<1	<1	373		
Bromomethane	<10	<10	<10	11	<10	<10	<10	11		
Chloroethane	<10	<10	<10	11	<10	<10	<10	11		
Chloroform	13.5	3.40	52.0	373	11.3	2.60	39.7	373		
Chloromethane	<10	<10	<10	11	<10	<10	<10	11		
Dibromochloromethane	<0.5	<0.5	<1.0	373	<0.5	<0.5	<1.0	373		
Dibromomethane	<1	<1	<1	11	<1	<1	<1	11		
Dichlorobenzene (1,3)	<0.5	<0.5	<0.5	362	<0.5	<0.5	<0.5	362		
Dichloroethylene, cis (1,2)	<0.5	<0.5	<0.5	362	<0.5	<0.5	<0.5	362		
Dichloroethylene, trans (1,2)	<0.5	<0.5	<0.5	362	<0.5	<0.5	<0.5	362		
Dichloropropane (1,2)	<0.5	<0.5	<0.5	362	<0.5	<0.5	<0.5	362		
Hexachlorobutadiene	<1	<1	<1	11	<1	<1	<1	11		
Hexachloroethane	<1	<1	<1	11	<1	<1	<1	11		
Methyl t-Butyl Ether (MTBE)	<0.5	<0.5	<0.5	362	<0.5	<0.5	<0.5	362	(15)	
MIBK	<1	<1	<1	362	<1	<1	<1	362		
n-Butylbenzene	<1	<1	<1	11	<1	<1	<1	11		
n-Propylbenzene	<1	<1	<1	11	<1	<1	<1	11		
p-Isopropyltoluene	<5	<5	<5	11	<5	<5	<5	11		
sec-Butylbenzene	<1	<1	<1	11	<1	<1	<1	11		
Styrene	<0.5	<0.5	<1.0	373	<0.5	<0.5	<1.0	373		
tert-Butylbenzene	<1	<1	<1	11	<1	<1	<1	11		
Tetrachloroethane (1,1,2,2)	<1	<1	<1	362	<1	<1	<1	362		
Total Volatile Organics (NonTHM)	<1	<1	<1	362	<1	<1	<1	362		
Total Volatile Organics (Unknown)	<1.0	<1.0	5.5	362	<1.0	<1.0	4.4	362		
Trichlorobenzene (1,2,4)	<0.5	<0.5	<0.5	362	<0.5	<0.5	<0.5	362		
Trichloroethane (1,1,1)	<0.5	<0.5	<0.5	362	<0.5	<0.5	<0.5	362		
Trichlorofluoromethane	<1	<1	<1	11	<1	<1	<1	11		
Xylene (1,2)	<0.5	<0.5	<0.5	362	<0.5	<0.5	<0.5	362		
Xylene (1,4)	<0.5	<0.5	<0.5	362	<0.5	<0.5	<0.5	362		

**TABLE EXPLANATIONS:**

- \* Numbers with no brackets are Health Canada Guidelines for Canadian Drinking Water Quality (GCDWQ) Maximum Acceptable Concentrations (MAC) and/or a limit set out in the Alberta Environment and Parks (AEP) Operating Approval 638-04-00. Limits in brackets indicate Aesthetic Objectives or Operational Guidelines (OG) and are not Approval Limits. The EPCOR limits are internal limits set by EPCOR in the Operations Program.
- \*\* Primary parameters are those that have health-based limits (MACs) according to the AEP Operating Approval 638-04-00
- \*\*\* Secondary parameters do not have health-based limits but may have aesthetic or operational objectives
- \*\*\*\* UV 254 %T for Rosssdale based on a sample collected daily from one of the nine filters selected randomly. For E.L. Smith it is based on a daily sample of Combined Filter Effluent

### 7.9.a Routine Distribution System (does not include Field Reservoirs)

2022

					Limits	
	Mean	Min	Max	Count	*Approval or GCDWQ MAC, (AO or OG)	EPCOR
<b>Microbiological</b>						
Microcystin	<0.1	<0.1	<0.1	6	1.5	
<b>Physical</b>						
Colour (TCU)	0.9	<0.5	1.7	4	(15)	10
pH (N/A)	7.9	7.7	8.1	29	(7.0 - 10.5)	7.3 - 8.3
Total Dissolved Solids (mg/L)	267	200	409	4	(500)	
Turbidity (NTU)	0.13	<0.04	3.06	1696		1.0
UV 254 %T	<93.1	<88.8	<94.5	4		
<b>Primary Inorganics (mg/L) **</b>						
Antimony	<0.0002	<0.0002	<0.0002	5	0.006	
Arsenic	<0.0002	<0.0002	<0.0002	5	0.01	
Barium	0.058	0.050	0.067	5	2	
Boron	0.011	0.007	0.022	5	2	
Bromate Dissolved	<0.005	<0.005	<0.005	27	0.01	
Cadmium	<0.0002	<0.0002	<0.0002	5	0.007	
Chlorate Dissolved	0.14	0.08	0.19	27	1	
Chlorite Dissolved	<0.005	<0.005	<0.005	27	1	
Chromium	<0.0002	<0.0002	<0.0002	5	0.05	
Copper	0.007	<0.005	0.012	5	2 (1)	
Cyanide Dissolved	<0.002	<0.002	<0.002	4	0.2	
Fluoride	0.67	0.64	0.71	4	1.5	0.6 - 0.8
Lead	<0.0002	<0.0002	<0.0002	5	0.005	
Manganese	<0.002	<0.002	<0.002	5	0.12 (0.02)	
Mercury	<0.00010	<0.00001	<0.00020	9	0.001	
Nitrate (as N) Dissolved	0.06	<0.01	0.19	27	10	
Nitrite (as N) Dissolved	<0.01	<0.01	<0.01	27	1	
Selenium	0.0003	<0.0002	0.0003	5	0.05	
Strontium	0.404	0.314	0.491	5	7.0	
Total Chlorine	1.77	0.96	2.20	1695	>0.5 and <3.0	>1.0 and <2.4
Uranium	0.0005	<0.0005	0.0006	5	0.02	



### 7.9.a Routine Distribution System (does not include Field Reservoirs)

2022

					Limits	
	Mean	Min	Max	Count	*Approval or GCDWQ MAC, (AO or OG)	EPCOR
<b>Primary Organics (ug/L) **</b>						
2,4-D	<2.54	<0.05	<10.00	4	100	
Atrazine	<0.1	<0.1	<0.1	4	5	
Atrazine+N-Dealkylated Metabolites	<0.2	<0.2	<0.2	4	0.005	
Azinphos-methyl	<0.1	<0.1	<0.1	4	0.02	
Benzene	<0.5	<0.5	<0.5	74	5	
Benzo(a)pyrene	<0.005	<0.005	<0.005	4	0.04	
Bromoxynil	<0.16	<0.05	<0.50	4	5	
Carbon Tetrachloride	<0.9675	<0.0005	<1.0000	77	2	
Chlorobenzene	<0.494	<0.001	<0.500	77	80 (30)	
Chlorpyrifos	<0.1	<0.1	<0.1	4	90	
Cyanazine	<0.1	<0.1	<0.1	4		
Diazinon	<0.1	<0.1	<0.1	4		
Dicamba	<3.1	<0.1	<12.0	4	110	
Dichlorobenzene (1,2)	<0.4935	<0.0005	<0.5000	77		
Dichlorobenzene (1,4)	<0.494	<0.001	<0.500	77	5 (1)	
Dichloroethane (1,2)	<0.375	<0.001	<0.500	4	5	
Dichloroethene (1,1)	<0.334	<0.001	<0.500	3	14	
Dichloroethylene (1,1)	<3	<3	<3	73	14	
Dichlorophenol (2,4)	<0.3	<0.3	<0.3	4		
Diclofop-methyl	<0.1	<0.1	<0.1	4		
Dimethoate	<0.1	<0.1	<0.1	4	20	
Diquat	<1	<1	<1	4	0.05	
Diuron	<1	<1	<1	4		
Ethylbenzene	<0.5	<0.5	<0.5	74	140 (1.6)	
Glyphosate	<0.15	<0.01	<0.20	4	280	
Malathion	<0.1	<0.1	<0.1	4	190	
MCPA	<0.16	<0.05	<0.50	4	100	
Methylene Chloride	<0.5	<0.5	<0.5	73	50	
Metolachlor	<0.1	<0.1	<0.1	4		
Metribuzin	<0.3	<0.1	<1.0	4	80	
Nitritriacetic acid	<0.2	<0.2	<0.2	4	0.4	
Paraquat	<1	<1	<1	4	0.07	
Pentachlorophenol	<1.9	<0.5	<6.0	4	60 (30)	
Perfluorooctane sulfonic acid (PFOS)	<0.01	<0.01	<0.01	4	0.0006	
Perfluorooctanoic acid (PFOA)	<0.01	<0.01	<0.01	4	0.0002	
Phorate	<0.1	<0.1	<0.1	4		
Picloram	<4.8	<0.1	<19.0	4		
Simazine	<0.1	<0.1	<0.1	4		
Terbufos	<0.1	<0.1	<0.1	4		

**7.9.a Routine Distribution System (does not include Field Reservoirs)**

2022

					Limits	
	Mean	Min	Max	Count	*Approval or GCDWQ MAC, (AO or OG)	EPCOR
<b>Primary Organics (ug/L) **</b>						
Tetrachloroethene	<0.334	<0.001	<0.500	3	0.01	
Tetrachloroethylene	<0.5	<0.5	<0.5	74	10	
Tetrachlorophenol (2,3,4,6)	<0.6	<0.5	<1.0	4	100 (1)	
Toluene	<0.5	<0.5	<0.5	74	60 (24)	
Total Xylenes	<2.5	<2.5	<2.5	73	90	
Trichloroethene	<0.334	<0.001	<0.500	3	0.005	
Trichloroethylene	<0.5	<0.5	<0.5	74	5	
Trichlorophenol (2,4,6)	<0.5	<0.5	<0.5	4	5 (2)	
Trifluralin	<0.1	<0.1	<0.1	4		

### 7.9.a Routine Distribution System (does not include Field Reservoirs)

2022

					Limits	
	Mean	Min	Max	Count	*Approval or GCDWQ MAC, (AO or OG)	EPCOR
<b>Secondary Inorganics (mg/L) ***</b>						
Alkalinity Total	112	96	123	4		
Alkalinity, PHP (mg CaCO <sub>3</sub> /L)	<3	<1	<3	4		
Aluminum	0.067	0.023	0.126	5	2.9	0.1/0.2
Ammonia as N	0.12	0.09	0.18	29		
Beryllium	<0.0002	<0.0002	<0.0002	5		
Bromide Dissolved	<0.01	<0.01	<0.01	27		
Calcium	46.0	40.3	51.4	5		
Chloride Dissolved	6.1	4.1	9.4	27	(250)	
Cobalt	<0.0002	<0.0002	<0.0002	5		
Free Chlorine	<0.03	<0.03	<0.03	4		
Iron	0.007	<0.005	0.017	5	(0.3)	0.3
Lanthanum	<0.001	<0.001	<0.001	5		
Lithium	0.0029	0.0026	0.0032	5		
Magnesium	13.6	11.9	16.1	5		
Molybdenum	0.0007	0.0006	0.0008	5		
Nickel	0.0005	<0.0005	0.0006	5		
Phosphorus	<0.02	<0.02	<0.02	5		
Potassium	1.1	0.6	2.5	5		
Silicon	2.16	1.63	2.88	5		
Silver	<0.0002	<0.0002	<0.0002	5		
Sodium	12.1	6.1	23.2	5	(200)	
Sulphate Dissolved	66.7	49.8	99.5	27	(500)	
Sulphide	<0.002	<0.002	<0.002	4	(0.05)	
Thallium	<0.0005	<0.0005	<0.0005	5		
Tin	<0.0005	<0.0005	<0.0005	5		
Titanium	<0.0005	<0.0005	<0.0005	5		
Total Hardness (mg/L CaCO <sub>3</sub> )	161	145	170	4		
Total Kjeldahl Nitrogen	0.5	0.3	0.6	4		
Vanadium	<0.0005	<0.0005	<0.0005	5		
Zinc	<0.005	<0.005	<0.005	5	(5.0)	
Zirconium	<0.001	<0.001	<0.001	5		

7.9.a Routine Distribution System (does not include Field Reservoirs)

2022

					Limits	
	Mean	Min	Max	Count	*Approval or GCDWQ MAC, (AO or OG)	EPCOR
<b>Secondary Organics (ug/L) ***</b>						
2,4,5-T	<7.04	<0.05	<28.00	4		
6:2 Fluorotelomer sulfonic acid(6:2 FTS)	<0.01	<0.01	<0.01	4		
8:2 Fluorotelomer sulfonic acid(8:2 FTS)	<0.01	<0.01	<0.01	4		
a-chlordane	<0.008	<0.008	<0.008	4		
Alachlor	<0.1	<0.1	<0.1	4		
Aldicarb	<1.0	<0.9	<1.0	4		
Aldrin	<0.008	<0.008	<0.008	4		
Ametryn	<0.1	<0.1	<0.1	3		
Atrazine Desethyl	<0.1	<0.1	<0.1	4		
Bendiocarb	<0.5	<0.5	<0.5	4		
Bromochloroacetic acid	<1	<1	<2	72		
Bromodichloromethane	0.51	<0.50	0.87	74		16
Bromoform	<1.0	<0.5	<1.0	74		
Carbaryl	<0.3	<0.2	<0.5	4		
Carbofuran	<0.3	<0.2	<0.5	4		
Chloroform	16.982	<0.016	40.800	77		
Dibromoacetic acid	<1	<1	<2	72		
Dibromochloromethane	<0.49	<0.01	<0.50	77		
Dibromoethane (1,2)	<0.5	<0.5	<0.5	1		
Dichloroacetic acid	9.3	4.8	21.5	72		
Dichlorobenzene (1,3)	<0.5	<0.5	<0.5	73		
Dichloroethylene, cis (1,2)	<0.5	<0.5	<0.5	73		
Dichloroethylene, trans (1,2)	<0.5	<0.5	<0.5	73		
Dichloropropane (1,2)	<0.5	<0.5	<0.5	73		
Dieldrin	<0.008	<0.008	<0.008	4		
Dinoseb	<0.29	<0.05	<1.00	4		
gamma-hexachlorocyclohexane	<0.008	<0.008	<0.008	4		
g-chlordane	<0.008	<0.008	<0.008	4		
Heptachlor	<0.008	<0.008	<0.008	4		
Heptachlor Epoxide	<0.008	<0.008	<0.008	4		
Methoxychlor	<22.506	<0.008	<90.000	4		
Methyl Parathion	<0.1	<0.1	<0.1	3		
Methyl t-Butyl Ether (MTBE)	<0.5	<0.5	<0.5	73	(15)	
Methylene chloride	<0.67	<0.01	<1.00	3		
MIBK	<1	<1	<1	73		
Monobromoacetic acid	<1	<1	<2	72		
Monochloroacetic acid	<5	<2	<5	72		
op-DDT	<0.004	<0.004	<0.004	4		
Oxychlordane	<0.008	<0.008	<0.008	4		

### 7.9.a Routine Distribution System (does not include Field Reservoirs)

2022

					Limits	
	Mean	Min	Max	Count	*Approval or GCDWQ MAC, (AO or OG)	EPCOR
<b>Secondary Organics (ug/L) ***</b>						
Parathion	<0.1	<0.1	<0.1	4		
Perfluorobutane sulfonic acid (PFBS)	<0.02	<0.01	<0.02	4		
Perfluorobutanoic acid (PFBA)	<0.6	<0.1	<0.8	4		
Perfluoroheptanoic acid (PFHpA)	<0.02	<0.01	<0.02	4		
Perfluorohexane sulfonic acid (PFHxS)	<0.02	<0.01	<0.02	4		
Perfluorohexanoic acid (PFHxA)	<0.02	<0.01	<0.02	4		
Perfluorononanoic acid (PFNA)	<0.02	<0.01	<0.02	4		
Perfluoropentanoic acid (PFPeA)	<0.02	<0.01	<0.02	4		
pp-DDD	<0.004	<0.004	<0.004	4		
pp-DDE	<0.004	<0.004	<0.004	4		
pp-DDT	<0.004	<0.004	<0.004	4		
Prometon	<0.1	<0.1	<0.1	3		
Prometryne	<0.1	<0.1	<0.1	4		
Propazine	<0.1	<0.1	<0.1	3		
Styrene	<0.5	<0.5	<0.5	74		
Temephos	<1	<1	<1	4		
Terbutryn	<0.1	<0.1	<0.1	3		
Tetrachloroethane (1,1,2,2)	<1	<1	<1	73		
Total Organic Carbon	1.4	0.9	2.8	4		
Total Volatile Organics (NonTHM)	<1	<1	<1	73		
Total Volatile Organics (Unknown)	<1	<1	<1	73		
Triallate	<0.1	<0.1	<0.1	4		
Trichloroacetic acid	8.7	4.7	17.8	72		
Trichlorobenzene (1,2,4)	<0.488	<0.001	<0.500	81		
Trichloroethane (1,1,1)	<0.5	<0.5	<0.5	73		
Trichloroethane (1,1,2)	<0.5	<0.5	<0.5	1		
Trichloropropane (1,2,3)	<0.5	<0.5	<0.5	1		
Xylene (1,2)	<0.5	<0.5	<0.5	73		
Xylene (1,4)	<0.5	<0.5	<0.5	73		

## TABLE EXPLANATIONS:

- \* Numbers with no brackets are Health Canada Guidelines for Canadian Drinking Water Quality (GCDWQ) Maximum Acceptable Concentrations (MAC) and/or a limit set out in the Alberta Environment and Parks (AEP) Operating Approval 638-04-00. Limits in brackets indicate Aesthetic Objectives or Operational Guidelines (OG) and are not Approval limits. The EPCOR limits are internal limits set by EPCOR in the Operations Program.
- \*\* Primary parameters are those that have health-based limits (MACs) according the AEP Operating Approval 638-000
- \*\*\* Secondary parameters do not have health-based limits but may have aesthetic or operational objectives

### Schedule 4 Testing:

- As per AEP Approval 638-04-00 requirements 2 grab samples per annum and these were collected from two location in the distribution system during December and February (sampled February 7, 2022) and June to August (sampled July 4, 2022) and tested for all Schedule 4 parameters. Two additional samples were collected from two locations in the distribution system (on April 4, 2022 and November 7, 2022) and tested for all Schedule 4 parameters.

### Microcystin Testing:

- As per AEP Approval 638-04-00, one sample was collected from the distribution system between August 1 and 16 (sampled August 2, 2022) and between September 1 and September 16 (sampled Sept 6, 2022) and tested for total microcystin.

## 7.9.b Additional Distribution System Samples Collected from Water Quality Complaint Investigations

2022

					Limits	
	Mean	Min	Max	Count	*Approval or GCDWQ MAC, (AO or OG)	EPCOR
<b>Physical</b>						
Colour (TCU)	1.0	<0.5	4.3	97	(15)	10
pH (N/A)	7.9	7.6	8.3	96	(7.0 - 10.5)	7.3 - 8.3
Turbidity (NTU)	0.41	<0.04	2.51	97		1.0
<b>Primary Inorganics (mg/L) **</b>						
Antimony	<0.0002	<0.0002	<0.0002	98	0.006	
Arsenic	<0.0002	<0.0002	<0.0002	98	0.01	
Barium	0.061	<0.002	0.119	98	2	
Boron	0.012	0.006	0.043	98	2	
Cadmium	<0.0002	<0.0002	<0.0002	98	0.007	
Chromium	<0.0002	<0.0002	<0.0002	98	0.05	
Copper	0.011	<0.005	0.340	98	2 (1)	
Lead	0.0003	<0.0002	0.0054	98	0.005	
Manganese	0.003	<0.002	0.050	98	0.12 (0.02)	
Mercury	<0.00020	<0.00020	<0.00020	98	0.001	
Selenium	0.0002	<0.0002	0.0003	98	0.05	
Strontium	0.409	<0.002	0.489	98	7.0	
Total Chlorine	1.71	0.94	2.16	97	>0.5 and <3.0	>1.0 and <2.4
Uranium	0.0005	<0.0005	0.0006	98	0.02	
<b>Primary Organics (ug/L) **</b>						
Benzene	<0.5	<0.5	<1.0	101	5	
Carbon Tetrachloride	<1.0	<0.5	<1.0	101	2	
Chlorobenzene	<0.5	<0.5	<1.0	101	80 (30)	
Dichlorobenzene (1,2)	<0.5	<0.5	<0.6	101		
Dichlorobenzene (1,4)	<0.5	<0.5	<1.0	101	5 (1)	
Dichloroethane (1,2)	<1	<1	<1	4	5	
Dichloroethene (1,1)	<1	<1	<1	4	14	
Dichloroethylene (1,1)	<3	<3	<3	97	14	
Ethylbenzene	<0.5	<0.5	<1.0	101	140 (1.6)	
Methylene Chloride	<0.7	<0.5	<5.0	101	50	
Tetrachloroethene	<1	<1	<1	4	0.01	
Tetrachloroethylene	<0.5	<0.5	<0.5	97	10	
Toluene	<0.5	<0.5	<1.0	101	60 (24)	
Total Xylenes	<2.5	<2.5	<2.5	97	90	
Trichloroethene	<1	<1	<1	4	0.005	
Trichloroethylene	<0.5	<0.5	<0.5	97	5	
Vinyl Chloride	<1	<1	<1	4	2	

**7.9.b Additional Distribution System Samples Collected from Water Quality Complaint Investigations**

2022

	Mean	Min	Max	Count	Limits	
					*Approval or GCDWQ MAC, (AO or OG)	EPCOR
<b>Secondary Inorganics (mg/L) ***</b>						
Aluminum	0.072	0.006	0.276	98	2.9	0.1/0.2
Beryllium	<0.0002	<0.0002	<0.0002	98		
Calcium	46.4	<0.1	63.6	98		
Cobalt	0.0002	<0.0002	0.0010	98		
Iron	0.059	<0.005	0.338	98	(0.3)	0.3
Lanthanum	<0.001	<0.001	<0.001	98		
Lithium	0.0033	<0.0002	0.0045	98		
Magnesium	13.7	<0.1	16.5	98		
Molybdenum	0.0007	0.0005	0.0010	98		
Nickel	0.0009	<0.0005	0.0284	98		
Phosphorus	<0.02	<0.02	<0.02	98		
Potassium	1.0	0.5	3.2	98		
Silicon	2.04	1.48	3.28	98		
Silver	<0.0002	<0.0002	<0.0002	98		
Sodium	14.6	6.1	87.8	98	(200)	
Thallium	<0.0005	<0.0005	<0.0005	98		
Tin	<0.0005	<0.0005	<0.0005	98		
Titanium	<0.0005	<0.0005	<0.0005	98		
Total Hardness	166	<2	201	97		
Vanadium	<0.0005	<0.0005	<0.0005	98		
Zinc	0.012	<0.005	0.589	98	(5.0)	
Zirconium	<0.001	<0.001	<0.001	98		



**7.9.b Additional Distribution System Samples Collected from Water Quality Complaint Investigations**

2022

	Mean	Min	Max	Count	Limits	
					*Approval or GCDWQ MAC, (AO or OG)	EPCOR
<b>Secondary Organics (ug/L) ***</b>						
Bromodichloromethane	<0.5	<0.5	2.1	101	(15)	16
Bromoform	<1	<1	<1	101		
Chloroform	19.8	5.3	58.7	101		
Dibromo-3-Chloropropane (1,2)	<1	<1	<1	4		
Dibromochloromethane	<0.5	<0.5	<1.0	101		
Dibromoethane (1,2)	<1	<1	<1	4		
Dichlorobenzene (1,3)	<0.5	<0.5	<0.5	97		
Dichloroethylene, cis (1,2)	<0.5	<0.5	<0.5	97		
Dichloroethylene, trans (1,2)	<0.5	<0.5	<0.5	97		
Dichloropropane (1,2)	<0.5	<0.5	<0.5	97		
Dichloropropane (1,3)	<1	<1	<1	4		
Methyl t-Butyl Ether (MTBE)	<0.5	<0.5	<0.5	97		
MIBK	<1	<1	<1	97		
Styrene	<0.5	<0.5	<1.0	101		
Tetrachloroethane (1,1,1,2)	<1	<1	<1	4		
Tetrachloroethane (1,1,2,2)	<1	<1	<1	97		
Total Volatile Organics (NonTHM)	<1	<1	<1	97		
Total Volatile Organics (Unknown)	1.2	<1.0	9.2	97		
Trichlorobenzene (1,2,4)	<0.5	<0.5	<1.0	105		
Trichloroethane (1,1,1)	<0.5	<0.5	<0.5	97		
Trichloroethane (1,1,2)	<1	<1	<1	4		
Trichloropropane (1,2,3)	<1	<1	<1	4		
Trimethylbenzene (1,2,4)	<1	<1	<1	4		
Trimethylbenzene (1,3,5)	<1	<1	<1	4		
Xylene (1,2)	<0.5	<0.5	<0.5	97		
Xylene (1,4)	<0.5	<0.5	<0.5	97		

## 7.9.b Additional Distribution System Samples Collected from Water Quality Complaint Investigations

2022

### TABLE EXPLANATIONS:

- \* Numbers with no brackets are Health Canada Guidelines for Canadian Drinking Water Quality (GCDWQ) Maximum Acceptable Concentrations (MAC) and/or a limit set out in the Alberta Environment and Parks (AEP) Operating Approval 638-04-00. Limits in brackets indicate Aesthetic Objectives or Operational Guidelines (OG) and are not Approval Limits. The EPCOR limits are internal limits set by EPCOR in the Operations Program.
- \*\* Primary parameters are those that have health-based limits (MACs) according to the AEP Operating Approval 638-04-00.
- \*\*\* Secondary parameters do not have health-based limits but may have aesthetic or operational objectives.

**7.10 Castledowns, Clareview and Discovery Park Reservoirs  
2022**

Parameter	Castledowns				Clareview				Discovery Park				Limits	
	Mean	Min	Max	Count	Mean	Min	Max	Count	Mean	Min	Max	Count	*Approval or GCDWQ MAC, (AO or OG)	EPCOR
<b>Physical</b>														
Colour (TCU)	0.6	<0.5	0.8	4	0.9	<0.5	1.3	3	0.8	0.5	1.3	5	(15)	10
Conductivity (uS/cm)	393	356	439	4	407	365	509	20	397	364	479	5		
Odour	Inoff	Inoff	Inoff	4	Inoff	Inoff	Inoff	3	Inoff	Inoff	Inoff	5		
pH (N/A)	8.0	7.9	8.1	4	7.9	7.9	7.9	3	8.1	8.0	8.2	5	(7.0 - 10.5)	7.3 - 8.3
Turbidity (NTU)	0.07	0.04	0.11	36	0.18	0.08	0.42	24	0.09	0.04	0.24	38		1
<b>Primary Inorganics (mg/L) **</b>														
Aluminum	0.060	0.026	0.082	4	0.042	0.034	0.050	3	0.050	0.031	0.084	5	2.9	0.1/0.2
Antimony	<0.0002	<0.0002	<0.0002	4	<0.0002	<0.0002	<0.0002	3	<0.0002	<0.0002	0.0003	5	0.006	
Arsenic	<0.0002	<0.0002	0.0002	4	<0.0002	<0.0002	<0.0002	3	<0.0002	<0.0002	<0.0002	5	0.01	
Barium	0.064	0.057	0.074	4	0.064	0.058	0.071	3	0.060	0.056	0.076	5	2	
Boron	0.014	0.007	0.029	4	0.016	0.010	0.028	3	0.008	0.006	0.010	5	5	
Bromate Dissolved	<0.005	<0.005	<0.005	8	<0.005	<0.005	<0.005	6	<0.005	<0.005	<0.005	10	0.01	
Cadmium	<0.0002	<0.0002	<0.0002	4	<0.0002	<0.0002	<0.0002	3	<0.0002	<0.0002	<0.0002	5	0.005	
Chlorate Dissolved	0.127	0.090	0.156	8	0.191	0.144	0.265	6	0.094	0.080	0.132	10	1	
Chlorite Dissolved	<0.005	<0.005	<0.005	8	<0.005	<0.005	<0.005	6	<0.005	<0.005	<0.005	10	1	
Chromium	<0.0002	<0.0002	<0.0002	4	<0.0002	<0.0002	<0.0002	3	<0.0002	<0.0002	<0.0002	5	0.05	
Copper	<0.005	<0.005	<0.005	4	<0.005	<0.005	<0.005	3	<0.005	<0.005	<0.005	5	(1)	
Fluoride	0.68	0.64	0.71	4	0.69	0.68	0.70	3	0.67	0.66	0.68	5	1.5	0.6 - 0.8
Lead	<0.0002	<0.0002	<0.0002	4	<0.0002	<0.0002	<0.0002	3	<0.0002	<0.0002	<0.0002	5	0.005	
Manganese	<0.002	<0.002	<0.002	4	<0.002	<0.002	<0.002	3	0.004	<0.002	0.010	5	0.12 (0.02)	
Mercury	<0.0002	<0.0002	<0.0002	4	<0.0002	<0.0002	<0.0002	3	<0.0002	<0.0002	<0.0002	5	0.001	
Nitrate (as N) Dissolved	0.074	0.010	0.164	8	0.085	0.020	0.176	6	0.064	0.040	0.100	10	10	
Nitrite (as N) Dissolved	<0.010	<0.010	<0.010	8	<0.010	<0.010	<0.010	6	<0.010	<0.010	<0.010	10	1	
Selenium	<0.0002	<0.0002	0.0003	4	0.0002	<0.0002	0.0003	3	<0.0002	<0.0002	0.0003	5	0.05	
Strontium	0.413	0.373	0.476	4	0.396	0.321	0.437	3	0.418	0.315	0.451	5	7.0	
Total Chlorine	1.78	1.50	1.98	36	1.67	1.40	1.97	24	1.32	1.08	1.59	38	>0.5 and <3.0	>1.0 and <2.4
Uranium	<0.0005	<0.0005	<0.0005	4	<0.0005	<0.0005	<0.0005	3	<0.0005	<0.0005	0.0005	5	0.02	
<b>Primary Organics (ug/L) **</b>														
Benzene	<0.5	<0.5	<0.5	4	<0.5	<0.5	<0.5	3	<0.5	<0.5	<0.5	5	5	
Carbon Tetrachloride	<1.0	<1.0	<1.0	4	<1.0	<1.0	<1.0	3	<1.0	<1.0	<1.0	5	2	
Chlorobenzene	<0.50	<0.50	<0.50	4	<0.50	<0.50	<0.50	3	<0.50	<0.50	<0.50	5	80 (30)	
Dichlorobenzene (1,2)	<0.50	<0.50	<0.50	4	<0.50	<0.50	<0.50	3	<0.50	<0.50	<0.50	5	200 (3)	
Dichlorobenzene (1,4)	<0.5	<0.5	<0.5	4	<0.5	<0.5	<0.5	3	<0.5	<0.5	<0.5	5	5 (1)	
Dichloroethylene (1,1)	<3.0	<3.0	<3.0	4	<3.0	<3.0	<3.0	3	<3.0	<3.0	<3.0	5	14	
Ethylbenzene	<0.50	<0.50	<0.50	4	<0.50	<0.50	<0.50	3	<0.50	<0.50	<0.50	5	140 (1.6)	
Methylene Chloride	<0.5	<0.5	<0.5	4	<0.5	<0.5	<0.5	3	<0.5	<0.5	<0.5	5	50	
Tetrachloroethylene	<0.5	<0.5	<0.5	4	<0.5	<0.5	<0.5	3	<0.5	<0.5	<0.5	5	10	

**7.10 Castledowns, Clareview and Discovery Park Reservoirs  
2022**

Parameter													Limits	
	Castledowns				Clareview				Discovery Park				*Approval or GCDWQ MAC, (AO or OG)	EPCOR
	Mean	Min	Max	Count	Mean	Min	Max	Count	Mean	Min	Max	Count		
Toluene	<0.50	<0.50	<0.50	4	<0.50	<0.50	<0.50	3	<0.50	<0.50	<0.50	5	60 (24)	
Total Xylenes	<3	<3	<3	4	<3	<3	<3	3	<3	<3	<3	5	90	
Trichloroethylene	<0.50	<0.50	<0.50	4	<0.50	<0.50	<0.50	3	<0.50	<0.50	<0.50	5	5	
<b>Secondary Inorganics (mg/L) ***</b>														
Alkalinity Total	120	101	139	4	110	109	111	3	118	112	126	5		
Beryllium	<0.0002	<0.0002	<0.0002	4	<0.0002	<0.0002	<0.0002	3	<0.0002	<0.0002	<0.0002	5		
Bromide Dissolved	<0.010	<0.010	<0.010	8	<0.010	<0.010	<0.010	6	<0.010	<0.010	<0.010	10		
Calcium	46.8	41.3	54.0	4	47.0	45.1	49.4	3	47.3	46.3	49.5	5		
Calcium Hardness	113	98	126	4	111	106	118	3	111	109	117	5		
Chloride Dissolved	7.0	5.6	9.2	8	9.3	6.9	12.8	6	6.5	5.8	7.5	10	(250)	
Cobalt	<0.0002	<0.0002	0.0002	4	<0.0002	<0.0002	<0.0002	3	<0.0002	<0.0002	<0.0002	5		
Iron	<0.005	<0.005	<0.005	4	0.023	0.017	0.032	3	<0.006	<0.005	0.010	5	(0.3)	0.3
Lanthanum	<Inoff	<Inoff	<Inoff	4	<Inoff	<Inoff	<Inoff	3	<0	<0	<0	5		
Lithium	0.0032	0.0027	0.0040	4	0.0033	0.0027	0.0037	3	0.0030	0.0026	0.0031	5		
Magnesium	13.7	11.8	16.0	4	13.0	12.5	13.3	3	13.6	12.1	14.4	5		
Molybdenum	0.0008	0.0006	0.0008	4	0.0007	0.0007	0.0007	3	0.0007	0.0007	0.0007	5		
Nickel	<0.0005	<0.0005	0.0006	4	0.0006	<0.0005	0.0009	3	<0.0006	<0.0005	0.0008	5		
Phosphorus	<0.02	<0.02	<0.02	4	<0.02	<0.02	<0.02	3	<0.02	<0.02	<0.02	5		
Potassium	1.15	0.40	2.40	4	1.60	1.10	2.40	3	0.92	0.50	1.20	5		
Silicon	1.90	1.66	2.16	4	2.19	1.71	2.88	3	1.99	1.59	2.98	5		
Silver	<0.0002	<0.0002	<0.0002	4	<0.0002	<0.0002	<0.0002	3	<0.0002	<0.0002	<0.0002	5		
Sodium	14.1	6.9	21.6	4	18.3	14.5	21.2	3	15.4	7.4	34.6	5	(200)	
Sulphate Dissolved	74	60	85	8	84	77	92	6	77	56	118	10	(500)	
Thallium	<0.0005	<0.0005	<0.0005	4	<0.0005	<0.0005	<0.0005	3	<0.0005	<0.0005	<0.0005	5		
Tin	<0.0005	<0.0005	<0.0005	4	<0.0005	<0.0005	<0.0005	3	<0.0005	<0.0005	<0.0005	5		
Titanium	<0.0005	<0.0005	<0.0005	4	<0.0005	<0.0005	<0.0005	3	<0.0005	<0.0005	<0.0005	5		
Total Hardness (mg/L CaCO3)	171	147	194	4	166	158	171	3	169	164	179	5		
Vanadium	<0.0005	<0.0005	<0.0005	4	<0.0005	<0.0005	<0.0005	3	<0.0005	<0.0005	<0.0005	5		
Zinc	<0.005	<0.005	<0.005	4	<0.005	<0.005	<0.005	3	<0.005	<0.005	<0.005	5	(5.0)	
Zirconium	<0.0010	<0.0010	<0.0010	4	<0.0010	<0.0010	<0.0010	3	<0.0010	<0.0010	<0.0010	5		
<b>Secondary Organics (ug/L) ***</b>														
Bromodichloromethane	<0.5	<0.5	<0.5	4	<0.5	<0.5	<0.5	3	<0.5	<0.5	<0.5	5		16
Bromoform	<1.0	<1.0	<1.0	4	<1.0	<1.0	<1.0	3	<1.0	<1.0	<1.0	5		
Chloroform	19.9	7.2	32.0	4	21.7	10.1	37.0	3	14.1	6.3	31.8	5		
Dibromochloromethane	<0.50	<0.50	<0.50	4	<0.50	<0.50	<0.50	3	<0.50	<0.50	<0.50	5		
Dichlorobenzene (1,3)	<0.50	<0.50	<0.50	4	<0.50	<0.50	<0.50	3	<0.50	<0.50	<0.50	5		
Dichloroethylene, cis (1,2)	<0.50	<0.50	<0.50	4	<0.50	<0.50	<0.50	3	<0.50	<0.50	<0.50	5		
Dichloroethylene, trans (1,2)	<0.50	<0.50	<0.50	4	<0.50	<0.50	<0.50	3	<0.50	<0.50	<0.50	5		

**7.10 Castledowns, Clareview and Discovery Park Reservoirs  
2022**

Parameter	Castledowns				Clareview				Discovery Park				Limits	
	Mean	Min	Max	Count	Mean	Min	Max	Count	Mean	Min	Max	Count	*Approval or GCDWQ MAC, (AO or OG)	EPCOR
Dichloropropane (1,2)	<0.5	<0.5	<0.5	4	<0.5	<0.5	<0.5	3	<0.5	<0.5	<0.5	5	(15)	
Methyl t-Butyl Ether (MTBE)	<0.5	<0.5	<0.5	4	<0.5	<0.5	<0.5	3	<0.5	<0.5	<0.5	5		
MIBK	<1.0	<1.0	<1.0	4	<1.0	<1.0	<1.0	3	<1.0	<1.0	<1.0	5		
Styrene	<0.50	<0.50	<0.50	4	<0.50	<0.50	<0.50	3	<0.50	<0.50	<0.50	5		
Tetrachloroethane (1,1,2,2)	<1.0	<1.0	<1.0	4	<1.0	<1.0	<1.0	3	<1.0	<1.0	<1.0	5		
Total Organic Carbon	1.5	1.0	1.9	4	2.1	1.6	3.0	3	1.4	0.9	3.0	5		
Total Volatile Organics (NonTHM)	<1.0	<1.0	<1.0	4	<1.0	<1.0	<1.0	3	<1.0	<1.0	<1.0	5		
Total Volatile Organics (Unknown)	<1.0	<1.0	<1.0	4	<1.0	<1.0	<1.0	3	<1.0	<1.0	<1.0	5		
Trichlorobenzene (1,2,4)	<0.5	<0.5	<0.5	4	<0.5	<0.5	<0.5	3	<0.5	<0.5	<0.5	5		
Trichloroethane (1,1,1)	<0.5	<0.5	<0.5	4	<0.5	<0.5	<0.5	3	<0.5	<0.5	<0.5	5		
Xylene (1,2)	<0.5	<0.5	<0.5	4	<0.5	<0.5	<0.5	3	<0.5	<0.5	<0.5	5		
Xylene (1,4)	<0.5	<0.5	<0.5	4	<0.5	<0.5	<0.5	3	<0.5	<0.5	<0.5	5		

**TABLE EXPLANATIONS:**

\* Numbers with no brackets are Health Canada Guidelines for Canadian Drinking Water Quality (GCDWQ) Maximum Acceptable Concentrations (MAC) and/or a limit set out in the Alberta Environment and Parks (AEP) Operating Approval 638-04-00. Limits in brackets indicate Aesthetic Objectives or Operational Guidelines (OG) and are not Approval limits. The EPCOR limits are internal limits set by EPCOR in the Operations Program.

\*\* Primary parameters are those that have health-based limits (MACs) according the AEP Operating Approval 638-04-00

\*\*\* Secondary parameters do not have health-based limits but may have aesthetic or operational objectives

**7.11 Kaskitayo, Londonderry, Millwoods Reservoirs  
2022**

Parameter	Kaskitayo				Londonderry				Millwoods				Limits	
	Mean	Min	Max	Count	Mean	Min	Max	Count	Mean	Min	Max	Count	*Approval or GCDWQ MAC, (AO or OG)	EPCOR
<b>Physical</b>														
Colour (TCU)	1.0	0.8	1.1	4	1.0	0.7	1.4	5	0.6	0.5	0.8	4	(15)	10
Conductivity (uS/cm)	419	380	470	4	383	360	426	5	393	357	440	4		
Odour	Inoff	Inoff	Inoff	4	Inoff	Inoff	Inoff	5	Inoff	Inoff	Inoff	4		
pH (N/A)	8.0	7.9	8.2	4	7.9	7.8	8.0	5	7.8	7.7	8.0	4	(7.0 - 10.5)	7.3 - 8.3
Turbidity (NTU)	0.07	<0.04	0.24	34	0.07	0.04	0.18	37	0.09	<0.04	0.75	34		1
<b>Primary Inorganics (mg/L) **</b>														
Aluminum	0.058	0.025	0.087	4	0.063	0.022	0.118	5	0.058	0.021	0.076	4	2.9	0.1/0.2
Antimony	0.0003	<0.0002	0.0005	4	<0.0002	<0.0002	<0.0002	5	<0.0002	<0.0002	<0.0002	4	0.006	
Arsenic	<0.0002	<0.0002	<0.0002	4	<0.0002	<0.0002	0.0003	5	<0.0002	<0.0002	0.0003	4	0.01	
Barium	0.061	0.056	0.066	4	0.064	0.059	0.074	5	0.063	0.057	0.073	4	2	
Boron	0.009	0.008	0.010	4	0.015	0.008	0.024	5	0.011	0.008	0.017	4	5	
Bromate Dissolved	<0.005	<0.005	<0.005	8	<0.005	<0.005	<0.005	10	<0.005	<0.005	<0.005	8	0.01	
Cadmium	<0.0002	<0.0002	<0.0002	4	<0.0002	<0.0002	<0.0002	5	<0.0002	<0.0002	<0.0002	4	0.005	
Chlorate Dissolved	0.106	0.080	0.131	8	0.179	0.148	0.209	10	0.114	0.080	0.139	8	1	
Chlorite Dissolved	<0.005	<0.005	<0.005	8	<0.005	<0.005	<0.005	10	<0.005	<0.005	<0.005	8	1	
Chromium	<0.0002	<0.0002	<0.0002	4	<0.0002	<0.0002	<0.0002	5	<0.0002	<0.0002	<0.0002	4	0.05	
Copper	<0.005	<0.005	0.006	4	<0.005	<0.005	<0.005	5	0.012	<0.005	0.033	4	(1)	
Fluoride	0.67	0.64	0.68	4	0.70	0.69	0.71	5	0.69	0.63	0.72	4	1.5	0.6 - 0.8
Lead	<0.0002	<0.0002	<0.0002	4	<0.0002	<0.0002	<0.0002	5	<0.0002	<0.0002	0.0003	4	0.005	
Manganese	0.003	<0.002	0.005	4	<0.002	<0.002	<0.002	5	<0.002	<0.002	0.003	4	0.12 (0.02)	
Mercury	<0.0002	<0.0002	<0.0002	4	<0.0002	<0.0002	<0.0002	5	<0.0002	<0.0002	<0.0002	4	0.001	
Nitrate (as N) Dissolved	0.060	0.010	0.090	8	0.096	0.010	0.176	10	0.058	0.010	0.090	8	10	
Nitrite (as N) Dissolved	<0.010	<0.010	<0.010	8	<0.010	<0.010	<0.010	10	<0.010	<0.010	<0.010	8	1	
Selenium	0.0003	<0.0002	0.0003	4	<0.0002	<0.0002	0.0003	5	0.0003	<0.0002	0.0003	4	0.05	
Strontium	0.411	0.282	0.483	4	0.411	0.376	0.478	5	0.418	0.374	0.474	4	7.0	
Total Chlorine	1.88	1.58	2.05	34	1.82	1.52	2.04	37	1.81	0.89	2.02	34	>0.5 and <3.0	>1.0 and <2.4
Uranium	<0.0005	<0.0005	0.0006	4	<0.0005	<0.0005	0.0005	5	<0.0005	<0.0005	<0.0005	4	0.02	
<b>Primary Organics (ug/L) **</b>														
Benzene	<0.5	<0.5	<0.5	5	<0.5	<0.5	<0.5	6	<0.5	<0.5	<0.5	4	5	
Carbon Tetrachloride	<1.0	<1.0	<1.0	5	<1.0	<1.0	<1.0	6	<1.0	<1.0	<1.0	4	2	
Chlorobenzene	<0.50	<0.50	<0.50	5	<0.50	<0.50	<0.50	6	<0.50	<0.50	<0.50	4	80 (30)	
Dichlorobenzene (1,2)	<0.50	<0.50	<0.50	5	<0.50	<0.50	<0.50	6	<0.50	<0.50	<0.50	4	200 (3)	
Dichlorobenzene (1,4)	<0.5	<0.5	<0.5	5	<0.5	<0.5	<0.5	6	<0.5	<0.5	<0.5	4	5 (1)	
Dichloroethylene (1,1)	<3.0	<3.0	<3.0	5	<3.0	<3.0	<3.0	6	<3.0	<3.0	<3.0	4	14	
Ethylbenzene	<0.50	<0.50	<0.50	5	<0.50	<0.50	<0.50	6	<0.50	<0.50	<0.50	4	140 (1.6)	
Methylene Chloride	<0.5	<0.5	<0.5	5	<0.5	<0.5	<0.5	6	<0.5	<0.5	<0.5	4	50	
Tetrachloroethylene	<0.5	<0.5	<0.5	5	<0.5	<0.5	<0.5	6	<0.5	<0.5	<0.5	4	10	

**7.11 Kaskitayo, Londonderry, Millwoods Reservoirs  
2022**

Parameter													Limits	
	Kaskitayo				Londonderry				Millwoods				*Approval or GCDWQ MAC, (AO or OG)	EPCOR
	Mean	Min	Max	Count	Mean	Min	Max	Count	Mean	Min	Max	Count		
Toluene	<0.50	<0.50	<0.50	5	<0.50	<0.50	<0.50	6	<0.50	<0.50	<0.50	4	60 (24)	
Total Xylenes	<3	<3	<3	5	<3	<3	<3	6	<3	<3	<3	4	90	
Trichloroethylene	<0.50	<0.50	<0.50	5	<0.50	<0.50	<0.50	6	<0.50	<0.50	<0.50	4	5	
<b>Secondary Inorganics (mg/L) ***</b>														
Alkalinity Total	124	110	139	4	115	98	135	5	118	100	135	4		
Beryllium	<0.0002	<0.0002	<0.0002	4	<0.0002	<0.0002	<0.0002	5	<0.0002	<0.0002	<0.0002	4		
Bromide Dissolved	<0.010	<0.010	<0.010	8	<0.010	<0.010	<0.010	10	<0.010	<0.010	<0.010	8		
Calcium	48.8	46.7	52.8	4	45.9	41.2	53.3	5	47.0	41.4	52.8	4		
Calcium Hardness	117	110	128	4	110	100	126	5	112	98	125	4		
Chloride Dissolved	6.8	5.6	7.6	8	7.4	6.0	9.4	10	6.6	5.4	7.6	8	(250)	
Cobalt	<0.0002	<0.0002	0.0003	4	<0.0002	<0.0002	<0.0002	5	<0.0002	<0.0002	0.0002	4		
Iron	0.014	<0.005	0.039	4	<0.005	<0.005	0.006	5	<0.005	<0.005	<0.005	4	(0.3)	0.3
Lanthanum	<Inoff	<Inoff	<Inoff	4	<Inoff	<Inoff	<Inoff	5	<0	<0	<0	4		
Lithium	0.0032	0.0026	0.0034	4	0.0036	0.0032	0.0044	5	0.0032	0.0026	0.0040	4		
Magnesium	14.2	12.2	16.2	4	13.5	11.9	15.9	5	13.9	11.9	15.8	4		
Molybdenum	0.0008	0.0006	0.0009	4	0.0008	0.0007	0.0008	5	0.0007	0.0006	0.0008	4		
Nickel	<0.0006	<0.0005	0.0007	4	<0.0005	<0.0005	0.0006	5	<0.0005	<0.0005	0.0006	4		
Phosphorus	<0.02	<0.02	<0.02	4	<0.02	<0.02	<0.02	5	<0.02	<0.02	<0.02	4		
Potassium	0.93	0.50	1.30	4	1.52	0.70	2.50	5	1.10	0.60	2.10	4		
Silicon	2.25	1.69	2.99	4	1.97	1.71	2.19	5	1.93	1.69	2.17	4		
Silver	<0.0002	<0.0002	<0.0002	4	<0.0002	<0.0002	<0.0002	5	<0.0002	<0.0002	<0.0002	4		
Sodium	16.9	7.4	31.5	4	12.9	7.5	17.7	5	13.8	7.0	22.0	4	(200)	
Sulphate Dissolved	81	63	115	8	71	59	79	10	71	60	82	8	(500)	
Thallium	<0.0005	<0.0005	<0.0005	4	<0.0005	<0.0005	<0.0005	5	<0.0005	<0.0005	<0.0005	4		
Tin	<0.0005	<0.0005	<0.0005	4	<0.0005	<0.0005	<0.0005	5	<0.0005	<0.0005	<0.0005	4		
Titanium	<0.0005	<0.0005	<0.0005	4	<0.0005	<0.0005	<0.0005	5	<0.0005	<0.0005	<0.0005	4		
Total Hardness (mg/L CaCO3)	177	168	193	4	165	142	193	5	170	145	189	4		
Vanadium	<0.0005	<0.0005	<0.0005	4	<0.0005	<0.0005	<0.0005	5	<0.0005	<0.0005	<0.0005	4		
Zinc	<0.006	<0.005	0.008	4	<0.005	<0.005	<0.005	5	0.007	<0.005	0.014	4	(5.0)	
Zirconium	<0.0010	<0.0010	<0.0010	4	<0.0010	<0.0010	<0.0010	5	<0.0010	<0.0010	<0.0010	4		
<b>Secondary Organics (ug/L) ***</b>														
Bromodichloromethane	<0.5	<0.5	<0.5	5	<0.5	<0.5	<0.5	6	<0.5	<0.5	<0.5	4		16
Bromoform	<1.0	<1.0	<1.0	5	<1.0	<1.0	<1.0	6	<1.0	<1.0	<1.0	4		
Chloroform	14.2	<0.5	29.8	5	16.9	<0.5	35.2	6	18.5	7.1	28.7	4		
Dibromochloromethane	<0.50	<0.50	<0.50	5	<0.50	<0.50	<0.50	6	<0.50	<0.50	<0.50	4		
Dichlorobenzene (1,3)	<0.50	<0.50	<0.50	5	<0.50	<0.50	<0.50	6	<0.50	<0.50	<0.50	4		
Dichloroethylene, cis (1,2)	<0.50	<0.50	<0.50	5	<0.50	<0.50	<0.50	6	<0.50	<0.50	<0.50	4		
Dichloroethylene, trans (1,2)	<0.50	<0.50	<0.50	5	<0.50	<0.50	<0.50	6	<0.50	<0.50	<0.50	4		

**7.11 Kaskitayo, Londonderry, Millwoods Reservoirs  
2022**

Parameter	Kaskitayo				Londonderry				Millwoods				Limits	
	Mean	Min	Max	Count	Mean	Min	Max	Count	Mean	Min	Max	Count	*Approval or GCDWQ MAC, (AO or OG)	EPCOR
Dichloropropane (1,2)	<0.5	<0.5	<0.5	5	<0.5	<0.5	<0.5	6	<0.5	<0.5	<0.5	4	(15)	
Methyl t-Butyl Ether (MTBE)	<0.5	<0.5	<0.5	5	<0.5	<0.5	<0.5	6	<0.5	<0.5	<0.5	4		
MIBK	<1.0	<1.0	<1.0	5	<1.0	<1.0	<1.0	6	<1.0	<1.0	<1.0	4		
Styrene	<0.50	<0.50	<0.50	5	<0.50	<0.50	<0.50	6	<0.50	<0.50	<0.50	4		
Tetrachloroethane (1,1,2,2)	<1.0	<1.0	<1.0	5	<1.0	<1.0	<1.0	6	<1.0	<1.0	<1.0	4		
Total Organic Carbon	1.8	1.1	2.9	4	1.6	1.1	1.9	5	1.4	0.9	1.8	4		
Total Volatile Organics (NonTHM)	<1.0	<1.0	<1.0	5	<1.0	<1.0	<1.0	6	<1.0	<1.0	<1.0	4		
Total Volatile Organics (Unknown)	<1.0	<1.0	<1.0	5	<1.0	<1.0	<1.0	6	<1.0	<1.0	<1.0	4		
Trichlorobenzene (1,2,4)	<0.5	<0.5	<0.5	5	<0.5	<0.5	<0.5	6	<0.5	<0.5	<0.5	4		
Trichloroethane (1,1,1)	<0.5	<0.5	<0.5	5	<0.5	<0.5	<0.5	6	<0.5	<0.5	<0.5	4		
Xylene (1,2)	<0.5	<0.5	<0.5	5	<0.5	<0.5	<0.5	6	<0.5	<0.5	<0.5	4		
Xylene (1,4)	<0.5	<0.5	<0.5	5	<0.5	<0.5	<0.5	6	<0.5	<0.5	<0.5	4		

**TABLE EXPLANATIONS:**

\* Numbers with no brackets are Health Canada Guidelines for Canadian Drinking Water Quality (GCDWQ) Maximum Acceptable Concentrations (MAC) and/or a limit set out in the Alberta Environment and Parks (AEP) Operating Approval 638-04-00. Limits in brackets indicate Aesthetic Objectives or Operational Guidelines (OG) and are not Approval limits. The EPCOR limits are internal limits set by EPCOR in the Operations Program.

\*\* Primary parameters are those that have health-based limits (MACs) according the AEP Operating Approval 638-04-00

\*\*\* Secondary parameters do not have health-based limits but may have aesthetic or operational objectives



**7.12 North Jasper Place, Ormsby, Papaschase 1 Reservoirs  
2022**

Parameter	North Jasper Place				Ormsby				Papaschase 1				Limits	
	Mean	Min	Max	Count	Mean	Min	Max	Count	Mean	Min	Max	Count	*Approval or GCDWQ MAC, (AO or OG)	EPCOR
<b>Physical</b>														
Colour (TCU)	0.9	0.7	1.3	5	0.7	<0.5	1.2	5	0.6	<0.5	0.7	4	(15)	10
Conductivity (uS/cm)	403	367	478	5	387	356	438	5	383	355	426	4		
Odour	Inoff	Inoff	Inoff	5	Inoff	Inoff	Inoff	5	Inoff	Inoff	Inoff	4		
pH (N/A)	8.0	7.9	8.1	5	7.9	7.7	8.0	5	7.9	7.7	8.0	4	(7.0 - 10.5)	7.3 - 8.3
Turbidity (NTU)	0.10	0.05	0.14	38	0.35	0.05	8.82	36	0.13	0.08	0.56	35		1
<b>Primary Inorganics (mg/L) **</b>														
Aluminum	0.059	0.034	0.078	5	0.152	0.030	0.434	4	0.070	0.037	0.108	4	2.9	0.1/0.2
Antimony	0.0006	<0.0002	0.0017	5	<0.0002	<0.0002	<0.0002	4	<0.0002	<0.0002	<0.0002	4	0.006	
Arsenic	<0.0002	<0.0002	0.0002	5	<0.0002	<0.0002	0.0003	4	<0.0002	<0.0002	0.0003	4	0.01	
Barium	0.061	0.056	0.073	5	0.064	0.057	0.075	4	0.064	0.059	0.073	4	2	
Boron	0.009	0.008	0.011	5	0.014	0.008	0.026	4	0.014	0.008	0.028	4	5	
Bromate Dissolved	<0.005	<0.005	<0.005	10	<0.005	<0.005	<0.005	8	<0.005	<0.005	<0.005	8	0.01	
Cadmium	<0.0002	<0.0002	<0.0002	5	<0.0002	<0.0002	<0.0002	4	<0.0002	<0.0002	<0.0002	4	0.005	
Chlorate Dissolved	0.110	0.100	0.137	10	0.115	0.080	0.145	8	0.153	0.130	0.174	8	1	
Chlorite Dissolved	<0.005	<0.005	<0.005	10	<0.005	<0.005	<0.005	8	<0.005	<0.005	<0.005	8	1	
Chromium	<0.0002	<0.0002	<0.0002	5	<0.0002	<0.0002	0.0002	4	<0.0002	<0.0002	<0.0002	4	0.05	
Copper	<0.005	<0.005	<0.005	5	<0.006	<0.005	0.009	4	<0.005	<0.005	<0.005	4	(1)	
Fluoride	0.67	0.64	0.70	5	0.67	0.63	0.71	5	0.69	0.66	0.72	4	1.5	0.6 - 0.8
Lead	<0.0002	<0.0002	<0.0002	5	<0.0002	<0.0002	<0.0002	4	<0.0002	<0.0002	<0.0002	4	0.005	
Manganese	0.003	<0.002	0.007	5	0.010	<0.002	0.034	4	<0.002	<0.002	<0.002	4	0.12 (0.02)	
Mercury	<0.0002	<0.0002	<0.0002	5	<0.0002	<0.0002	<0.0002	4	<0.0002	<0.0002	<0.0002	4	0.001	
Nitrate (as N) Dissolved	0.074	0.050	0.090	10	0.062	0.010	0.107	8	0.067	0.020	0.116	8	10	
Nitrite (as N) Dissolved	<0.010	<0.010	<0.010	10	<0.010	<0.010	<0.010	8	<0.010	<0.010	<0.010	8	1	
Selenium	0.0003	<0.0002	0.0003	5	0.0003	0.0002	0.0003	4	0.0003	0.0002	0.0003	4	0.05	
Strontium	0.418	0.305	0.465	5	0.419	0.385	0.474	4	0.429	0.386	0.469	4	7.0	
Total Chlorine	1.56	1.27	1.98	38	1.79	1.42	2.04	36	1.65	1.17	2.03	35	>0.5 and <3.0	>1.0 and <2.4
Uranium	<0.0005	<0.0005	0.0005	5	<0.0005	<0.0005	<0.0005	4	<0.0005	<0.0005	<0.0005	4	0.02	
<b>Primary Organics (ug/L) **</b>														
Benzene	<0.5	<0.5	<0.5	6	<0.5	<0.5	<0.5	4	<0.5	<0.5	<0.5	5	5	
Carbon Tetrachloride	<1.0	<1.0	<1.0	6	<1.0	<1.0	<1.0	4	<1.0	<1.0	<1.0	5	2	
Chlorobenzene	<0.50	<0.50	<0.50	6	<0.50	<0.50	<0.50	4	<0.50	<0.50	<0.50	5	80 (30)	
Dichlorobenzene (1,2)	<0.50	<0.50	<0.50	6	<0.50	<0.50	<0.50	4	<0.50	<0.50	<0.50	5	200 (3)	
Dichlorobenzene (1,4)	<0.5	<0.5	<0.5	6	<0.5	<0.5	<0.5	4	<0.5	<0.5	<0.5	5	5 (1)	
Dichloroethylene (1,1)	<3.0	<3.0	<3.0	6	<3.0	<3.0	<3.0	4	<3.0	<3.0	<3.0	5	14	
Ethylbenzene	<0.50	<0.50	<0.50	6	<0.50	<0.50	<0.50	4	<0.50	<0.50	<0.50	5	140 (1.6)	
Methylene Chloride	<0.5	<0.5	<0.5	6	<0.5	<0.5	<0.5	4	<0.5	<0.5	<0.5	5	50	
Tetrachloroethylene	<0.5	<0.5	<0.5	6	<0.5	<0.5	<0.5	4	<0.5	<0.5	<0.5	5	10	

**7.12 North Jasper Place, Ormsby, Papaschase 1 Reservoirs  
2022**

Parameter													Limits	
	North Jasper Place				Ormsby				Papaschase 1				*Approval or GCDWQ MAC, (AO or OG)	EPCOR
	Mean	Min	Max	Count	Mean	Min	Max	Count	Mean	Min	Max	Count		
Toluene	<0.50	<0.50	<0.50	6	<0.50	<0.50	<0.50	4	<0.50	<0.50	<0.50	5	60 (24)	
Total Xylenes	<3	<3	<3	6	<3	<3	<3	4	<3	<3	<3	5	90	
Trichloroethylene	<0.50	<0.50	<0.50	6	<0.50	<0.50	<0.50	4	<0.50	<0.50	<0.50	5	5	
<b>Secondary Inorganics (mg/L) ***</b>														
Alkalinity Total	122	112	130	5	119	98	137	5	120	109	132	4		
Beryllium	<0.0002	<0.0002	<0.0002	5	<0.0002	<0.0002	<0.0002	4	<0.0002	<0.0002	<0.0002	4		
Bromide Dissolved	<0.010	<0.010	<0.010	10	<0.010	<0.010	<0.010	8	<0.010	<0.010	<0.010	8		
Calcium	48.1	46.7	49.7	5	46.8	41.3	53.7	4	47.8	44.5	52.0	4		
Calcium Hardness	115	110	118	5	113	98	126	5	114	106	122	4		
Chloride Dissolved	6.5	5.9	7.4	10	6.6	5.4	7.8	8	6.6	5.8	7.7	8	(250)	
Cobalt	<0.0002	<0.0002	<0.0002	5	0.0003	<0.0002	0.0004	4	<0.0002	<0.0002	<0.0002	4		
Iron	0.008	<0.005	0.011	5	0.013	<0.005	0.035	4	0.012	0.010	0.015	4	(0.3)	0.3
Lanthanum	<Inoff	<Inoff	<Inoff	5	<Inoff	<Inoff	<Inoff	4	<0	<0	<0	4		
Lithium	0.0031	0.0026	0.0033	5	0.0033	0.0028	0.0040	4	0.0036	0.0032	0.0044	4		
Magnesium	13.9	12.1	15.1	5	13.8	12.0	15.8	4	14.1	12.9	15.4	4		
Molybdenum	0.0007	0.0007	0.0008	5	0.0008	0.0007	0.0008	4	0.0007	0.0007	0.0008	4		
Nickel	<0.0005	<0.0005	0.0007	5	<0.0006	<0.0005	0.0008	4	<0.0005	<0.0005	<0.0005	4		
Phosphorus	<0.02	<0.02	<0.02	5	<0.02	<0.02	<0.02	4	<0.02	<0.02	<0.02	4		
Potassium	0.94	0.70	1.30	5	1.15	0.60	2.30	4	1.08	0.70	1.80	4		
Silicon	2.15	1.75	3.09	5	1.96	1.70	2.32	4	1.96	1.76	2.20	4		
Silver	<0.0002	<0.0002	<0.0002	5	<0.0002	<0.0002	<0.0002	4	<0.0002	<0.0002	<0.0002	4		
Sodium	15.5	7.3	36.1	5	14.0	6.9	21.9	4	11.5	7.4	16.4	4	(200)	
Sulphate Dissolved	74	57	120	10	72	60	82	8	69	60	79	8	(500)	
Thallium	<0.0005	<0.0005	<0.0005	5	<0.0005	<0.0005	<0.0005	4	<0.0005	<0.0005	<0.0005	4		
Tin	<0.0005	<0.0005	<0.0005	5	<0.0005	<0.0005	<0.0005	4	<0.0005	<0.0005	<0.0005	4		
Titanium	<0.0005	<0.0005	<0.0005	5	0.0027	<0.0005	0.0083	4	<0.0005	<0.0005	<0.0005	4		
Total Hardness (mg/L CaCO3)	173	167	180	5	171	145	189	5	173	158	184	4		
Vanadium	<0.0005	<0.0005	<0.0005	5	<0.0005	<0.0005	<0.0005	4	<0.0005	<0.0005	<0.0005	4		
Zinc	<0.005	<0.005	<0.005	5	<0.005	<0.005	<0.005	4	<0.005	<0.005	<0.005	4	(5.0)	
Zirconium	<0.0010	<0.0010	<0.0010	5	<0.0010	<0.0010	<0.0010	4	<0.0010	<0.0010	<0.0010	4		
<b>Secondary Organics (ug/L) ***</b>														
Bromodichloromethane	<0.5	<0.5	<0.5	6	<0.5	<0.5	<0.5	4	<0.5	<0.5	<0.5	5		16
Bromoform	<1.0	<1.0	<1.0	6	<1.0	<1.0	<1.0	4	<1.0	<1.0	<1.0	5		
Chloroform	13.5	<0.5	29.4	6	19.4	7.5	30.3	4	17.8	<0.5	33.3	5		
Dibromochloromethane	<0.50	<0.50	<0.50	6	<0.50	<0.50	<0.50	4	<0.50	<0.50	<0.50	5		
Dichlorobenzene (1,3)	<0.50	<0.50	<0.50	6	<0.50	<0.50	<0.50	4	<0.50	<0.50	<0.50	5		
Dichloroethylene, cis (1,2)	<0.50	<0.50	<0.50	6	<0.50	<0.50	<0.50	4	<0.50	<0.50	<0.50	5		
Dichloroethylene, trans (1,2)	<0.50	<0.50	<0.50	6	<0.50	<0.50	<0.50	4	<0.50	<0.50	<0.50	5		

**7.12 North Jasper Place, Ormsby, Papaschase 1 Reservoirs  
2022**

Parameter	North Jasper Place				Ormsby				Papaschase 1				Limits	
	Mean	Min	Max	Count	Mean	Min	Max	Count	Mean	Min	Max	Count	*Approval or GCDWQ MAC, (AO or OG)	EPCOR
Dichloropropane (1,2)	<0.5	<0.5	<0.5	6	<0.5	<0.5	<0.5	4	<0.5	<0.5	<0.5	5	(15)	
Methyl t-Butyl Ether (MTBE)	<0.5	<0.5	<0.5	6	<0.5	<0.5	<0.5	4	<0.5	<0.5	<0.5	5		
MIBK	<1.0	<1.0	<1.0	6	<1.0	<1.0	<1.0	4	<1.0	<1.0	<1.0	5		
Styrene	<0.50	<0.50	<0.50	6	<0.50	<0.50	<0.50	4	<0.50	<0.50	<0.50	5		
Tetrachloroethane (1,1,2,2)	<1.0	<1.0	<1.0	6	<1.0	<1.0	<1.0	4	<1.0	<1.0	<1.0	5		
Total Organic Carbon	1.4	0.8	3.0	5	1.4	0.9	1.8	4	1.4	1.0	1.9	4		
Total Volatile Organics (NonTHM)	<1.0	<1.0	<1.0	6	<1.0	<1.0	<1.0	4	<1.0	<1.0	<1.0	5		
Total Volatile Organics (Unknown)	<1.0	<1.0	<1.0	6	<1.0	<1.0	<1.0	4	<1.0	<1.0	<1.0	5		
Trichlorobenzene (1,2,4)	<0.5	<0.5	<0.5	6	<0.5	<0.5	<0.5	4	<0.5	<0.5	<0.5	5		
Trichloroethane (1,1,1)	<0.5	<0.5	<0.5	6	<0.5	<0.5	<0.5	4	<0.5	<0.5	<0.5	5		
Xylene (1,2)	<0.5	<0.5	<0.5	6	<0.5	<0.5	<0.5	4	<0.5	<0.5	<0.5	5		
Xylene (1,4)	<0.5	<0.5	<0.5	6	<0.5	<0.5	<0.5	4	<0.5	<0.5	<0.5	5		

**TABLE EXPLANATIONS:**

- \* Numbers with no brackets are Health Canada Guidelines for Canadian Drinking Water Quality (GCDWQ) Maximum Acceptable Concentrations (MAC) and/or a limit set out in the Alberta Environment and Parks (AEP) Operating Approval 638-04-00. Limits in brackets indicate Aesthetic Objectives or Operational Guidelines (OG) and are not Approval limits. The EPCOR limits are internal limits set by EPCOR in the Operations Program.
- \*\* Primary parameters are those that have health-based limits (MACs) according the AEP Operating Approval 638-04-00
- \*\*\* Secondary parameters do not have health-based limits but may have aesthetic or operational objectives

**7.13 Papaschase 2, Rosslyn 1, Rosslyn 2 Reservoirs  
2022**

Parameter	Papaschase 2				Rosslyn 1				Rosslyn 2				Limits	
	Mean	Min	Max	Count	Mean	Min	Max	Count	Mean	Min	Max	Count	*Approval or GCDWQ MAC, (AO or OG)	EPCOR
<b>Physical</b>														
Colour (TCU)	1.0	<0.5	1.4	5	0.9	0.6	1.1	4	1.1	0.9	1.6	4	(15)	10
Conductivity (uS/cm)	412	377	438	5	389	366	423	4	390	368	423	4		
Odour	Inoff	Inoff	Inoff	5	Inoff	Inoff	Inoff	4	Inoff	Inoff	Inoff	4		
pH (N/A)	8.0	7.8	8.2	5	7.9	7.9	8.0	4	7.9	7.8	8.1	4	(7.0 - 10.5)	7.3 - 8.3
Turbidity (NTU)	0.08	<0.04	0.37	36	0.08	0.05	0.17	35	0.08	0.05	0.15	31		1
<b>Primary Inorganics (mg/L) **</b>														
Aluminum	0.049	0.026	0.085	5	0.070	0.027	0.118	4	0.055	0.021	0.086	4	2.9	0.1/0.2
Antimony	<0.0003	<0.0002	0.0005	5	<0.0002	<0.0002	<0.0002	4	0.0004	<0.0002	0.0011	4	0.006	
Arsenic	<0.0002	<0.0002	<0.0002	5	<0.0002	<0.0002	0.0002	4	<0.0002	<0.0002	0.0002	4	0.01	
Barium	0.065	0.057	0.074	5	0.066	0.062	0.071	4	0.062	0.056	0.074	4	2	
Boron	0.009	0.008	0.010	5	0.015	0.009	0.027	4	0.009	0.007	0.011	4	5	
Bromate Dissolved	<0.005	<0.005	<0.005	10	<0.005	<0.005	<0.005	8	<0.005	<0.005	<0.005	8	0.01	
Cadmium	<0.0002	<0.0002	<0.0002	5	<0.0002	<0.0002	<0.0002	4	<0.0002	<0.0002	<0.0002	4	0.005	
Chlorate Dissolved	0.130	0.080	0.160	10	0.169	0.145	0.222	8	0.155	0.134	0.199	8	1	
Chlorite Dissolved	<0.005	<0.005	<0.005	10	<0.005	<0.005	<0.005	8	<0.005	<0.005	<0.005	8	1	
Chromium	<0.0002	<0.0002	<0.0002	5	<0.0002	<0.0002	<0.0002	4	<0.0002	<0.0002	<0.0002	4	0.05	
Copper	<0.005	<0.005	<0.005	5	<0.005	<0.005	<0.005	4	<0.005	<0.005	<0.005	4	(1)	
Fluoride	0.68	0.68	0.69	5	0.70	0.69	0.71	4	0.69	0.68	0.70	4	1.5	0.6 - 0.8
Lead	<0.0002	<0.0002	<0.0002	5	<0.0002	<0.0002	<0.0002	4	<0.0002	<0.0002	<0.0002	4	0.005	
Manganese	<0.002	<0.002	0.003	5	<0.002	<0.002	<0.002	4	<0.002	<0.002	<0.002	4	0.12 (0.02)	
Mercury	<0.0002	<0.0002	<0.0002	5	<0.0002	<0.0002	<0.0002	4	<0.0002	<0.0002	<0.0002	4	0.001	
Nitrate (as N) Dissolved	0.058	0.010	0.090	10	0.080	0.020	0.179	8	0.065	0.030	0.090	8	10	
Nitrite (as N) Dissolved	<0.010	<0.010	<0.010	10	<0.010	<0.010	<0.010	8	<0.010	<0.010	<0.010	8	1	
Selenium	0.0003	<0.0002	0.0003	5	0.0003	0.0002	0.0003	4	0.0002	0.0002	0.0003	4	0.05	
Strontium	0.398	0.309	0.488	5	0.423	0.374	0.464	4	0.411	0.301	0.467	4	7.0	
Total Chlorine	1.82	1.47	2.00	36	1.64	1.08	1.98	35	1.75	1.28	1.99	31	>0.5 and <3.0	>1.0 and <2.4
Uranium	<0.0005	<0.0005	0.0006	5	<0.0005	<0.0005	0.0005	4	<0.0005	<0.0005	0.0005	4	0.02	
<b>Primary Organics (ug/L) **</b>														
Benzene	<0.5	<0.5	<0.5	7	<0.5	<0.5	<0.5	4	<0.5	<0.5	<0.5	6	5	
Carbon Tetrachloride	<1.0	<1.0	<1.0	7	<1.0	<1.0	<1.0	4	<1.0	<1.0	<1.0	6	2	
Chlorobenzene	<0.50	<0.50	<0.50	7	<0.50	<0.50	<0.50	4	<0.50	<0.50	<0.50	6	80 (30)	
Dichlorobenzene (1,2)	<0.50	<0.50	<0.50	7	<0.50	<0.50	<0.50	4	<0.50	<0.50	<0.50	6	200 (3)	
Dichlorobenzene (1,4)	<0.5	<0.5	<0.5	7	<0.5	<0.5	<0.5	4	<0.5	<0.5	<0.5	6	5 (1)	
Dichloroethylene (1,1)	<3.0	<3.0	<3.0	7	<3.0	<3.0	<3.0	4	<3.0	<3.0	<3.0	6	14	
Ethylbenzene	<0.50	<0.50	<0.50	7	<0.50	<0.50	<0.50	4	<0.50	<0.50	<0.50	6	140 (1.6)	
Methylene Chloride	<0.5	<0.5	<0.5	7	<0.5	<0.5	<0.5	4	<0.5	<0.5	<0.5	6	50	
Tetrachloroethylene	<0.5	<0.5	<0.5	7	<0.5	<0.5	<0.5	4	<0.5	<0.5	<0.5	6	10	

**7.13 Papaschase 2, Rosslyn 1, Rosslyn 2 Reservoirs  
2022**

Parameter													Limits	
	Papaschase 2				Rosslyn 1				Rosslyn 2				*Approval or GCDWQ MAC, (AO or OG)	EPCOR
	Mean	Min	Max	Count	Mean	Min	Max	Count	Mean	Min	Max	Count		
Toluene	<0.50	<0.50	<0.50	7	<0.50	<0.50	<0.50	4	<0.50	<0.50	<0.50	6	60 (24)	
Total Xylenes	<3	<3	<3	7	<3	<3	<3	4	<3	<3	<3	6	90	
Trichloroethylene	<0.50	<0.50	<0.50	7	<0.50	<0.50	<0.50	4	<0.50	<0.50	<0.50	6	5	
<b>Secondary Inorganics (mg/L) ***</b>														
Alkalinity Total	119	107	139	5	119	100	132	4	119	101	132	4		
Beryllium	<0.0002	<0.0002	<0.0002	5	<0.0002	<0.0002	<0.0002	4	<0.0002	<0.0002	<0.0002	4		
Bromide Dissolved	<0.010	<0.010	<0.010	10	<0.010	<0.010	<0.010	8	<0.010	<0.010	<0.010	8		
Calcium	49.0	46.6	53.8	5	47.6	42.3	52.2	4	47.5	46.5	48.8	4		
Calcium Hardness	116	110	126	5	114	102	122	4	114	112	118	4		
Chloride Dissolved	6.9	5.5	8.1	10	7.4	6.1	10.4	8	6.3	5.2	7.2	8	(250)	
Cobalt	<0.0002	<0.0002	0.0002	5	<0.0002	<0.0002	<0.0002	4	<0.0002	<0.0002	<0.0002	4		
Iron	<0.005	<0.005	<0.005	5	0.013	0.005	0.035	4	<0.005	<0.005	<0.005	4	(0.3)	0.3
Lanthanum	<Inoff	<Inoff	<Inoff	5	<Inoff	<Inoff	<Inoff	4	<0	<0	<0	4		
Lithium	0.0031	0.0025	0.0037	5	0.0036	0.0033	0.0042	4	0.0030	0.0024	0.0034	4		
Magnesium	13.9	12.3	16.4	5	14.1	12.3	15.5	4	14.0	12.2	15.1	4		
Molybdenum	0.0008	0.0007	0.0008	5	0.0008	0.0007	0.0008	4	0.0008	0.0007	0.0008	4		
Nickel	<0.0006	<0.0005	0.0008	5	<0.0005	<0.0005	0.0005	4	<0.0006	<0.0005	0.0008	4		
Phosphorus	<0.02	<0.02	<0.02	5	<0.02	<0.02	<0.02	4	<0.02	<0.02	<0.02	4		
Potassium	0.98	0.50	1.40	5	1.30	0.70	2.50	4	0.90	0.50	1.30	4		
Silicon	2.38	1.70	2.98	5	2.00	1.71	2.26	4	2.17	1.68	3.07	4		
Silver	<0.0002	<0.0002	<0.0002	5	<0.0002	<0.0002	<0.0002	4	<0.0002	<0.0002	<0.0002	4		
Sodium	17.1	7.5	26.8	5	12.7	7.9	17.9	4	12.5	7.0	22.5	4	(200)	
Sulphate Dissolved	82	62	104	10	70	59	79	8	72	57	98	8	(500)	
Thallium	<0.0005	<0.0005	<0.0005	5	<0.0005	<0.0005	<0.0005	4	<0.0005	<0.0005	<0.0005	4		
Tin	<0.0005	<0.0005	<0.0005	5	<0.0005	<0.0005	<0.0005	4	<0.0005	<0.0005	<0.0005	4		
Titanium	<0.0005	<0.0005	<0.0005	5	<0.0005	<0.0005	<0.0005	4	<0.0005	<0.0005	<0.0005	4		
Total Hardness (mg/L CaCO3)	175	168	189	5	170	150	188	4	171	164	178	4		
Vanadium	<0.0005	<0.0005	<0.0005	5	<0.0005	<0.0005	<0.0005	4	<0.0005	<0.0005	<0.0005	4		
Zinc	<0.005	<0.005	<0.005	5	<0.005	<0.005	<0.005	4	<0.005	<0.005	<0.005	4	(5.0)	
Zirconium	<0.0010	<0.0010	<0.0010	5	<0.0010	<0.0010	<0.0010	4	<0.0010	<0.0010	<0.0010	4		
<b>Secondary Organics (ug/L) ***</b>														
Bromodichloromethane	<0.5	<0.5	<0.5	7	<0.5	<0.5	<0.5	4	<0.5	<0.5	<0.5	6		16
Bromoform	<1.0	<1.0	<1.0	7	<1.0	<1.0	<1.0	4	<1.0	<1.0	<1.0	6		
Chloroform	15.8	<0.5	33.1	7	22.5	10.8	35.2	4	12.8	<0.5	30.1	6		
Dibromochloromethane	<0.50	<0.50	<0.50	7	<0.50	<0.50	<0.50	4	<0.50	<0.50	<0.50	6		
Dichlorobenzene (1,3)	<0.50	<0.50	<0.50	7	<0.50	<0.50	<0.50	4	<0.50	<0.50	<0.50	6		
Dichloroethylene, cis (1,2)	<0.50	<0.50	<0.50	7	<0.50	<0.50	<0.50	4	<0.50	<0.50	<0.50	6		
Dichloroethylene, trans (1,2)	<0.50	<0.50	<0.50	7	<0.50	<0.50	<0.50	4	<0.50	<0.50	<0.50	6		

**7.13 Papaschase 2, Rosslyn 1, Rosslyn 2 Reservoirs  
2022**

Parameter	Papaschase 2				Rosslyn 1				Rosslyn 2				Limits	
	Mean	Min	Max	Count	Mean	Min	Max	Count	Mean	Min	Max	Count	*Approval or GCDWQ MAC, (AO or OG)	EPCOR
Dichloropropane (1,2)	<0.5	<0.5	<0.5	7	<0.5	<0.5	<0.5	4	<0.5	<0.5	<0.5	6	(15)	
Methyl t-Butyl Ether (MTBE)	<0.5	<0.5	<0.5	7	<0.5	<0.5	<0.5	4	<0.5	<0.5	<0.5	6		
MIBK	<1.0	<1.0	<1.0	7	<1.0	<1.0	<1.0	4	<1.0	<1.0	<1.0	6		
Styrene	<0.50	<0.50	<0.50	7	<0.50	<0.50	<0.50	4	<0.50	<0.50	<0.50	6		
Tetrachloroethane (1,1,2,2)	<1.0	<1.0	<1.0	7	<1.0	<1.0	<1.0	4	<1.0	<1.0	<1.0	6		
Total Organic Carbon	2.0	1.0	3.0	5	1.6	1.1	2.0	4	1.7	0.9	3.2	4		
Total Volatile Organics (NonTHM)	<1.0	<1.0	<1.0	7	<1.0	<1.0	<1.0	4	<1.0	<1.0	<1.0	6		
Total Volatile Organics (Unknown)	<1.0	<1.0	<1.0	7	<1.0	<1.0	<1.0	4	<1.0	<1.0	<1.0	6		
Trichlorobenzene (1,2,4)	<0.5	<0.5	<0.5	7	<0.5	<0.5	<0.5	4	<0.5	<0.5	<0.5	6		
Trichloroethane (1,1,1)	<0.5	<0.5	<0.5	7	<0.5	<0.5	<0.5	4	<0.5	<0.5	<0.5	6		
Xylene (1,2)	<0.5	<0.5	<0.5	7	<0.5	<0.5	<0.5	4	<0.5	<0.5	<0.5	6		
Xylene (1,4)	<0.5	<0.5	<0.5	7	<0.5	<0.5	<0.5	4	<0.5	<0.5	<0.5	6		

**TABLE EXPLANATIONS:**

- \* Numbers with no brackets are Health Canada Guidelines for Canadian Drinking Water Quality (GCDWQ) Maximum Acceptable Concentrations (MAC) and/or a limit set out in the Alberta Environment and Parks (AEP) Operating Approval 638-04-00. Limits in brackets indicate Aesthetic Objectives or Operational Guidelines (OG) and are not Approval limits. The EPCOR limits are internal limits set by EPCOR in the Operations Program.
- \*\* Primary parameters are those that have health-based limits (MACs) according the AEP Operating Approval 638-04-00
- \*\*\* Secondary parameters do not have health-based limits but may have aesthetic or operational objectives

**7.14 Thorncliff Reservoir  
2022**

Parameter	Thorncliff				Limits	
	Mean	Min	Max	Count	*Approval or GCDWQ MAC, (AO or OG)	EPCOR
<b>Physical</b>						
Colour (TCU)	0.8	0.7	1.0	4	(15)	10
Conductivity (uS/cm)	409	368	483	4		
Odour	Inoff	Inoff	Inoff	4		
pH (N/A)	8.0	7.9	8.2	4	(7.0 - 10.5)	7.3 - 8.3
Turbidity (NTU)	0.10	0.05	0.27	36		1
<b>Primary Inorganics (mg/L) **</b>						
Aluminum	0.076	0.031	0.096	4	2.9	0.1/0.2
Antimony	<0.0003	<0.0002	0.0004	4	0.006	
Arsenic	<0.0002	<0.0002	<0.0002	4	0.01	
Barium	0.063	0.056	0.078	4	2	
Boron	0.009	0.007	0.011	4	5	
Bromate Dissolved	<0.005	<0.005	<0.005	8	0.01	
Cadmium	<0.0002	<0.0002	<0.0002	4	0.005	
Chlorate Dissolved	0.101	0.080	0.132	8	1	
Chlorite Dissolved	<0.005	<0.005	<0.005	8	1	
Chromium	<0.0002	<0.0002	<0.0002	4	0.05	
Copper	<0.005	<0.005	<0.005	4	(1)	
Fluoride	0.67	0.66	0.69	4	1.5	0.6 - 0.8
Lead	<0.0002	<0.0002	<0.0002	4	0.005	
Manganese	0.005	<0.002	0.012	4	0.12 (0.02)	
Mercury	<0.0002	<0.0002	<0.0002	4	0.001	
Nitrate (as N) Dissolved	0.070	0.040	0.090	8	10	
Nitrite (as N) Dissolved	<0.010	<0.010	<0.010	8	1	
Selenium	0.0003	<0.0002	0.0003	4	0.05	
Strontium	0.419	0.331	0.476	4	7.0	
Total Chlorine	1.62	1.13	2.14	36	>0.5 and <3.0	>1.0 and <2.4
Uranium	<0.0005	<0.0005	0.0005	4	0.02	
<b>Primary Organics (ug/L) **</b>						
Benzene	<0.5	<0.5	<0.5	4	5	
Carbon Tetrachloride	<1.0	<1.0	<1.0	4	2	
Chlorobenzene	<0.50	<0.50	<0.50	4	80 (30)	
Dichlorobenzene (1,2)	<0.50	<0.50	<0.50	4	200 (3)	
Dichlorobenzene (1,4)	<0.5	<0.5	<0.5	4	5 (1)	
Dichloroethylene (1,1)	<3.0	<3.0	<3.0	4	14	
Ethylbenzene	<0.50	<0.50	<0.50	4	140 (1.6)	
Methylene Chloride	<0.5	<0.5	<0.5	4	50	
Tetrachloroethylene	<0.5	<0.5	<0.5	4	10	

**7.14 Thorncliff Reservoir  
2022**

Parameter	Thorncliff				Limits	
	Mean	Min	Max	Count	*Approval or GCDWQ MAC, (AO or OG)	EPCOR
Toluene	<0.50	<0.50	<0.50	4		
Total Xylenes	<3	<3	<3	4	60 (24)	
Trichloroethylene	<0.50	<0.50	<0.50	4	90	
					5	
<b>Secondary Inorganics (mg/L) ***</b>						
Alkalinity Total	122	113	133	4		
Beryllium	<0.0002	<0.0002	<0.0002	4		
Bromide Dissolved	<0.010	<0.010	<0.010	8		
Calcium	48.2	46.5	49.7	4		
Calcium Hardness	116	111	124	4		
Chloride Dissolved	6.6	5.6	7.4	8	(250)	
Cobalt	<0.0002	<0.0002	<0.0002	4		
Iron	<0.005	<0.005	<0.005	4	(0.3)	0.3
Lanthanum	<Inoff	<Inoff	<Inoff	4		
Lithium	0.0030	0.0026	0.0032	4		
Magnesium	13.9	12.2	15.5	4		
Molybdenum	0.0008	0.0007	0.0008	4		
Nickel	<0.0006	<0.0005	0.0007	4		
Phosphorus	<0.02	<0.02	<0.02	4		
Potassium	0.88	0.50	1.20	4		
Silicon	2.14	1.70	2.82	4		
Silver	<0.0002	<0.0002	<0.0002	4		
Sodium	16.6	7.2	34.1	4	(200)	
Sulphate Dissolved	80	59	120	8	(500)	
Thallium	<0.0005	<0.0005	<0.0005	4		
Tin	<0.0005	<0.0005	<0.0005	4		
Titanium	<0.0005	<0.0005	<0.0005	4		
Total Hardness (mg/L CaCO3)	175	168	182	4		
Vanadium	<0.0005	<0.0005	<0.0005	4		
Zinc	<0.005	<0.005	<0.005	4	(5.0)	
Zirconium	<0.0010	<0.0010	<0.0010	4		
<b>Secondary Organics (ug/L) ***</b>						
Bromodichloromethane	<0.5	<0.5	<0.5	4		16
Bromoform	<1.0	<1.0	<1.0	4		
Chloroform	17.7	11.4	33.7	4		
Dibromochloromethane	<0.50	<0.50	<0.50	4		
Dichlorobenzene (1,3)	<0.50	<0.50	<0.50	4		
Dichloroethylene, cis (1,2)	<0.50	<0.50	<0.50	4		
Dichloroethylene, trans (1,2)	<0.50	<0.50	<0.50	4		



**7.14 Thorncliff Reservoir  
2022**

Parameter	Thorncliff				Limits	
	Mean	Min	Max	Count	*Approval or GCDWQ MAC, (AO or OG)	EPCOR
Dichloropropane (1,2)	<0.5	<0.5	<0.5	4	(15)	
Methyl t-Butyl Ether (MTBE)	<0.5	<0.5	<0.5	4		
MIBK	<1.0	<1.0	<1.0	4		
Styrene	<0.50	<0.50	<0.50	4		
Tetrachloroethane (1,1,2,2)	<1.0	<1.0	<1.0	4		
Total Organic Carbon	1.6	0.9	2.9	4		
Total Volatile Organics (NonTHM)	<1.0	<1.0	<1.0	4		
Total Volatile Organics (Unknown)	<1.0	<1.0	<1.0	4		
Trichlorobenzene (1,2,4)	<0.5	<0.5	<0.5	4		
Trichloroethane (1,1,1)	<0.5	<0.5	<0.5	4		
Xylene (1,2)	<0.5	<0.5	<0.5	4		
Xylene (1,4)	<0.5	<0.5	<0.5	4		

**TABLE EXPLANATIONS:**

- \* Numbers with no brackets are Health Canada Guidelines for Canadian Drinking Water Quality (GCDWQ) Maximum Acceptable Concentrations (MAC) and/or a limit set out in the Alberta Environment and Parks (AEP) Operating Approval 638-04-00. Limits in brackets indicate Aesthetic Objectives or Operational Guidelines (OG) and are not Approval limits. The EPCOR limits are internal limits set by EPCOR in the Operations Program.
- \*\* Primary parameters are those that have health-based limits (MACs) according the AEP Operating Approval 638-04-00
- \*\*\* Secondary parameters do not have health-based limits but may have aesthetic or operational objectives

## 7.15 Distribution System Disinfection By-products

2022

Parameter	Mean	Min	Max	Count	Limits	
					GCDWQ or Approval or MAC* or (AO or OG)	EPCOR single result
<b>HAA (ug/L)</b>					80	40
<b>Far End of Distribution System</b>						
Dead End	19.4	11.2	41.3	13		
Water Transfer to Regional Customers	21.4	12.6	37.1	12		
<b>Middle of Distribution System</b>						
Staff Residence	19.4	10.5	40.2	46		
	19.8	10.5	41.3	71		
<b>NDMA (ng/L)</b>					40	10
<b>Far End of Distribution System</b>						
Dead End	0.002	0.001	0.004	8		
Water Transfer to Regional Customers	0.002	0.001	0.003	5		
<b>Middle of Distribution System</b>						
Staff Residence	0.002	0.001	0.004	26		
	0.002	0.001	0.004	39		
<b>Trihalomethanes (ug/L)</b>					100	50
<b>Far End of Distribution System</b>						
Dead End	16.7	7.4	37.2	13		
Water Transfer to Regional Customers	18.8	11.4	35.5	12		
<b>Middle of Distribution System</b>						
Field Reservoirs	15.6	1.0	37.0	96		
Staff Residence	16.5	7.0	37.4	46		
	16.2	1.0	37.4	167		

## 7.16 Raw River Water: Physical, Inorganic, Organic and Pesticide Parameters

2022

	ROSSDALE				E.L. SMITH			
	Mean	Min	Max	Count	Mean	Min	Max	Count
<b>Microbiologicals</b>								
Microcystin	<0.10	<0.10	0.11	12	<0.10	<0.10	0.13	12
<b>Physical</b>								
Colour (TCU)	9.8	1.6	72.2	365	9.9	2.2	76.9	366
Conductivity (uS/cm)	343	297	396	53	338	297	386	53
FPA-Intensity (N/A)	0.65	0.25	1.50	66	0.65	0.31	1.38	66
pH (N/A)	8.2	8.0	8.4	13	8.2	8.0	8.4	13
Total Dissolved Solids (mg/L)	202	166	228	13	202	167	228	13
Total Suspended Solids	47	<5	376	13	26	<5	129	13
Turbidity (NTU)	39	1	2,590	365	29	1	2,330	366
<b>Primary Inorganics (mg/L) **</b>								
Antimony	0.0004	<0.0002	0.0033	13	0.0004	<0.0002	0.0032	13
Arsenic	0.0006	<0.0002	0.0039	13	0.0004	<0.0002	0.0010	13
Barium	0.083	0.053	0.233	13	0.076	0.055	0.127	13
Boron	0.009	<0.005	0.013	13	0.010	<0.005	0.013	13
Bromate Dissolved	<0.005	<0.003	<0.005	54	<0.005	<0.003	<0.005	54
Cadmium	<0.0002	<0.0002	<0.0002	13	<0.0002	<0.0002	<0.0002	13
Chlorate Dissolved	<0.012	<0.010	<0.100	54	<0.012	<0.010	<0.100	54
Chlorite Dissolved	<0.009	<0.005	<0.200	54	<0.009	<0.005	<0.200	54
Chromium	0.0022	<0.0002	0.0188	13	0.0012	<0.0002	0.0061	13
Copper	<0.005	<0.005	0.009	13	<0.005	<0.005	<0.005	13
Cyanide Dissolved	<0.002	<0.002	<0.002	13	<0.002	<0.002	<0.002	13
Fluoride	0.12	0.10	0.14	53	0.11	0.10	0.13	53
Lead	0.0009	<0.0002	0.0065	13	0.0004	<0.0002	0.0010	13
Manganese	0.045	<0.002	0.371	13	0.021	0.003	0.095	13
Mercury	<0.0002	<0.000005	<0.0002	17	<0.0002	<0.000005	<0.0002	17
Nitrate (as N) Dissolved	0.053	<0.010	0.306	54	0.049	<0.010	0.278	54
Nitrite (as N) Dissolved	<0.010	<0.005	0.010	54	<0.010	<0.005	0.010	54
Selenium	<0.0002	<0.0002	0.0004	13	<0.0002	<0.0002	0.0003	13
Total Chlorine	<0.03	<0.03	<0.03	13	<0.03	<0.03	<0.03	13
Uranium	<0.0005	<0.0005	0.0006	13	<0.0005	<0.0005	0.0006	13

## 7.16 Raw River Water: Physical, Inorganic, Organic and Pesticide Parameters

2022

	ROSSDALE				E.L. SMITH			
	Mean	Min	Max	Count	Mean	Min	Max	Count
<b>Primary Organics (ug/L) **</b>								
2,4-D	<2.538	<0.050	<10.000	4	<2.538	<0.050	<10.000	4
Atrazine	<0.100	<0.100	<0.100	4	<0.100	<0.100	<0.100	4
Benzene	<0.5	<0.5	<1.0	375	<0.5	<0.5	<1.0	376
Benzo(a)pyrene	<0.01	<0.01	<0.01	4	<0.01	<0.01	<0.01	4
Bromoxynil	<0.163	<0.050	<0.500	4	<0.163	<0.050	<0.500	4
Carbon Tetrachloride	<1.0	<0.5	<1.0	374	<1.0	<0.5	<1.0	375
Chlorobenzene	<0.51	<0.00	<1.00	378	<0.51	<0.00	<1.00	379
Chlorpyrifos	<0.100	<0.100	<0.100	4	<0.100	<0.100	<0.100	4
Cyanazine	<0.100	<0.100	<0.100	4	<0.100	<0.100	<0.100	4
Diazinon	<0.100	<0.100	<0.100	4	<0.100	<0.100	<0.100	4
Dicamba	<3.075	<0.100	<12.000	4	<3.075	<0.100	<12.000	4
Dichlorobenzene (1,2)	<0.50	<0.50	<0.50	363	<0.50	<0.50	<0.50	364
Dichlorobenzene (1,4)	<0.5	<0.5	<0.5	363	<0.5	<0.5	<0.5	364
Dichloroethylene (1,1)	<3.00	<3.00	<3.00	363	<3.00	<3.00	<3.00	364
Dichlorophenol (2,4)	<0.30	<0.30	<0.30	4	<0.30	<0.30	<0.30	4
Diclofop-methyl	<0.10	<0.10	<0.10	4	<0.10	<0.10	<0.10	4
Dimethoate	<0.100	<0.100	<0.100	4	<0.100	<0.100	<0.100	4
Diuron	<1.0	<1.0	<1.0	4	<1.0	<1.0	<1.0	4
Ethylbenzene	<0.51	<0.50	<1.00	375	<0.51	<0.50	<1.00	376
Glyphosate	<0.15	<0.01	<0.20	4	<0.15	<0.01	<0.20	4
Malathion	<0.100	<0.100	<0.100	4	<0.100	<0.100	<0.100	4
MCPA	<0.163	<0.050	<0.500	4	<0.163	<0.050	<0.500	4
Methylene Chloride	<0.6	<0.5	<5.0	374	<0.6	<0.5	<5.0	375
Metolachlor	<0.100	<0.100	<0.100	4	<0.100	<0.100	<0.100	4
Metribuzin	<0.325	<0.100	<1.000	4	<0.325	<0.100	<1.000	4
Nitritotriacetic acid	<0.20	<0.20	<0.20	4	<0.20	<0.20	<0.20	4
Pentachlorophenol	<1.9	<0.5	<6.0	4	<1.9	<0.5	<6.0	4
Perfluorooctane sulfonic acid (PFOS)	<0.01	<0.01	<0.01	4	<0.01	<0.01	<0.01	4
Perfluorooctanoic acid (PFOA)	<0.01	<0.01	<0.01	4	<0.01	<0.01	<0.01	4
Phorate	<0.100	<0.100	<0.100	4	<0.100	<0.100	<0.100	4
Picloram	<4.825	<0.100	<19.000	4	<4.825	<0.100	<19.000	4
Simazine	<0.100	<0.100	<0.100	4	<0.100	<0.100	<0.100	4
Terbufos	<0.10	<0.10	<0.10	4	<0.10	<0.10	<0.10	4
Tetrachloroethylene	<0.5	<0.5	<0.5	364	<0.5	<0.5	<0.5	365
Toluene	<0.51	<0.50	<1.00	375	<0.51	<0.50	<1.00	376
Total Xylenes	<3	<3	<3	363	<3	<3	<3	364
Trichloroethylene	<0.50	<0.50	<0.50	364	<0.50	<0.50	<0.50	365
Trifluralin	<0.100	<0.100	<0.100	4	<0.100	<0.100	<0.100	4
Trihalomethanes	<1.0	<1.0	<1.0	363	<1.0	<1.0	<1.0	364
Vinyl Chloride	<1.0	<1.0	<1.0	11	<1.0	<1.0	<1.0	11
<b>Radionuclides (Bq/L)</b>								
Cesium-137	<0.15	<0.10	<0.20	2	<0.15	<0.10	<0.20	2
Gross Alpha	0.60	<0.21	0.98	2	<0.14	<0.11	<0.16	2
Gross Beta	0.85	0.29	1.40	2	0.11	0.08	0.14	2
Iodine-131	<0.50	<0.30	<0.70	2	<0.45	<0.40	<0.50	2
Lead-210	<0.11	<0.02	<0.20	2	<0.02	<0.02	<0.02	2
Radium-226	0.06	0.01	0.10	2	<0.01	<0.01	<0.01	2
Strontium-90	<0.3	<0.1	<0.5	2	<0.1	<0.1	<0.1	2
Tritium	<40	<40	<40	2	<40	<40	<40	2

## 7.16 Raw River Water: Physical, Inorganic, Organic and Pesticide Parameters

2022

	ROSSDALE				E.L. SMITH			
	Mean	Min	Max	Count	Mean	Min	Max	Count
<b>Secondary Inorganics (mg/L) ***</b>								
Alkalinity Total	132	112	172	53	131	111	168	53
Alkalinity, PHP (mg CaCO <sub>3</sub> /L)	<3	<1	<3	13	<3	<1	<3	13
Aluminum	1.579	0.037	15.200	13	0.924	0.063	5.280	13
Ammonia as NH <sub>3</sub>	<0.05	<0.05	0.14	68	<0.06	<0.05	0.15	68
Beryllium	<0.0002	<0.0002	<0.0002	13	<0.0002	<0.0002	<0.0002	13
Bromide Dissolved	<0.012	<0.010	<0.050	54	<0.012	<0.010	<0.050	54
Calcium Dissolved	46.6	40.9	53.0	13	46.3	40.4	53.3	13
Calcium Hardness	108	92	126	53	108	91	126	53
Chloride Dissolved	1.52	0.50	5.05	54	0.80	0.40	3.34	54
Cobalt	0.0007	<0.0002	0.0057	13	0.0003	<0.0002	0.0008	13
Free Chlorine	<0.03	<0.03	<0.03	13	<0.03	<0.03	<0.03	13
Iron	1.503	0.036	14.000	13	0.814	0.066	4.260	13
Lanthanum	<0.001	<0.001	<0.001	13	<0.001	<0.001	<0.001	13
Lithium	0.0048	0.0029	0.0148	13	0.0041	0.0030	0.0073	13
Magnesium	14.9	12.4	19.1	13	14.4	11.6	16.2	13
Manganese Dissolved	<0.002	<0.002	0.005	13	<0.002	<0.002	0.006	13
Molybdenum	0.0007	<0.0002	0.0009	13	0.0007	<0.0002	0.0009	13
Nickel	0.0025	<0.0005	0.0183	13	0.0010	<0.0005	0.0024	13
Ortho_P	<0.02	<0.02	0.02	12	<0.02	<0.02	<0.02	12
Phosphorus	0.06	<0.02	0.31	13	0.03	<0.02	0.07	13
Potassium	1.30	0.60	4.70	13	1.13	0.60	2.40	13
Silicon	5.00	1.41	34.80	13	3.76	1.50	14.60	13
Silver	<0.0002	<0.0002	0.0003	13	<0.0002	<0.0002	<0.0002	13
Sodium	4.5	2.8	6.8	13	3.9	2.7	6.2	13
Strontium	0.434	0.336	0.489	13	0.429	0.302	0.496	13
Sulphate Dissolved	49.9	32.5	60.0	54	49.2	32.8	60.0	54
Sulphide	<0.002	<0.002	0.003	13	<0.002	<0.002	0.003	13
Thallium	<0.0005	<0.0005	<0.0005	13	<0.0005	<0.0005	<0.0005	13
Tin	<0.0005	<0.0005	<0.0005	13	<0.0005	<0.0005	<0.0005	13
Titanium	0.0250	<0.0005	0.2300	13	0.0211	0.0011	0.1200	13
Total Hardness (mg/L CaCO <sub>3</sub> )	170	145	193	53	169	142	194	53
Total Kjeldahl Nitrogen	0.36	<0.10	2.00	13	0.22	<0.10	0.60	13
Vanadium	0.0036	<0.0005	0.0337	13	0.0023	<0.0005	0.0097	13
Zinc	<0.006	<0.005	0.008	13	<0.005	<0.005	0.007	13
Zirconium	<0.0010	<0.0010	<0.0010	13	<0.0010	<0.0010	<0.0010	13

## 7.16 Raw River Water: Physical, Inorganic, Organic and Pesticide Parameters

2022

	ROSSDALE				E.L. SMITH			
	Mean	Min	Max	Count	Mean	Min	Max	Count
Secondary Organics (ug/L) ***								
Aldicarb	<1.0	<0.9	<1.0	4	<1.0	<0.9	<1.0	4
Aldrin	<0.008	<0.008	<0.008	4	<0.008	<0.008	<0.008	4
Azinphos-methyl	<0.1	<0.1	<0.1	4	<0.1	<0.1	<0.1	4
Bromobenzene	<1.00	<1.00	<1.00	11	<1.00	<1.00	<1.00	11
Bromodichloromethane	<0.5	<0.5	<1.0	375	<0.5	<0.5	<1.0	376
Bromoform	<1.0	<0.5	<1.0	375	<1.0	<0.5	<1.0	376
Bromomethane	<9.2	<0.5	<10.0	12	<9.2	<0.5	<10.0	12
Carbaryl	<0.275	<0.200	<0.500	4	<0.275	<0.200	<0.500	4
Carbofuran	<0.275	<0.200	<0.500	4	<0.275	<0.200	<0.500	4
Chloroethane	<9.2	<0.5	<10.0	12	<9.2	<0.5	<10.0	12
Chloroform	<0.513	<0.001	<1.000	378	<0.513	<0.001	<1.000	379
Chloromethane	<9.6	<5.0	<10.0	12	<9.6	<5.0	<10.0	12
Dibromochloromethane	<0.51	<0.01	<1.00	378	<0.51	<0.01	<1.00	379
Dibromomethane	<1.00	<1.00	<1.00	11	<1.00	<1.00	<1.00	11
Dichlorobenzene (1,3)	<0.50	<0.50	<0.50	363	<0.50	<0.50	<0.50	364
Dichloroethylene, cis (1,2)	<0.50	<0.50	<0.50	363	<0.50	<0.50	<0.50	364
Dichloroethylene, trans (1,2)	<0.50	<0.50	<0.50	363	<0.50	<0.50	<0.50	364
Dichloropropane (1,2)	<0.5	<0.5	<0.5	363	<0.5	<0.5	<0.5	364
Dieldrin	<0.008	<0.008	<0.008	4	<0.008	<0.008	<0.008	4
Hexachlorobutadiene	<1.0	<1.0	<1.0	11	<1.0	<1.0	<1.0	11
Hexachloroethane	<1.0	<1.0	<1.0	11	<1.0	<1.0	<1.0	11
Methyl t-Butyl Ether (MTBE)	<0.5	<0.5	<0.5	363	<0.5	<0.5	<0.5	364
MIBK	<1.0	<1.0	<1.0	363	<1.0	<1.0	<1.0	364
n-Butylbenzene	<1.0	<1.0	<1.0	11	<1.0	<1.0	<1.0	11
n-Propylbenzene	<1.00	<1.00	<1.00	11	<1.00	<1.00	<1.00	11
Parathion	<0.100	<0.100	<0.100	4	<0.100	<0.100	<0.100	4
Perfluorobutanoic acid (PFBA)	<0.6	<0.1	<0.8	4	<0.6	<0.1	<0.8	4
Perfluoroheptanoic acid (PFHpA)	<0.02	<0.01	<0.02	4	<0.02	<0.01	<0.02	4
Perfluorohexane sulfonic acid (PFHxS)	<0.02	<0.01	<0.02	4	<0.02	<0.01	<0.02	4
Perfluorohexanoic acid (PFHxA)	<0.02	<0.01	<0.02	4	<0.02	<0.01	<0.02	4
Perfluorononanoic acid (PFNA)	<0.02	<0.01	<0.02	4	<0.02	<0.01	<0.02	4
Perfluoropentanoic acid (PFPeA)	<0.02	<0.01	<0.02	4	<0.02	<0.01	<0.02	4
p-Isopropyltoluene	<5.00	<5.00	<5.00	11	<5.00	<5.00	<5.00	11
sec-Butylbenzene	<1.0	<1.0	<1.0	11	<1.0	<1.0	<1.0	11
Styrene	<0.51	<0.50	<1.00	375	<0.51	<0.50	<1.00	376
tert-Butylbenzene	<1.0	<1.0	<1.0	11	<1.0	<1.0	<1.0	11
Tetrachloroethane (1,1,2,2)	<1.0	<1.0	<1.0	363	<1.0	<1.0	<1.0	364
Total Organic Carbon	2.5	1.0	10.6	53	2.5	<0.6	10.3	53
Total Volatile Organics (NonTHM)	<1.0	<1.0	<1.0	363	<1.0	<1.0	<1.0	364
Total Volatile Organics (Unknown)	<1.0	<1.0	<1.0	363	<1.0	<1.0	<1.0	364
Triallate	<0.100	<0.100	<0.100	4	<0.100	<0.100	<0.100	4
Trichlorobenzene (1,2,4)	<0.5	<0.5	<0.5	363	<0.5	<0.5	<0.5	364
Trichloroethane (1,1,1)	<0.5	<0.5	<0.5	363	<0.5	<0.5	<0.5	364
Trichlorofluoromethane	<1.00	<1.00	<1.00	11	<1.00	<1.00	<1.00	11
Xylene (1,2)	<0.5	<0.5	<0.5	363	<0.5	<0.5	<0.5	364
Xylene (1,4)	<0.5	<0.5	<0.5	363	<0.5	<0.5	<0.5	364

**TABLE EXPLANATIONS:**

- \*\* Primary parameters are those that have health-based limits (MACs) according the AEP Operating Approval 638-04-00**
- \*\*\* Secondary parameters do not have health-based limits but may have aesthetic or operational objectives**

## 7. 17 EPCOR Lead Management Program (2022)

EPCOR has had a proactive lead management program in place since 2008, which aims to reduce exposures to lead in drinking water. For many years a major focus of the lead management program was dealing with lead service lines. The underground pipe that connects a property's plumbing to the water main in the street is called a service line. The EPCOR portion of the service line runs from the water main under the street or alley to the property line, and the homeowner (or business owner) portion of the service line runs from the property line to the water meter in the home or building. At the end of 2021, approximately 4,000 homes had lead service lines in Edmonton on either the EPCOR side or the homeowner side, or both. These are homes located in older neighbourhoods that were typically built before 1950. They represent about 1.4% of the approximately 274,000 homes in the City supplied with EPCOR water.

In 2019 the City of Edmonton approved a new Lead Mitigation Strategy. The goal of the program is to ensure that the lead concentration at the tap in all homes and businesses supplied through lead service lines in the City of Edmonton is less than the Health Canada Maximum Acceptable Concentration (MAC) for lead of 5 µg/L and to reduce lead release from all other sources of lead, such as lead-containing plumbing components, in all homes across the city. EPCOR's Lead Management Program has three main components:

1. **Adding a lead Inhibitor** (orthophosphate) to the Edmonton drinking water: Orthophosphate creates a protective coating on the inside of lead pipes and plumbing that prevents lead from leaching into drinking water. It is commonly used for this purpose by water utilities across North America and the United Kingdom. It has no impact on the taste or odour of drinking water. It is naturally present in food and is a common additive to beverages and considered to be a safe additive. Orthophosphate addition systems are being designed and constructed at our two water treatment plants and will be operational in 2023.
2. **Elimination of Partial Lead Service Line Replacements / Utility Funding of Private Portion Replacements:** EPCOR has ended the practice of replacing just the utility portion of a lead service line while leaving the private portion in place. These partial lead service line replacements are not effective for lead reduction and can sometimes result in higher lead levels at the tap. EPCOR will replace from the LSL from "main to meter". That is, we will replace the private portion any time we replace the utility portion. Both the utility and private portion replacements will be funded through water utility rates at no cost to the recipient.
3. **Accelerated Replacement of High Priority Lead Service Lines / Utility Funding of Private Portion Replacements:** EPCOR will accelerate the replacement of any lead service lines (private and utility portions) that have been identified through testing as having lead levels in excess of the new Health Canada Guideline after the implementation of orthophosphate. Both the utility and private portion replacements for these "High Priority" LSLs will be funded through water utility rates at no cost to the recipient. Since the start of the program in 2020, 280 high priority lead service lines have been replaced



### Annual Totals for Accelerated replacement of High Priority Lead Service Lines

Replacements	Year			Grand Total
	2020	2021	2022	
High Priority Lead Service Lines	69	144	67	280
Full Replacement	37	71	30	138
Private Side Only	28	54	34	116

EPCOR completed the construction of facilities to add the lead inhibitor orthophosphate to the Edmonton drinking water in 2022. Commissioning of those facilities and the start of orthophosphate will be occurring in the first quarter of 2023.

Orthophosphate is the final stage of EPCOR's Lead Mitigation Strategy and it will ensure that lead levels remain low in all other homes/businesses with lead service lines, but ongoing customer communication and monitoring for lead at the tap will be required. EPCOR will develop a comprehensive monitoring plan that will include lead at the tap in 2023 and beyond to ensure the effectiveness of lead reduction through the addition of orthophosphate.

## 7.18 REPORTABLE DETECTION LIMITS

Analyte	RDL	Unit
Alkalinity phenolphthalein	3	mg CaCO <sub>3</sub> /L
Alkalinity Total	6	mg CaCO <sub>3</sub> /L
Aluminum	0.005	mg/L
Ammonia as N	0.05	mg/L
Ammonia as NH <sub>3</sub>	0.05	mg/L
Antimony	0.0002	mg/L
Arsenic	0.0002	mg/L
Barium	0.002	mg/L
Benzene	0.5	µg/L
Beryllium	0.0002	mg/L
Bicarbonate	3	mg CaCO <sub>3</sub> /L
Boron	0.005	mg/L
Bromate Dissolved	0.005	mg/L
Bromide Dissolved	0.01	mg/L
Bromochloroacetic acid	1.0	ug/L
Bromodichloromethane	0.5	µg/L
Bromoform	1.0	µg/L
Cadmium	0.0002	mg/L
Calcium	0.1	mg/L
Calcium Dissolved	0.1	mg/L
Calcium Hardness	2	mg/L CaCO <sub>3</sub>
Carbon Tetrachloride	1.0	µg/L
Carbonate	3	mg/L CaCO <sub>3</sub>
Cellular ATP	0.1	pg/mL
Chlorate Dissolved	0.01	mg/L
Chloride Dissolved	0.1	mg/L
Chlorite Dissolved	0.005	mg/L
Chlorobenzene	0.5	µg/L
Chloroform	0.5	µg/L
Chromium	0.0002	mg/L
Cobalt	0.0002	mg/L
Coliforms, total	1.0	MPN/100 mL
Colour	0.5	TCU
Conductivity	1	µS/cm
Copper	0.005	mg/L
Copper Dissolved	0.005	mg/L
Cryptosporidium	0.1	oocysts/100L
Dibromoacetic acid	1.0	ug/L
Dibromochloromethane	0.5	µg/L
Dichloroacetic acid	2.0	ug/L
Dichlorobenzene (1,2)	0.5	µg/L
Dichlorobenzene (1,3)	0.5	µg/L
Dichlorobenzene (1,4)	0.5	µg/L
Dichloroethylene (1,1)	3.0	µg/L
Dichloroethylene, cis (1,2)	0.5	µg/L
Dichloroethylene, trans (1,2)	0.5	µg/L
Dichloropropane (1,2)	0.5	µg/L
Dissolved Organic Carbon	0.6	mg/L
E. coli	1.0	MPN/100 mL
Ethylbenzene	0.5	µg/L

## 7.18 REPORTABLE DETECTION LIMITS

Analyte	RDL	Unit
Fluoride	0.05	mg/L
Free Chlorine	0.03	mg/L
Giardia	0.1	cysts/100L
Haloacetic Acids, total (HAA5)	5.0	ug/L
Haloacetic Acids, total (HAA6)	5.0	ug/L
Iron	0.005	mg/L
Lanthanum	0.001	mg/L
Lead	0.0002	mg/L
Lithium	0.0002	mg/L
Magnesium	0.1	mg/L
Manganese	0.002	mg/L
Manganese Dissolved	0.002	mg/L
Mercury	0.0002	mg/L
Methyl t-Butyl Ether (MTBE)	0.5	µg/L
Methylene Chloride	0.5	µg/L
MIBK	1.0	µg/L
Microcystin	0.10	µg/L
Molybdenum	0.0002	mg/L
Monobromoacetic acid	1.0	ug/L
Monochloroacetic acid	5.0	ug/L
Nickel	0.0005	mg/L
Nitrate (as N) Dissolved	0.01	mg/L
Nitrite (as N) Dissolved	0.01	mg/L
Ortho_P	0.02	mg/L
Phosphorus	0.02	mg/L
Potassium	0.1	mg/L
Selenium	0.0002	mg/L
Silicon	0.05	mg/L
Silver	0.0002	mg/L
Sodium	0.1	mg/L
Strontium	0.002	mg/L
Styrene	0.5	µg/L
Sulphate Dissolved	0.2	mg/L
Tetrachloroethane (1,1,2,2)	1.0	µg/L
Tetrachloroethylene	0.5	µg/L
Thallium	0.0005	mg/L
Tin	0.0005	mg/L
Titanium	0.0005	mg/L
Toluene	0.5	µg/L
Total Chlorine	0.03	mg/L
Total Dissolved Solids	25	mg/L
Total Hardness	2	mg/L CaCO3
Total Kjeldahl Nitrogen	0.1	mg/L N
Total Organic Carbon	0.6	mg/L
Total Suspended Solids	5	mg/L
Total Volatile Organics (NonTHM)	1.0	µg/L
Total Volatile Organics (Unknown)	1.0	µg/L
Total Xylenes	2.5	µg/L
Trichloroacetic acid	3.0	ug/L
Trichlorobenzene (1,2,4)	0.5	µg/L
Trichloroethane (1,1,1)	0.5	µg/L
Trichloroethylene	0.5	µg/L

### 7.18 REPORTABLE DETECTION LIMITS

Analyte	RDL	Unit
Trihalomethanes	1.0	µg/L
Turbidity	0.04	NTU
Uranium	0.0005	mg/L
UV 254 % Transmittance	99.8	%T/cm
Vanadium	0.0005	mg/L
Xylene (1,2)	0.5	µg/L
Xylene (1,4)	0.5	µg/L
Zinc	0.005	mg/L
Zirconium	0.001	mg/L
Zirconium Dissolved	0.001	mg/L

## 7.18 REPORTABLE DETECTION LIMITS

Analyte	RDL	Unit
<b>Contract Lab Analysis</b>		
1,1,1-Trichloroethane	0.50	ug/L
1,1,2,2-Tetrachloroethane	0.50	ug/L
1,1,2-Trichloroethane	0.50	ug/L
1,1-Dichloroethane	0.50	ug/L
1,1-Dichloroethylene	0.50	ug/L
1,2,3-Trichlorobenzene	0.50	ug/L
1,2,3-Trichloropropane	0.50	ug/L
1,2,4-Trichlorobenzene	0.50	ug/L
1,2-Dibromoethane	0.50	ug/L
1,2-Dichlorobenzene	0.50	ug/L
1,2-Dichloroethane	0.50	ug/L
1,2-Dichloroethylene, cis	0.50	ug/L
1,2-Dichloroethylene, trans	0.50	ug/L
1,2-Dichloropropane	0.50	ug/L
1,3,5-Trichlorobenzene	0.50	ug/L
1,3-Dichlorobenzene	0.50	ug/L
1,3-Dichloropropylene, trans	0.50	ug/L
1,3-Dichloropropylene, cis	0.50	ug/L
1,4-Dichloro-2-butene, cis	5.0	ug/L
1,4-Dichloro-2-butene, trans	5.0	ug/L
1,4-Dichlorobenzene	0.50	ug/L
2,3,4,6-Tetrachlorophenol	0.50	µg/L
2,4,5-T	0.500	µg/L
2,4,6-Trichlorophenol	0.50	µg/L
2,4-D	0.500	µg/L
2,4-Dichlorophenol	0.30	µg/L
2-Hexanone	20	ug/L
6:2 Fluorotelomer sulfonic acid(6:2 FTS)	0.010	µg/L
8:2 Fluorotelomer sulfonic acid(8:2 FTS)	0.010	µg/L
Acetone	20	ug/L
a-chlordane	0.0080	µg/L
Acrolein	50	ug/L
Acrylonitrile	20	ug/L
Alachlor	0.10	µg/L
Aldicarb	1.0	µg/L
Aldrin	0.0080	µg/L
Ametryn	0.10	µg/L
Atrazine	0.10	µg/L
Atrazine Desethyl	0.10	µg/L
Atrazine+N-Dealkylated Metabolites	0.2	µg/L
Azinphos-methyl	0.10	µg/L
Bendiocarb	0.50	µg/L
Benzene	0.50	ug/L
Benzo(a)pyrene	0.0050	ug/L
Bromodichloromethane	0.50	ug/L
Bromoform	0.50	ug/L
Bromomethane	0.50	ug/L
Bromoxynil	0.500	µg/L
BTEX, Total	1.0	ug/L
Carbaryl	0.20	µg/L
Carbofuran	0.20	µg/L

## 7.18 REPORTABLE DETECTION LIMITS

Analyte	RDL	Unit
Carbon Disulfide	0.50	ug/L
Carbon tetrachloride	0.50	ug/L
Cesium-137	0.08	Bq/L
Chlorobenzene	0.50	ug/L
Chloroethane	0.50	ug/L
Chloroform	0.50	ug/L
Chloromethane	5.00	ug/L
Chlorpyrifos	0.10	µg/L
Cyanazine	0.10	µg/L
Cyanide Dissolved	0.002	mg/L
Diazinon	0.10	µg/L
Dibromochloromethane	0.50	ug/L
Dibromoethane	0.50	ug/L
Dicamba	1.00	µg/L
Dichlorodifluoromethane	0.50	ug/L
Dichloromethane	1.00	ug/L
Diclofop-methyl	0.10	µg/L
Dieldrin	0.0080	µg/L
Dimethoate	0.10	µg/L
Dinoseb	0.500	µg/L
Diquat	1.0	µg/L
Diuron	1.0	µg/L
Ethanol	250	ug/L
Ethyl Methacrylate	5.0	ug/L
Ethylbenzene	0.50	ug/L
gamma-hexachlorocyclohexane	0.0080	µg/L
g-chlordane	0.0080	µg/L
Glyphosate	0.20	µg/L
Gross Alpha	0.12	Bq/L
Gross Beta	0.06	Bq/L
Heptachlor	0.0080	µg/L
Heptachlor Epoxide	0.0080	µg/L
Iodine-131	0.2	Bq/L
Iodomethane	0.50	ug/L
Lead-210	0.02	Bq/L
m+p-Xylene	0.40	ug/L
Malathion	0.10	µg/L
MCPA	0.500	µg/L
Mercury	0.0000500	mg/L
Methoxychlor	0.0080	µg/L
Methyl Ethyl Ketone (MEK)	20	ug/L
Methyl Isobutyl Ketone (MIBK)	20	ug/L
Methyl Parathion	0.10	µg/L
Metolachlor	0.10	µg/L
Metribuzin	0.10	µg/L
NDMA	0.00090	µg/L
Nitrilotriacetic acid	0.20	mg/L
op-DDT	0.0040	µg/L
Oxychlordane	0.0080	µg/L
o-Xylene	0.30	ug/L
Paraquat	1.0	µg/L
Parathion	0.10	µg/L

## 7.18 REPORTABLE DETECTION LIMITS

Analyte	RDL	Unit
Pentachlorophenol	0.50	µg/L
Perfluorobutane sulfonic acid (PFBS)	0.020	µg/L
Perfluorobutanoic acid [PFBA]	0.80	µg/L
Perfluoroheptanoic acid [PFHpA]	0.020	µg/L
Perfluorohexanesulfonic acid [PFHxS]	0.020	µg/L
Perfluorohexanoic acid [PFHxA]	0.020	µg/L
Perfluorononanoic acid [PFNA]	0.020	µg/L
Perfluorooctanesulfonic acid [PFOS]	0.010	µg/L
Perfluorooctanoic acid (PFOA)	0.010	µg/L
Perfluoropentanoic acid (PFPeA)	0.020	µg/L
Phorate	0.10	µg/L
Picloram	1.00	µg/L
pp-DDD	0.0040	µg/L
pp-DDE	0.0040	µg/L
pp-DDT	0.0040	µg/L
Prometon	0.10	µg/L
Prometryne	0.10	µg/L
Propazine	0.10	µg/L
Radium-226	0.005	Bq/L
Simazine	0.10	µg/L
Strontium-90	0.05	Bq/L
Styrene	0.50	ug/L
Sulphide	0.002	mg/L
Temephos	1.0	µg/L
Terbufos	0.10	µg/L
Terbutryn	0.10	µg/L
Tetrachloroethylene	0.50	ug/L
Toluene	0.50	ug/L
Triallate	0.10	µg/L
Trichlorofluoromethane	0.50	ug/L
Trichloroethylene	0.50	ug/L
Trifluralin	0.10	µg/L
Trihalomethanes (THMs), Total	1.0	ug/L
Tritium	40	Bq/L
Vinyl chloride	0.50	ug/L
Xylenes, Total	0.50	ug/L

## 7.19 EXPLANATION OF NOTATIONS USED

Concentrations are reported as mg/L unless otherwise indicated.  
Alkalinity and Hardness (Ca and Total) are reported as mg CaCO<sub>3</sub>/L

%T	= % Transmission
- ve	= Absent
+ ve	= Present
µg/L	= Micrograms per litre (1 µg/L = 0.001 mg/L)
µS/cm	= Microsiemens per centimeter (unit of conductivity)
2/Y	= Twice per Year
AO	= Aesthetic Objective
Bq/L	= Becquerel(s) per litre (unit of radionuclide concentration)
CCPP	= Calcium Carbonate Precipitation Potential
CFU	= Colony Forming Units
Comm	= Commercial Laboratories
D	= Daily
EWSI	= EPCOR Water Services Inc.
FPA	= Flavour Profile Analysis
GCDWQ	= Guidelines for Canadian Drinking Water Quality
GM	= Geometric Mean
HPC	= Heterotrophic Plate Count
inoff	= Inoffensive (no objectionable odour)
M	= Monthly
MAC	= Maximum Acceptable Concentration
MDL	= Method Detection Limit
N/A	= Not Available
ND	= Not Detected
NTU	= Nephelometric Turbidity Units
PA	= Presence/Absence Testing
PBR	= Performance Based Rates
PHP	= phenolphthalein
PLPH	= Provincial Laboratory of Public Health
ppb	= Parts Per Billion
ppm	= Parts Per Million
Q	= Quarterly
QA	= Quality Assurance
QC	= Quality Control
RDL	= Reportable Detection Limit
TCU	= True Colour Units
TDS	= Total Dissolved Solids
TOC	= Total Organic Carbon
WL	= Water Laboratory
WTP	= Water Treatment Plant