

**2.2.1 Bacteriological Data: Water Treatment Plants  
2023**

	Coliforms, total					E. coli					cATP (pg/mL)				
	Count	# +ve	% +ve	Mean	Min	Max	# +ve	% +ve	Mean	Min	Max	Count	Mean	Min	Max
<b>January</b>															
Rossdale Raw (MPN/100mL)	31			84	24	308			4	1	26	1	27.2	27.2	27.2
E.L. Smith Raw (MPN/100mL)	4			72	40	120			1	1	1	0			
<b>Raw River Water Entering the Treatment Plants</b>	<b>35</b>			<b>83</b>	<b>24</b>	<b>308</b>			<b>4</b>	<b>1</b>	<b>26</b>	<b>1</b>	<b>27.2</b>	<b>27.2</b>	<b>27.2</b>
Rossdale Treated (PA/100mL)	31	0	0.0				0	0.0				31	0.69	0.10	1.99
E.L. Smith Treated (PA/100mL)	31	0	0.0				0	0.0				31	0.65	0.11	1.00
<b>Water Entering the Plant Reservoir</b>	<b>62</b>	<b>0</b>	<b>0.0</b>				<b>0</b>	<b>0.0</b>				<b>62</b>	<b>0.67</b>	<b>0.10</b>	<b>1.99</b>
Rossdale Reservoir (PA/100mL)	31	0	0.0				0	0.0				31	0.71	0.12	1.07
E.L. Smith Reservoir (PA/100mL)	31	0	0.0				0	0.0				31	0.60	0.13	1.81
<b>Treated Water Entering the Distribution System</b>	<b>62</b>	<b>0</b>	<b>0.0</b>				<b>0</b>	<b>0.0</b>				<b>62</b>	<b>0.66</b>	<b>0.12</b>	<b>1.81</b>
<b>February</b>															
Rossdale Raw (MPN/100mL)	28			65	21	166			9	1	24	1	32.2	32.2	32.2
E.L. Smith Raw (MPN/100mL)	4			36	25	51			1	1	1	1	27.0	27.0	27.0
<b>Raw River Water Entering the Treatment Plants</b>	<b>32</b>			<b>61</b>	<b>21</b>	<b>166</b>			<b>8</b>	<b>1</b>	<b>24</b>	<b>2</b>	<b>29.6</b>	<b>27.0</b>	<b>32.2</b>
Rossdale Treated (PA/100mL)	28	0	0.0				0	0.0				28	0.85	0.11	2.10
E.L. Smith Treated (PA/100mL)	28	0	0.0				0	0.0				28	0.82	0.10	2.51
<b>Water Entering the Plant Reservoir</b>	<b>56</b>	<b>0</b>	<b>0.0</b>				<b>0</b>	<b>0.0</b>				<b>56</b>	<b>0.84</b>	<b>0.10</b>	<b>2.51</b>
Rossdale Reservoir (PA/100mL)	28	0	0.0				0	0.0				28	0.76	0.10	1.71
E.L. Smith Reservoir (PA/100mL)	28	0	0.0				0	0.0				28	0.77	0.11	2.25
<b>Treated Water Entering the Distribution System</b>	<b>56</b>	<b>0</b>	<b>0.0</b>				<b>0</b>	<b>0.0</b>				<b>56</b>	<b>0.77</b>	<b>0.10</b>	<b>2.25</b>

**2.2.1 Bacteriological Data: Water Treatment Plants  
2023**

	Coliforms, total					E. coli					cATP (pg/mL)				
	Count	# +ve	% +ve	Mean	Min	Max	# +ve	% +ve	Mean	Min	Max	Count	Mean	Min	Max
<b>March</b>															
Rossdale Raw (MPN/100mL)	31			264	16	980			31	1	115	1	68.3	68.3	68.3
E.L. Smith Raw (MPN/100mL)	5			19	13	29			1	1	2	1	21.7	21.7	21.7
<b>Raw River Water Entering the Treatment Plants</b>	36			230	13	980			27	1	115	2	45.0	21.7	68.3
Rossdale Treated (PA/100mL)	31	0	0.0				0	0.0				31	0.71	0.11	1.47
E.L. Smith Treated (PA/100mL)	31	0	0.0				0	0.0				31	0.69	0.10	1.59
<b>Water Entering the Plant Reservoir</b>	62	0	0.0				0	0.0				62	0.70	0.10	1.59
Rossdale Reservoir (PA/100mL)	31	0	0.0				0	0.0				31	0.85	0.12	1.00
E.L. Smith Reservoir (PA/100mL)	31	0	0.0				0	0.0				31	0.70	0.11	1.00
<b>Treated Water Entering the Distribution System</b>	62	0	0.0				0	0.0				62	0.78	0.11	1.00
<b>April</b>															
Rossdale Raw (MPN/100mL)	30			224	42	1,200			15	2	50	1	207	207	207
E.L. Smith Raw (MPN/100mL)	4			52	15	88			1	1	2	1	186	186	186
<b>Raw River Water Entering the Treatment Plants</b>	34			203	15	1,200			13	1	50	2	197	186	207
Rossdale Treated (PA/100mL)	30	0	0.0				0	0.0				30	0.69	0.12	2.46
E.L. Smith Treated (PA/100mL)	30	0	0.0				0	0.0				30	0.64	0.10	2.28
<b>Water Entering the Plant Reservoir</b>	60	0	0.0				0	0.0				60	0.67	0.10	2.46
Rossdale Reservoir (PA/100mL)	30	0	0.0				0	0.0				30	0.73	0.10	2.42
E.L. Smith Reservoir (PA/100mL)	30	0	0.0				0	0.0				30	0.62	0.10	3.35
<b>Treated Water Entering the Distribution System</b>	60	0	0.0				0	0.0				60	0.68	0.10	3.35

**2.2.1 Bacteriological Data: Water Treatment Plants  
2023**

	Coliforms, total					E. coli					cATP (pg/mL)				
	Count	# +ve	% +ve	Mean	Min	Max	# +ve	% +ve	Mean	Min	Max	Count	Mean	Min	Max
<b>May</b>															
Rossdale Raw (MPN/100mL)	32			408	1	5,820			26	1	320	3	52.1	32.8	75.4
E.L. Smith Raw (MPN/100mL)	5			159	140	179			12	2	31	1	62.9	62.9	62.9
<b>Raw River Water Entering the Treatment Plants</b>	37			374	1	5,820			24	1	320	4	54.8	32.8	75.4
Rossdale Treated (PA/100mL)	31	0	0.0				0	0.0				31	0.67	0.11	1.46
E.L. Smith Treated (PA/100mL)	31	0	0.0				0	0.0				31	0.75	0.11	1.62
<b>Water Entering the Plant Reservoir</b>	62	0	0.0				0	0.0				62	0.71	0.11	1.62
Rossdale Reservoir (PA/100mL)	31	0	0.0				0	0.0				31	0.66	0.11	1.18
E.L. Smith Reservoir (PA/100mL)	31	0	0.0				0	0.0				31	0.70	0.11	1.01
<b>Treated Water Entering the Distribution System</b>	62	0	0.0				0	0.0				62	0.68	0.11	1.18
<b>June</b>															
Rossdale Raw (MPN/100mL)	30			3,552	66	31,100			171	1	1,720	1	54.5	54.5	54.5
E.L. Smith Raw (MPN/100mL)	4			6,767	219	24,100			247	22	828	1	125	125	125
<b>Raw River Water Entering the Treatment Plants</b>	34			3,931	66	31,100			180	1	1,720	2	89.5	54.5	125
Rossdale Treated (PA/100mL)	30	0	0.0				0	0.0				30	0.89	0.11	1.00
E.L. Smith Treated (PA/100mL)	30	0	0.0				0	0.0				30	0.78	0.11	1.15
<b>Water Entering the Plant Reservoir</b>	60	0	0.0				0	0.0				60	0.84	0.11	1.15
Rossdale Reservoir (PA/100mL)	30	0	0.0				0	0.0				30	0.81	0.12	1.00
E.L. Smith Reservoir (PA/100mL)	30	0	0.0				0	0.0				30	0.87	0.14	1.00
<b>Treated Water Entering the Distribution System</b>	60	0	0.0				0	0.0				60	0.84	0.12	1.00

## 2.2.1 Bacteriological Data: Water Treatment Plants

2023

	Coliforms, total					E. coli					cATP (pg/mL)				
	Count	# +ve	% +ve	Mean	Min	Max	# +ve	% +ve	Mean	Min	Max	Count	Mean	Min	Max
<b>July</b>															
Rossdale Raw (MPN/100mL)	32			3,797	1	48,400			237	1	1,980	1	148	148	148
E.L. Smith Raw (MPN/100mL)	4			926	613	1,550			31	11	45	1	47.7	47.7	47.7
<b>Raw River Water Entering the Treatment Plants</b>	<b>36</b>			<b>3,478</b>	<b>1</b>	<b>48,400</b>			<b>214</b>	<b>1</b>	<b>1,980</b>	<b>2</b>	<b>97.7</b>	<b>47.7</b>	<b>148</b>
Rossdale Treated (PA/100mL)	31	0	0.0				0	0.0				31	0.84	0.13	1.00
E.L. Smith Treated (PA/100mL)	31	0	0.0				0	0.0				31	0.82	0.12	1.00
<b>Water Entering the Plant Reservoir</b>	<b>62</b>	<b>0</b>	<b>0.0</b>				<b>0</b>	<b>0.0</b>				<b>62</b>	<b>0.83</b>	<b>0.12</b>	<b>1.00</b>
Rossdale Reservoir (PA/100mL)	31	0	0.0				0	0.0				31	0.79	0.10	1.00
E.L. Smith Reservoir (PA/100mL)	31	0	0.0				0	0.0				31	0.85	0.11	1.00
<b>Treated Water Entering the Distribution System</b>	<b>62</b>	<b>0</b>	<b>0.0</b>				<b>0</b>	<b>0.0</b>				<b>62</b>	<b>0.82</b>	<b>0.10</b>	<b>1.00</b>
<b>August</b>															
Rossdale Raw (MPN/100mL)	32			5,558	1	34,700			647	1	2,900	1	283	283	283
E.L. Smith Raw (MPN/100mL)	5			550	365	980			14	5	20	1	128	128	128
<b>Raw River Water Entering the Treatment Plants</b>	<b>37</b>			<b>4,881</b>	<b>1</b>	<b>34,700</b>			<b>561</b>	<b>1</b>	<b>2,900</b>	<b>2</b>	<b>205</b>	<b>128</b>	<b>283</b>
Rossdale Treated (PA/100mL)	31	0	0.0				0	0.0				31	0.70	0.14	1.00
E.L. Smith Treated (PA/100mL)	31	0	0.0				0	0.0				31	0.58	0.14	1.00
<b>Water Entering the Plant Reservoir</b>	<b>62</b>	<b>0</b>	<b>0.0</b>				<b>0</b>	<b>0.0</b>				<b>62</b>	<b>0.64</b>	<b>0.14</b>	<b>1.00</b>
Rossdale Reservoir (PA/100mL)	31	0	0.0				0	0.0				31	0.63	0.11	1.00
E.L. Smith Reservoir (PA/100mL)	31	0	0.0				0	0.0				31	0.66	0.12	1.00
<b>Treated Water Entering the Distribution System</b>	<b>62</b>	<b>0</b>	<b>0.0</b>				<b>0</b>	<b>0.0</b>				<b>62</b>	<b>0.64</b>	<b>0.11</b>	<b>1.00</b>

**2.2.1 Bacteriological Data: Water Treatment Plants  
2023**

	Coliforms, total					E. coli					cATP (pg/mL)				
	Count	# +ve	% +ve	Mean	Min	Max	# +ve	% +ve	Mean	Min	Max	Count	Mean	Min	Max
<b>September</b>															
Rossdale Raw (MPN/100mL)	31			230	1	1,300			21	1	124	1	78.8	78.8	78.8
E.L. Smith Raw (MPN/100mL)	4			232	86	488			35	6	77	1	72.1	72.1	72.1
<b>Raw River Water Entering the Treatment Plants</b>	35			231	1	1,300			23	1	124	2	75.5	72.1	78.8
Rossdale Treated (PA/100mL)	30	0	0.0				0	0.0				30	0.60	0.12	1.00
E.L. Smith Treated (PA/100mL)	30	0	0.0				0	0.0				30	0.66	0.12	1.06
<b>Water Entering the Plant Reservoir</b>	60	0	0.0				0	0.0				60	0.63	0.12	1.06
Rossdale Reservoir (PA/100mL)	30	0	0.0				0	0.0				30	0.48	0.12	1.00
E.L. Smith Reservoir (PA/100mL)	32	1	3.1				0	0.0				30	0.58	0.10	1.00
<b>Treated Water Entering the Distribution System</b>	62	1	1.6				0	0.0				60	0.53	0.10	1.00

PA = present or absent, MPN = most probable number, cATP = cellular adenosine triphosphate

**2.2.2 Bacteriological Data: Distribution System**  
**September 2023**

	Coliforms, total (PA/100 mL)			E. coli (PA/100 mL)		cATP (pg/mL)			
	Count	# +ve	% +ve	# +ve	% +ve	Count	Mean	Min	Max
<b>January</b>									
FIELD DISTRIBUTION	88	1	1.1	0	0.0	8	0.58	0.14	1.30
FIELD DISTRIBUTION - PLPH	56	0	0.0	0	0.0				
FIELD RESERVOIR	65	0	0.0	0	0.0	65	0.49	0.12	1.08
FIELD RESERVOIR - PLPH (duplicate-not counted)	65	0	0.0	0	0.0				
Monthly	209	1	0.5	0	0.0	73	0.50	0.12	1.30
<b>February</b>									
FIELD DISTRIBUTION	102	1	1.0	0	0.0	8	0.81	0.10	1.93
FIELD DISTRIBUTION - PLPH	56	0	0.0	0	0.0				
FIELD RESERVOIR	50	0	0.0	0	0.0	50	0.73	0.10	4.28
FIELD RESERVOIR - PLPH (duplicate-not counted)	50	0	0.0	0	0.0				
Monthly	208	1	0.5	0	0.0	58	0.74	0.10	4.28
<b>March</b>									
FIELD DISTRIBUTION	100	1	1.0	0	0.0	12	0.52	0.15	1.29
FIELD DISTRIBUTION - PLPH	56	0	0.0	0	0.0				
FIELD RESERVOIR	52	0	0.0	0	0.0	52	0.31	0.11	1.45
FIELD RESERVOIR - PLPH (duplicate-not counted)	51	0	0.0	0	0.0				
Monthly	208	1	0.5	0	0.0	64	0.36	0.11	1.45
<b>April</b>									
FIELD DISTRIBUTION	105	0	0.0	0	0.0	18	0.39	0.11	0.91
FIELD DISTRIBUTION - PLPH	55	0	0.0	0	0.0				
FIELD RESERVOIR	52	0	0.0	0	0.0	52	0.50	0.11	2.29
FIELD RESERVOIR - PLPH (duplicate-not counted)	52	0	0.0	0	0.0				
Monthly	212	0	0.0	0	0.0	70	0.46	0.11	2.29

**2.2.2 Bacteriological Data: Distribution System**  
**September 2023**

	Coliforms, total (PA/100 mL)			E. coli (PA/100 mL)		cATP (pg/mL)			
	Count	# +ve	% +ve	# +ve	% +ve	Count	Mean	Min	Max
<b>May</b>									
FIELD DISTRIBUTION	114	0	0.0	0	0.0	11	0.65	0.16	1.45
FIELD DISTRIBUTION - PLPH	56	0	0.0	0	0.0				
FIELD RESERVOIR	66	0	0.0	0	0.0	66	0.43	0.10	1.34
FIELD RESERVOIR - PLPH (duplicate-not counted)	64	0	0.0	0	0.0				
Monthly	236	0	0.0	0	0.0	77	0.45	0.10	1.45
<b>June</b>									
FIELD DISTRIBUTION	104	1	1.0	0	0.0	12	0.17	0.10	0.29
FIELD DISTRIBUTION - PLPH	56	0	0.0	0	0.0				
FIELD RESERVOIR	52	0	0.0	0	0.0	52	0.25	0.11	0.71
FIELD RESERVOIR - PLPH (duplicate-not counted)	52	0	0.0	0	0.0				
Monthly	212	1	0.5	0	0.0	64	0.24	0.10	0.71
<b>July</b>									
FIELD DISTRIBUTION	95	0	0.0	0	0.0	6	0.21	0.12	0.29
FIELD DISTRIBUTION - PLPH	56	0	0.0	0	0.0				
FIELD RESERVOIR	52	0	0.0	0	0.0	52	0.80	0.12	2.40
FIELD RESERVOIR - PLPH (duplicate-not counted)	51	0	0.0	0	0.0				
Monthly	203	0	0.0	0	0.0	58	0.77	0.12	2.40
<b>August</b>									
FIELD DISTRIBUTION	96	0	0.0	0	0.0	10	0.48	0.28	0.73
FIELD DISTRIBUTION - PLPH	56	0	0.0	0	0.0				
FIELD RESERVOIR	65	0	0.0	0	0.0	65	0.72	0.11	7.28
FIELD RESERVOIR - PLPH (duplicate-not counted)	64	0	0.0	0	0.0				
Monthly	217	0	0.0	0	0.0	75	0.69	0.11	7.28

**2.2.2 Bacteriological Data: Distribution System  
September 2023**

	Coliforms, total (PA/100 mL)			E. coli (PA/100 mL)		cATP (pg/mL)			
	Count	# +ve	% +ve	# +ve	% +ve	Count	Mean	Min	Max
<b>September</b>									
FIELD DISTRIBUTION	116	4	3.4	0	0.0	10	0.42	0.14	1.49
FIELD DISTRIBUTION - PLPH	55	0	0.0	0	0.0				
FIELD RESERVOIR	51	0	0.0	0	0.0	51	1.21	0.13	8.20
FIELD RESERVOIR - PLPH (duplicate-not counted)	50	0	0.0	0	0.0				
Monthly	222	4	1.8	0	0.0	61	1.08	0.13	8.20
Year to Date	1,927	8	0.4	0	0.0	600	0.62	0.10	8.20

Guidelines for Canadian Drinking Water Quality recommend 195 bacteriological samples for a city the size of Edmonton. Total Coliform and E.coli testing is required in the AEP Approval. At least 95 of the 195 samples must be tested at ProVLab each month according to our Operations Program.

Testing conducted by Laboratory for Provincial Laboratory for Public Health (ProvLAB) are labelled with PLPH.



**2.2.2 Bacteriological Data: Distribution System  
September 2023**

	Coliforms, total (PA/100 mL)			E. coli (PA/100 mL)		cATP (pg/mL)			
	Count	# +ve	% +ve	# +ve	% +ve	Count	Mean	Min	Max
<b>Samples from Complaints</b>									
January	12	1	8.3	0	0.0	8	0.58	0.14	1.30
February	8	0	0.0	0	0.0	8	0.81	0.10	1.93
March	16	1	6.3	0	0.0	12	0.52	0.15	1.29
April	18	0	0.0	0	0.0	18	0.39	0.11	0.91
May	11	0	0.0	0	0.0	11	0.65	0.16	1.45
June	12	0	0.0	0	0.0	12	0.17	0.10	0.29
July	6	0	0.0	0	0.0	6	0.21	0.12	0.29
August	10	0	0.0	0	0.0	10	0.48	0.28	0.73
September	17	1	5.9	0	0.0	10	0.42	0.14	1.49
Year to Date	110	3	2.7	0	0.0	95	0.48	0.10	1.93
<b>Samples from Depressurizations</b>									
January	54	0	0.0	0	0.0				
February	49	1	2.0	0	0.0				
March	60	0	0.0	0	0.0				
April	49	0	0.0	0	0.0				
May	68	0	0.0	0	0.0				
June	75	0	0.0	0	0.0				
July	72	1	1.4	0	0.0				
August	61	0	0.0	0	0.0				
September	74	7	9.5	0	0.0				
Year to Date	562	9	1.6	0	0.0				