

**2.2.1 Bacteriological Data: Water Treatment Plants
2024**

	Coliforms, total					E. coli					cATP (pg/mL)				
	Count	# +ve	% +ve	Mean	Min	Max	# +ve	% +ve	Mean	Min	Max	Count	Mean	Min	Max
January															
Rossdale Raw (MPN/100mL)	32			133	1	517			13	1	40	1	44.7	44.7	44.7
E.L. Smith Raw (MPN/100mL)	5			41	28	53			2	1	3	1	14.2	14.2	14.2
Raw River Water Entering the Treatment Plants	37			121	1	517			11	1	40	2	29.4	14.2	44.7
Rossdale Treated (PA/100mL)	31	0	0.0				0	0.0				31	0.44	0.10	1.00
E.L. Smith Treated (PA/100mL)	30	0	0.0				0	0.0				30	0.50	0.12	1.00
Water Entering the Plant Reservoir	61	0	0.0				0	0.0				61	0.47	0.10	1.00
Rossdale Reservoir (PA/100mL)	31	0	0.0				0	0.0				31	0.45	0.10	1.00
E.L. Smith Reservoir (PA/100mL)	30	0	0.0				0	0.0				30	0.52	0.10	1.00
Treated Water Entering the Distribution System	61	0	0.0				0	0.0				61	0.49	0.10	1.00

PA = present or absent, MPN = most probable number, cATP = cellular adenosine triphosphate

2.2.2 Bacteriological Data: Distribution System

January 2024

	Coliforms, total (PA/100 mL)			E. coli (PA/100 mL)		cATP (pg/mL)			
	Count	# +ve	% +ve	# +ve	% +ve	Count	Mean	Min	Max
January									
FIELD DISTRIBUTION	104	0	0.0	0	0.0	15	0.36	0.14	1.50
FIELD DISTRIBUTION - PLPH	55	1	1.8	0	0.0				
FIELD RESERVOIR	22	0	0.0	0	0.0	22	0.46	0.15	1.20
FIELD RESERVOIR - PLPH (duplicate-not counted)	22	0	0.0	0	0.0				
Monthly	181	1	0.6	0	0.0	37	0.42	0.14	1.50
Year to Date	181	1	0.6	0	0.0	37	0.42	0.14	1.50

Guidelines for Canadian Drinking Water Quality recommend 195 bacteriological samples for a city the size of Edmonton. Total Coliform and E.coli testing is required in the AEP Approval. At least 95 of the 195 samples must be tested at ProvLab each month according to our Operations Program.

Testing conducted by Laboratory for Provincial Laboratory for Public Health (ProvLAB) are labelled with PLPH.

2.2.2 Bacteriological Data: Distribution System
January 2024

		Coliforms, total (PA/100 mL)			E. coli (PA/100 mL)		cATP (pg/mL)			
		Count	# +ve	% +ve	# +ve	% +ve	Count	Mean	Min	Max
Samples from Complaints										
	January	15	0	0.0	0	0.0	15	0.36	0.14	1.50
	Year to Date	15	0	0.0	0	0.0	15	0.36	0.14	1.50
Samples from Depressurizations										
	January	70	0	0.0	0	0.0				
	Year to Date	70	0	0.0	0	0.0				