

## Lake Havasu

# Typical Water Quality Information

**PWSID Number:** 04-08-015

Area Served: Desert Hills, Sunlake Village, Northpoint, and the

Refuge communities.

### Where Does My Water Come From?

All of the water supplied by Arizona American Water comes from groundwater (wells) pumped from the Lake Havasu Basin.

The water supply is distributed for residential and commercial use.

### Average amount of water supplied to customers on a daily basis

715,500 gallons per day

| Parameter                    | Average or Range | Comments   |
|------------------------------|------------------|--|
| рН                           | 7.8 pH Units AV  | A measurement of water acidity, 7.0 is neutral       |
| Total Hardness<br>(as CaCO3) | NA mg/L          | No MCL - Naturally occurring                         |
| Total Hardness               | 11-40 gpg        | No MCL - Naturally occurring                         |
| Fluoride                     | 1.7-2 mg/L       | Naturally occurring from erosion of natural deposits |
| Sodium                       | 220-290 mg/L     | No MCL – Informational only                          |
| Iron                         | NA mg/L          | Secondary Standard Limit = 0.3 mg/L                  |

Typical Water Quality 1

| Parameter  | Average or<br>Range | Comments   |
|--|---------------------|--|
| Type of disinfection   | Chlorination        |  |
| Disinfectant residual level in the distribution system (average) | 0.3-1.1             | Maximum Residual Disinfectant Level based on Running Annual Avg. < or = 4.0 mg/L |
| Lead<br>[90 <sup>th</sup> percentile result]                     | 4 μg/L              | Action Level = 15 μg/L   |
| Copper [90 <sup>th</sup> percentile result]                      | 0.061 mg/L          | Action Level = 1.3 mg/L  |
| Nitrate as Nitrogen  | 1.9-6.5 mg/L        | MCL = 10 mg/L  |
| Arsenic  | 3-5 μg/L            | MCL = 10 μg/L  |
| Alkalinity as CaCO3, mg/L  | NA mg/l             | No MCL – Informational only  |
| Sulfate, mg/L  | 133-280 mg/L        | No MCL – Informational only  |
| Total Dissolved Solids,<br>mg/L                                  | 660-980 mg/L        | No MCL – Informational only  |

#### **Definitions**

- mg/L milligrams per liter; one milligram per liter is equal to one part per million, which is approximately the same as 1 second in 11.5 days
- μg/L micrograms per liter; one microgram per liter is equal to one part per billion, which is approximately the same as 1 second in 31.7 years
- N/A not applicable
- ND not detected
- MCL Maximum Contaminant Level the highest level of a contaminant allowed in drinking water under State and Federal regulations

For more information about water quality in your area, please contact Matt Giulioli at 928-763-0489

Other inquiries should be directed to our Customer Service Center at 1-800-383-0834

Typical Water Quality 2